

Combined
Sewer Overflow Study
for the
Hudson River Conference
August 1972
Interstate Sanitation Commission

**COMBINED
SEWER OVERFLOW STUDY
FOR THE
HUDSON RIVER CONFERENCE**



OFFICE USE

INTERSTATE SANITATION COMMISSION

New York
New Jersey
Connecticut

COMBINED SEWER OVERFLOW STUDY
FOR THE
HUDSON RIVER CONFERENCE

by

Interstate Sanitation Commission
10 Columbus Circle
New York, N.Y. 10019

for the

OFFICE OF ENFORCEMENT AND GENERAL COUNSEL
and the
OFFICE OF RESEARCH AND MONITORING
STORM AND COMBINED SEWER TECHNOLOGY PROGRAM
ENVIRONMENTAL PROTECTION AGENCY

Contract # 68-01-0055

August 1972

INTERSTATE SANITATION COMMISSION

10 Columbus Circle

New York, New York - 10019

COMMISSIONERS

NEW YORK

Natale Colosi, Ph.D.
Chairman
Henry L. Diamond
Chester Schwimmer
Oliver J. Troster

NEW JERSEY

Joseph J. Brennan
James R. Cowan, M. D.
Louis J. Fontenelli
Samuel P. Owen
Richard J. Sullivan

CONNECTICUT

John B. Dioguardi
Franklin M. Foote, M. D.
Robert K. Killian
Daniel W. Lufkin
H. Parker Sund

Thomas R. Glenn, Jr.
Director-Chief Engineer

EPA REVIEW NOTICE

This report has been reviewed by the Environmental Protection Agency and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the Environmental Protection Agency, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

ABSTRACT

A detailed examination was conducted of ten (10) combined sewer overflow systems within that portion of the Hudson River Basin lying within the Interstate Sanitation District. The work included the identification and study of these combined sewer systems in order to determine their location, physical characteristics, and service areas.

The procedure employed included the physical examination of each system's regulators to determine their location, type, dimensions, and condition. A study of available records was made to determine, where possible, trunk line flow, interceptor line design capacity, and characterization of the drainage area served by each regulator which included population and land use. Ten (10) summary tables and forty (40) regulator location figures are included in the report. Dry weather and wet weather sampling was also conducted. Bypass loadings for several pollution parameters have been calculated during storm flow conditions based upon this sampling. Recommendations for minimizing combined sewer overflows are included.

This report was submitted in fulfillment of Contract Number 68-01-0055, under the partial sponsorship of the Office of Enforcement and General Counsel, Environmental Protection Agency.

CONTENTS

<u>Section</u>		<u>Page</u>
I	Conclusions	1
II	Recommendations	5
III	Arrangement of the Report	7
IV	Introduction and Literature Review	25
V	General Discussion	29
VI	Bayonne Sewage Treatment Plant Drainage Basin, Bayonne, N.J.	35
VII	✓ Hoboken Sewage Treatment Plant Drainage Basin, Hoboken, N.J.	47
VIII	✓✓ Jersey City, East Side, Sewage Treatment Plant Drainage Basin, Jersey City, N.J.	55
IX	West New York Sewage Treatment Plant Drainage Basin, West New York, N.J.	69
X	✓✓ Newtown Creek Sewage Treatment Plant Drainage Basin, Brooklyn, Manhattan, and Queens, N.Y.	75
XI	North River Sewage Treatment Plant Drainage Basin, New York, N.Y.	123
XII	Owls Head Sewage Treatment Plant Drainage Basin, Brooklyn, N.Y.	155
XIII	Port Richmond Sewage Treatment Plant Drainage Basin, Staten Island, N.Y.	173
XIV	✓ Red Hook Sewage Treatment Plant Drainage Basin, Brooklyn, N.Y.	201
XV	Yonkers Joint Meeting Sewage Treatment Plant Drainage Basin, Yonkers, N.Y.	215
XVI	Regulator Sampling and Analyses	227

CONTENTS

<u>Section</u>		<u>Page</u>
XVII	Acknowledgements	271
XVIII	References	275
XIX	Appendices	279

TABLES

<u>Table</u>		<u>Page</u>
1	Bayonne Treatment Plant Drainage Basin, Bayonne, N.J.	36-41
2	Hoboken Treatment Plant Drainage Basin, Hoboken, N.J.	48-51
3	Jersey City, East Side Treatment Plant Drainage Basin, Jersey City, N.J.	56-62
4	West New York Treatment Plant Drainage Basin, West New York, N.J.	70-71
5-B	Newtown Creek Treatment Plant Drainage Basin, Brooklyn, N.Y.	76-81
5-M	Newtown Creek Treatment Plant Drainage Basin, New York, N.Y.	94-112
5-Q	Newtown Creek Treatment Plant Drainage Basin, Queens, N.Y.	82-83
6	North River Treatment Plant Drainage Basin, New York, N.Y.	124-141
7	Owls Head Treatment Plant Drainage Basin, Brooklyn, N.Y.	156-161
8	Port Richmond Treatment Plant Drainage Basin, Staten Island, N.Y.	174-187
9	Red Hook Treatment Plant Drainage Basin, Brooklyn, N.Y.	202-209
10	Yonkers Treatment Plant Drainage Basin, Yonkers, N.Y.	216-221
11	Land Use and Demographic Characteristics of Drainage Basin - Regulator 5, Ingham Avenue and East 5th Street, Bayonne, N.J.	231

TABLES

<u>Table</u>		<u>Page</u>
12	Sampling Results - Regulator 5, Ingham Avenue and East 5th Street, Bayonne, N.J.; dry weather sampling - April 5, 1972	234-235
13	Sampling Results - Regulator 5, Ingham Avenue and East 5th Street, Bayonne, N.J.; dry weather sampling - April 12, 1972	236
14	Land Use and Demographic Characteristics of Drainage Basin - Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.	241
15	Sampling Results - Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.; dry weather sampling - March 1, 1972	245
16	Sampling Results - Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.; dry weather sampling - March 8,9, 1972	246-247
17	Sampling Results - Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.; wet weather sampling - April 13, 1972	248-249
18	Summary Results - Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.; storm flow and pol- lution characteristics during storm of April 13, 1972	250
19	Sampling Results - Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.; wet weather sampling - June 16, 1972	258-259
20	Summary Results - Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.; storm flow and pol- lution characteristics during storm of June 15, 1972	260

FIGURES

<u>Figure</u>		<u>Page</u>
1	Location map of the ten drainage basins under study within Hudson River Conference area	9
2	Key map for figure locations for Bayonne, Jersey City, Hoboken, and West New York Sewage Treatment Plant Drainage Basins	11
3	Key map for figure locations for Newtown Creek Sewage Treatment Plant Drainage Basin (Brooklyn and Queens)	13
4	Key map for figure locations for Newtown Creek Sewage Treatment Plant Drainage Basin (Manhattan)	15
5	Key map for figure locations for North River Sewage Treatment Drainage Basin	17
6	Key map for figure locations for Owls Head and Red Hook Sewage Treatment Drainage Basins	19
7	Key map for figure locations for Port Richmond Sewage Treatment Plant Drainage Basin	21
8	Key map for figure locations for Yonkers Joint Meeting Sewage Treatment Plant Drainage Basin	23
9	Photographs: A - Standard preparation and setup for regulator inspection B - Field personnel entering manhole for regulator inspection	30 30
10	Photographs: A - Hydraulically operated sluice gate at Regulator 6 (Contract 2), Nicholas Avenue and Richmond Terrace, Port Richmond, N.Y. B - An outfall for one of the Port Richmond N.Y. regulators	33 33
11	Regulator location and drainage basins, Bayonne, N.J.; Regulators 1, 2, 5-12	43

FIGURES

<u>Figure</u>		<u>Page</u>
12	Regulator locations and drainage basins, Bayonne, N.J.; Regulators 3,4,13 through 18	45
13	Regulator location and drainage basins, Hoboken, N.J.; Regulators 1-7	53
14	Regulator location and drainage basins, Jersey City, East Side, N.J.; Regulators E-1, E-2	63
15	Regulator location and drainage basins, Jersey City, East Side, N.J.; Regulators E-3 through E-15	65
16	Regulator location and drainage basins, Jersey City, East Side, N.J.; Regulators E-16 through E-21	67
17	Regulator location and drainage basins, West New York, N.J.; Regulator 1	73
18	Regulator location and drainage basins, Newtown Creek, Brooklyn, N.Y.; Regulators B-3 through B-17	85
19	Regulator location and drainage basins, Newtown Creek, Brooklyn, N.Y.; Regulators B-1, B-1A, B-2, Q-1	87
20	Regulator location and drainage basins, Newtown Creek, Brooklyn, N.Y.; Portion of drainage basins	89
21	Regulator location and drainage basins, Newtown Creek, Brooklyn, N.Y.; Portion of drainage basins	91
22	Regulator location and drainage basins, Newtown Creek, New York, N.Y.; Regulator M-1	113

FIGURES

<u>Figure</u>		<u>Page</u>
23	Regulator location and drainage basins, Newtown Creek, New York, N.Y.; Regulators M-2 through M-9	115
24	Regulator location and drainage basins, Newtown Creek, New York, N.Y.; Regulators M-10 through M-13, M-17, M-19, M-21 through M-25	117
25	Regulator location and drainage basins, Newtown Creek, New York, N.Y.; Regulators M-26, M-29, M-30, M-32 through M-43B	119
26	Regulator location and drainage basins, Newtown Creek, New York, N.Y.; Regulators M-44 through M-51C	121
27	Regulator location and drainage basins, North River, New York, N.Y.; Regulators N-43, N-45 through N-51, N-53 through N-56	143
28	Regulator location and drainage basins, North River, New York, N.Y.; Regulators N-28 through N-34, N-36, N-38 through N-40, N-42	145
29	Regulator location and drainage basins, North River, New York, N.Y.; Regulators N-24, N-26, N-26A	147
30	Regulator location and drainage basins, North River, New York, N.Y.; Regulators N-18 through N-23	149
31	Regulator location and drainage basins, North River, New York, N.Y.; Regulators N-1, N-3 through N-10, N-12 through N-17	151
32	Regulator location and drainage basins, North River, New York, N.Y.; Portion of drainage basins	153

FIGURES

<u>Figure</u>		<u>Page</u>
33	Regulator location and drainage basins, Owls Head, Brooklyn, N.Y.; Regulators 9A	163
34	Regulator location and drainage basins, Owls Head, New York, N.Y.; Regulators 1 through 3, 9	165
35	Regulator location and drainage basins, Owls Head, Brooklyn, N.Y.; Regulators 4 through 7D	167
36	Regulator location and drainage basins, Owls Head, Brooklyn, N.Y.; Portions of drainage basins	169
37	Regulator location and drainage basins, Owls Head, Brooklyn, N.Y.; Regulators 8 through 8B	171
38	Regulator location and drainage basins, Port Richmond, Staten Island, N.Y.; Regulators R-1 through R-5 (Contract 4-A)	189
39	Regulator location and drainage basins, Port Richmond, Staten Island, N.Y.; Regulators R-6 through R-22	191
40	Regulator location and drainage basins, Port Richmond, Staten Island, N.Y.; Regulators R-23 through R-37	193
41	Regulator location and drainage basins, Port Richmond, Staten Island, N.Y.; Regulators R-1 through R-5 (Contract 2)	195
42	Regulator location and drainage basins, Port Richmond, Staten Island, N.Y.; Portion of drainage basins	197
43	Regulator location and drainage basins, Port Richmond, Staten Island, N.Y.; Portion of drainage basins	199

FIGURES

<u>Figure</u>		<u>Page</u>
44	Regulator location and drainage basins, Red Hook, Brooklyn, N.Y.; Regulators R-1 through R-19A	211
45	Regulator location and drainage basins, Red Hook, Brooklyn, N.Y.; Regulators R-20, R-21	213
46	Regulator location and drainage basins, Yonkers Joint Meeting, Yonkers, N.Y.; Regulators 1 through 6, 11 through 18	223
47	Regulator location and drainage basins, Yonkers Joint Meeting, Yonkers, N.Y.; Regulators 7 through 10	225
48	Land Use map for Regulator 5, Ingham Avenue and East 5th Street, Bayonne, N.J.	229
49	Location plan for Regulator 5, Ingham Avenue and East 5th Street, Bayonne, N.J.	232
50	Photographs: A - Trunk line flow to regulator chamber at Regulator 5, Ingham Avenue and East 5th Street, Bayonne, N.J. B - Outfall for Regulator 5, Ingham Avenue and East 5th Street, Bayonne, N.J.	233 233
51	Land use map for Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.	239
52	Location plan for Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.	242
53	Photographs: A - Hydraulically operated sluice gate at Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y. B - Outfall for Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.	243 243

FIGURES

<u>Figure</u>		<u>Page</u>
54	Total Suspended Solids versus Time during storm of April 13, 1972 at Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.	251
55	B.O.D. versus Time during storm of April 13, 1972, at Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.	253
56	Oil and Grease versus Time during storm of April 13, 1972 at Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.	255
57	Total Suspended Solids versus Time during storm of June 16, 1972 at Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.	261
58	B.O.D. versus Time during storm of June 16, 1972 at Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.	263
59	Oil and Grease versus Time during storm of June 16, 1972 at Regulator B-1, Johnson Avenue, east of Morgan Avenue, Brooklyn, N.Y.	265
60	Key to line designations for a typical regulator	279

SECTION I

CONCLUSIONS

From the information collected in the course of this study, much insight was gained into the status of the ten sewage collection systems contained in that portion of the Hudson River Basin which lies within the District waters of the Interstate Sanitation Commission. Based upon this study, we have reached the following conclusions:

- 1) The general condition of the ten sewage systems which were studied indicates that more attention needs to be given to the operation, performance, efficiency, and maintenance of the regulators.
- 2) Within six of the systems inspected, over 25% of the regulators were inoperable. The severity of conditions which resulted in regulator inoperability ranged from the need for adjustments to the need for complete overhaul.
- 3) In far too many cases, the personnel assigned to regulator maintenance duty are not properly equipped with either maintenance tools or the necessary safety equipment to properly service the regulators. A noticeable lack of understanding on the part of many of the maintenance personnel as to the purpose and proper operation of regulators was evident during field inspection. Additionally, many of the regulators were intentionally jammed or chained in the open position to maximize wet weather flow to the treatment plant. This can create a three-fold problem of (a) an imbalance of sewage mixture from each regulator drainage basin during wet weather flow; (b) an unreasonably high wet weather flow to the treatment plant which in turn minimizes the effective treatment of this sewage; and (c) a surcharge of the interceptor system with associated local flooding of sewage into streets and basements.
- 4) With the exception of the Hoboken, New Jersey sewage system, ingress and egress to regulators were through manholes. The small size of the manholes required that personnel had to climb down inadequately sized ladder rungs for access to the regulator chamber. This made maintenance and inspection of equipment difficult and in many cases dangerous. Such conditions are definite deterrents to creating an environment conducive to proper and systematic maintenance of regulator equipment.
- 5) In many cases, adequate data relating to demographic and hydraulic characteristics for each regulator drainage basin

were either not available or were outdated or incomplete.

6) No remote sensing devices are presently installed on any of the regulators or tide gates to indicate whether the regulator or tide gate is operating properly. Thus, only time-consuming inspection techniques can be utilized to determine when and where a regulator gate, orifice, or tide gate is jammed or clogged and creating a condition of prolonged dry weather bypassing or salt water intrusion into the system.

7) It is strongly felt that in comparison to the attention given to treatment plant efficiencies, too little attention is given to the operation, performance, maintenance, and efficiency of regulators which are a vital part of the sewage system. In fact, the sewage network should be treated as an integral part of the total system of collection and treatment.

8) Field inspections of tide gates and regulators revealed instances where control equipment, i.e., hand cranks and chains, were so severely corroded that they could impair the proper functioning of the equipment. In these cases, tide gates or regulators could jam during dry weather flow such that effluent would bypass the treatment plant.

9) Wet weather sampling conducted at Regulator B-1, located in the Newtown Creek Treatment Plant drainage basin, exhibited a very pronounced first flush phenomena. The quantities of pollutants such as solids, BOD, and oil and grease which are bypassed during a storm are extremely high; for example, during the storm of June 16, 1972, which spanned a 4-hour period and had a peak intensity of 0.65 inches in 1 hour, over 1,000,000 pounds of total suspended solids, 36,000 pounds of BOD, and 180,000 pounds (24,000 gallons) of oil and grease were bypassed. During this period of bypassing (about 4 hours), approximately 30 times as much suspended solids were bypassed as are discharged from the treatment plant in a full 24-hour normal dry weather flow period. The respective maximum concentrations (Mg/L) for TSS, BOD, and oil and grease were 20,000, 465, and 4,300 during this storm. These values, together with those found for heavy metals, confirm that a high priority needs to be given to the pre-treatment of industrial wastes and source control to minimize their deposition on streets and subsequent contamination of runoff water.

10) In view of the tremendous quantities of pollutants bypassed during the rainfall from this combined sewer system, it does not seem reasonable to debate whether secondary treatment plants should be designed for 80, 85, or 90% BOD or suspended solids removal when in fact the small increments

gained in this range are completely overshadowed by the bypassing occurring at regulators during wet weather flow.

11) The necessary improvement in the quality of receiving waters and the reopening of beaches will not be accomplished by the multi-billion dollar treatment plant upgrading and expansion program now going on within the District, and the monies spent for this construction in large part will be wasted if means of mitigating the effects of combined sewers are not found.

ge
m
nt.

e

ed
ted
f
re

xe
rm.

nize
of

tem,

ents

SECTION II

RECOMMENDATIONS

Based upon the results of the study and the conclusions reached, the following are strongly recommended:

- 1) Greater emphasis needs to be placed on the establishment of significant programs to better maintain and regulate the overall performance and hence efficiency of combined sewer systems. Maintenance programs, inspection procedures, and surveillance networks need to be either established or better formulated to insure that optimal amounts of highly concentrated sewage be intercepted for treatment purposes.
- 2) Conventional methods of evaluating sewage treatment plant efficiencies by means of percentage removal of pollutants leaving compared to those entering the treatment plants need to be revised. Attention should also be given to evaluating the overall efficiency of a sewage network by considering the bypass discharge from regulators during dry and wet weather flows together with the effluent from treatment plants. The percent removal of pollutants would then be based on the quantity of sewage exiting from the entire system, i.e., treatment plant and regulator bypass as compared to the sewage entering the system.
- 3) Access to regulator equipment needs improvement. Certainly, in the design and construction of new regulators, the following should be provided: larger entrance openings to chambers, larger work areas within chambers, and space for the installation of lighting equipment within chambers. Emphasis should also be given to using the latest available construction materials which can best withstand the corrosive environment found within regulator chambers.
- 4) Initiation of training programs for regulator maintenance personnel for the purpose of giving instruction and stressing the importance of proper maintenance and operation of regulators is needed. Sufficient maintenance and safety equipment and supplies should also be provided to all regulator maintenance crews.
- 5) Increased types of information should be kept on a current basis for each regulator. This should include demographic and hydraulic data as well as information concerning bypass flows.
- 6) In addition to establishing a scheduled maintenance program for regulators and tide gates by trained field personnel, methods for minimizing the effects from combined

sewers on receiving waters need to be developed. In this regard, the following are suggested:

- (a) Consideration should be given to the installation of a monitoring system to signal to a central location whether a regulator or tide gate is in the open or closed position so that non-essential bypassing can be eliminated.
 - (b) Consideration should be given to flushing sewers during dry weather periods in order to eliminate solids buildup that may occur. Means of flushing, whether by use of small slugs of potable water or sewage treatment plant effluent recirculated into the system, need to be examined on a case-by-case basis.
 - (c) Consideration should be given to in-line sewage storage and optimization of regulator settings to enable as much of the first flush as possible to flow to treatment plants before the combined sewage is diverted by the regulators directly to the receiving waters.
 - (d) Consideration should be given to the construction of two dikes -- one extending from Fort Wadsworth on Staten Island and one from Nortons Point on Coney Island (see Figure 1). The purpose of these dikes would be to divert the flows which come through the Narrows into the Lower Bay away from the beaches for a longer period of time, thus improving the water quality at the beaches during and following wet weather periods.
- 7) A high priority should be given to the pretreatment of industrial wastes to remove heavy metals and other harmful constituents to the maximum extent possible. This will not only reduce their detrimental effects on treatment plants but also prevent them from being directly discharged into receiving waterways by regulators which bypass during wet weather conditions.
 - 8) Consideration should be given to the control of contaminants and debris in street runoff water. This should include improved street cleaning operations as well as source controls.
 - 9) The type of information developed in this study of ten sewerage systems is needed for the other areas of the Interstate Sanitation District. A similar study should be extended to these areas as soon as possible so that a definitive evaluation of the combined sewer overflow problem during dry and wet weather periods can be made.

SECTION III

ARRANGEMENT OF THE REPORT

This report is arranged in the following manner:
Sections I and II are the Conclusions and Recommendations of this study.

Section IV is the Introduction and Literature Review which contains the background information relating to the inception of this study and gives pertinent information obtained from a survey of the literature.

Section V is a General Discussion. It includes information on safety equipment precautions, procedures followed during regulator inspections, and some general comments on these inspections.

Sections VI through XV contain information on the ten drainage systems studied. Each section gives the specific results of the Interstate Sanitation Commission inspections of each regulator within the given drainage area including the operability of the regulator and information pertaining to the drainage area for each regulator. Each of the ten sections is arranged as follows: First there is a brief discussion of the system. This is followed by a table containing information describing each regulator. The data is presented in tabular form in order to condense the information as much as possible. Each table contains the following information (when available):

First page - regulator number
- location
- manufacturer
- type
- drainage area
- population data
- land use data
- trunk line mean dry weather flow (MDWF)
- interceptor design capacity

Continuing page - regulator number
- line size characteristics, line size and materials of construction of the interceptor (upstream and downstream), trunk, bypass, and outfall lines

- receiving waterway -- of outfall line
- inspection data -- findings of the ISC inspections (the latest information on the condition of the regulators are contained in the Notes on the bottom of the final table sheet)
- figure number -- directs the reader to the figure in which that regulator can be found on a map of the area

Following the table are figures (maps) which give the location for each regulator, the drainage area boundaries, the sizes and locations of interceptor lines, the locations of bypass and outfall lines, the locations of pump stations, and the treatment plant.

Following the sections on inspections and detailed information on each drainage area is Section XVI which details the Commission's sampling and analyses at two regulators within the study area. Additional land use and demographic characteristics of drainage areas relating to these regulators are also presented.

Appendices A, B, C, and D, respectively, are a figure depicting a schematic diagram of a typical regulator, a glossary of terms used in this report, a legend showing symbols used on the "key" and regulator maps, and a listing of terms used in Tables 18 and 20.

Following this section (Section III) is Figure 1 -- a location map showing the ten drainage basins that were studied in this report. This map is followed by Figures 2 through 8 which are "key maps" outlining figure locations within the drainage areas of the ten systems studied. The "key maps" also indicate the surrounding area of each map in a particular drainage basin.

FIG. 1 LOCATION MAP OF THE TEN DRAINAGE BASINS UNDER STUDY WITHIN HUDSON RIVER CONFERENCE AREA





FIG. 2 KEY MAP
FOR FIGURE LOCATIONS
FOR
BAYONNE, JERSEY CITY,
HOBOKEN, W. NEW YORK







FIG. 3 KEY MAP FOR FIGURE LOCATIONS FOR NEWTOWN CREEK (BROOKLYN)



**FIG. 4 KEY MAP
FOR FIGURE LOCATIONS
FOR NEWTOWN CREEK
(MANHATTAN)**






FIG. 5 KEY MAP FOR FIGURE LOCATIONS FOR NORTH RIVER



**FIG. 6 KEY MAP
FOR FIGURE LOCATIONS
FOR OWLS HEAD
AND RED HOOK**



**FIG. 7 KEY MAP
FOR FIGURE LOCATIONS
FOR PORT RICHMOND**




FIG. 8 KEY MAP
FOR FIGURE LOCATION
FOR YONKERS

SECTION IV

INTRODUCTION AND LITERATURE REVIEW

A sizable portion of the sewer systems within the Interstate Sanitation District are of the combined type and their effluents represent a major water pollution problem. As such, a comprehensive understanding and evaluation of these systems is a prerequisite to the achievement of water quality standards for the combined sewer receiving waters in the Interstate Sanitation District.

One of the recommendations of the Third Session Conference on the Hudson River (1) was that the Interstate Sanitation Commission undertake an examination of combined sewer overflows as the first stage in the development of a remedial program for this area. The Commission initiated its program which was subsequently augmented by a grant from the United States Environmental Protection Agency. The ten combined sewer systems investigated in this study were:

1. Bayonne, New Jersey
2. Hoboken, New Jersey
3. Jersey City East Side, New Jersey
4. West New York Joint Outlet, New Jersey
5. Newtown Creek, New York
6. Owls Head, New York
7. North River, New York
8. Port Richmond, New York
9. Red Hook, New York
10. Yonkers, New York

The report of this study includes findings, conclusions, and recommendations, together with identification and examination of regulators in these ten combined sewer systems. The procedures employed included inspection and examination of the combined sewer regulators to determine their locations, types, dimensions, and conditions and a study of available records concerning regulator hydraulic capacity as well as land use data and population densities of the drainage areas served by these regulators.

A sampling and analysis program was also conducted at two regulators to establish characteristic flow curves, analyze effluent species, and determine loadings for dry and wet weather flows. Grab samples of regulator flows were obtained at appropriate intervals. Composite samples, when required, were formed by combining these samples. All samples were analyzed by laboratory methods as specified in "Standard Methods of Water and Wastewater Analysis" (2) to determine their respective concentrations. Effluent loadings could

then be estimated by utilizing this data together with total runoff data as calculated by the rational formula $Q=CIA$ where:

Q = peak runoff
C = runoff coefficient
I = average rainfall intensity
A = drainage area

Section XVI describes the details involved in applying the rational method to this study.

In coordination with the preparation of this study, a literature search was conducted to ascertain pertinent background information.

A questionnaire study was conducted by the American Public Works Association. Their first report (3) was concerned with the extent of the overflow problem and its effect on the Nation's waterways. Some of the findings in their report were:

(a) A total of 10,025 regulators located at combined sewer overflow stations or other locations were used by the 641 jurisdictions surveyed. The most common regulator type was of the weir construction or static. The least common was the mechanical regulator, i.e., hydraulic cylinder, manual or automatic valves.

(b) The operational performance of all the regulators was rated about equal.

(c) Dry weather overflows were reported by 96% of the jurisdictions. Half of these overflows were the result of improper regulator operation and half by insufficient sewer capacity.

(d) Few of the jurisdictions surveyed monitored the quantity or quality of the combined sewer overflow.

In 1970, the American Public Works Association issued a second report (4). This study was primarily concerned with the design, operation, maintenance, and utilization of combined sewer overflow regulators. Several factors relative to the design and operation of regulators were found to be contributory to the pollution of receiving waters. They are:

(a) Regulator malfunctions which allow overflows during dry weather flow periods.

(b) Regulator malfunctions which allow overflow to continue for periods considerably longer than that required to protect the treatment plant.

(c) Tide gate malfunctions which fail to protect interceptor lines from the inflow or receiving waters.

This report also recommends improved regulator practices to reduce pollution. These include:

(a) Use of regulators which are sensitive to variations in hydraulic flow.

(b) Improved operations and maintenance procedures to increase efficiency and performance of existing regulators.

(c) Integration of individual regulators into a total system so as to have complete management of the regulators, interceptors, pump stations, and treatment plants.

(d) Use of instrumentation and remote control functions for control of interceptor flows upstream of regulators.

Both of the APWA reports recognize that the proper operation of the overflow regulator is a key factor in insuring the efficient operation of treatment plants and other control facilities.

Automated data acquisition and remote control functions of combined sewer systems have been reported in the literature. The City of Cincinnati (5) uses telemetered monitoring to detect regulator malfunctions and excess overflows. A visual display is utilized to locate the region of the overflows. The Minneapolis-St. Paul Sanitary District (6) has demonstrated reductions in combined sewer overflow pollution by utilizing a rather sophisticated regulator control system. The incidence of overflow was reduced by 88%. The project includes a computerized data acquisition and control system that permits remote control of modified regulators. Based upon rainfall and wastewater level measurements, storm flows can be diverted to interceptors for temporary storage.

The Cities of Detroit (7) and Seattle (8) have completed projects similar to a system developed in Minneapolis-St. Paul (6). They incorporate rain and sewer level sensors, computerized data acquisition and remote control operation of regulators and pump stations. The monitoring system provides data on which regulators are slow, overloaded, or

blocked as well as permitting first flush interception, selective retention and overflow.

The American Public Works Association has also published a manual of practice for combined sewer regulation and management (9). It provides guidelines for designs, application, instrumentation, operation, and maintenance of static, semi-automatic and automatic regulators. New concepts in regulator design are also presented. These include: fluidic devices, swirl (vortex) regulator/separators, spiral (helical) flow regulator/separators, stilling ponds, high side spill weirs, broadcrested inflatable fabric dams, and overall system remote positive control.

A study (10) of the management and control of combined sewer overflows presents various techniques and systems to control these overflows. These methods include physical-chemical treatment of overflows (11,12), underwater storage (13), or storm standby tanks (14). Other advance control systems include high-rate dual media filtration (15, 16), micro-straining (17), and screening/dissolved air flotation (18).

Additional studies (19,20, 21) have been performed relating urban storm runoff and the stormwater infiltration problem. It should be noted that in these studies as well as those mentioned previously, extrapolation of data is quite difficult due to differences in land use, population, and sewer system sizes.

Preliminary pollution model studies of the New York Harbor Area performed by the U.S. Corps of Engineers (22) have shown that two dikes - one extending from Fort Wadsworth on Staten Island and the other from Nortons Point on Coney Island (See Figure I) would tend to divert combined sewer overflow from the surrounding beaches as well as increasing the time before the overflow reached the beaches during and following wet weather periods. These studies have shown that additional effort is warranted to optimize the location, size and orientation of these dikes.

SECTION V

GENERAL DISCUSSION

The importance of safety cannot be overemphasized during field operations. Safety procedures and equipment must be specified in any inspection work involving entrance to regulator structures.

Safety Equipment:

The safety equipment utilized in the inspection and sampling of regulators in the Hudson River Conference study area is illustrated in Figure 9-A. The following is a list of the equipment used to permit safe inspection by crews within a regulator facility.

1. Oxygen Deficiency and Explosion Meter
2. Steel Tip Work Shoes and Rubber Boots
3. Explosion Proof Lights
4. Hard Hat
5. Rain Wear (rain garments and hip boots)
6. Rubber Gloves
7. Safety Harness and Lines
8. Manhole Cover Hooks
9. Road Safety Cones
10. Barricades
11. Flashing Hazard Warning Lights

It is strongly recommended that maintenance personnel for the purpose of inspection familiarize themselves with the proper use, limitations, and maintenance of this equipment prior to utilizing them in any inspection activities.

Regulator Inspection Procedure:

A typical inspection involves three major phases after verifying the regulator location with the use of map coordinates. These three phases are as follows:

- Phase 1 - Regulator Site Safety Inspection
- Phase 2 - Inspection of Regulator Equipment
- Phase 3 - Reports and/or Correction of Malfunctions

Phase 1 involves the positioning of road safety cones and hazard lights. A traffic controller should be used when manholes are located on roads. The oxygen deficiency and explosion meter is utilized to determine the air quality within the chamber. Usually the probe is inserted into the vent port on the manhole to take this measurement. If conditions are within prescribed safety requirements, the manhole



FIG. 9-A, STANDARD PREPARATION AND SET-UP FOR REGULATOR INSPECTION



FIG. 9-B, FIELD PERSONNEL ENTERING MANHOLE FOR REGULATOR INSPECTION

cover is removed to allow for additional venting and to permit entry of the crew. Prior to entry into the regulator chamber, the inspector should don the proper safety equipment. A minimum of two men should remain on the surface, one fully outfitted with a duplicate set of equipment in the event of an emergency.

Phase 2 consists of inspecting the regulator equipment, verifying the proper operation of the regulator and associated components, and checking the tide gate for proper seal. Visual inspections are also made of the chamber and of its condition, i.e., quantities of debris, oil, grit, and grease.

Phase 3 consists of recording all pertinent observations regarding nominal performance of the regulator and of any improper conditions. Sufficient information should be reported to permit repair crews to correct failures or clean regulators without additional utilization of the inspection crew.

General Inspection Observations:

The performance of maintenance operations on regulator systems was the most predominant problem reported by inspection crews. Access to regulator chambers was generally difficult due to a combination of bulky safety equipment (i.e., Scott Air Packs) and small manhole entry points. Ladder rungs proved to be too narrow and most times provided inadequate footing for inspection crews. Lighting within the regulator chambers was poor and made visual observations difficult. Since most of the regulators were located beneath heavily travelled streets, inspections had to be scheduled to minimize traffic interference.

Bypass lines had small manholes which made access difficult. As a result, tide gates were usually poorly maintained and accumulation of wood and other debris was common. (A coarse bar screen at the exit of the outfall would probably limit the entrance of this material into the bypass line.) Chains used to lift tide gates were missing or usually severely damaged due to corrosion and, as a result, proper seating of the tide gate was difficult to check. High tides occurring during daylight working hours severely limited the inspection crew from maintaining the tide gates.

Float wells usually had large accumulations of grit and grease. These deposits could not be cleaned easily because of the lack of high pressure water lines to wash down the chamber.

Regulators which were inspected and maintained on a routine basis by full-time regulator inspection crews provided more

efficient flow control to the sewage treatment plant.

A regulator typical of those found in this survey is shown in Figure 10-A. Figure 10-B is somewhat typical of the outfalls observed in this study.



FIG. 10-A, HYDRAULICALLY OPERATED SLUICE GATE AT REGULATOR 6
(CONTRACT 2), NICHOLAS AVENUE AND RICHMOND TERRACE,
PORT RICHMOND, NEW YORK




FIG. 10-B, AN OUTFALL FOR ONE OF THE PORT RICHMOND, NEW YORK,
REGULATORS

SECTION VI

BAYONNE SEWAGE TREATMENT PLANT DRAINAGE BASIN

BAYONNE, N.J.

The sewage system for Bayonne consists of eighteen mechanical float actuated regulators. The float position for these regulators is determined by the height of flow in the upstream interceptor line. Of the eighteen regulators within this system, overflow from ten regulators bypass to Newark Bay, five bypass to the Kill Van Kull, and three bypass to Upper New York Harbor.

Sewage from the West Side interceptor line flows by gravity to a pump station at East 23rd Street. It is then pumped eastward through a 30" Ø force main to a junction chamber on the East Side interceptor line. Storm water trunk lines have been installed along Avenue E, from East 27th Street south to East 8th Street. This storm flow is then pumped to the Kill Van Kull through a 300 MGD capacity pump station. A storm water pump station (shown on Figure 11) located at Garretson Avenue at the Kill Van Kull, acts to relieve flooding conditions from its low level drainage basin.

The maintenance personnel for the Bayonne sewage system consist of sewage treatment plant workers used on a rotational work assignment basis. Maintenance apparatus was somewhat limited, i.e., pick-up trucks, and the lack of sufficient equipment hindered inspection or maintenance.

During the Commission's inspections, nine of the system's eighteen regulators were found to be inoperable. A follow-up telephone conversation with the plant superintendent indicated that all regulators had been placed back into operable condition since our field investigation.

Additional information relative to the regulators found in this drainage area is shown in Table 1 and Figures 11 through 12.

TABLE 1 - BAYONNE TREATMENT PLANT DRAINAGE BASIN

BAYONNE, NEW JERSEY

Regulator Number	Location	Manufacturer (Reference Number)	Type	Drainage Area (Acres)	Population- Residential	Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
						Res.	Com.	Ind.	Oth.		
1	E. 19th St. and Avenue F	Brown & Brown No. 5-A	Hinged Gate with Mechanical Float System	65	1,000	30	5	45	20	N/A	N/A
2	E. 15th St. East of Avenue E	Brown & Brown No. 8	21" x 32 5/8" Hinged Gate with Mechanical Float System	252	8,700	80	15	0	5	N/A	N/A
3	E. 30th St. and Avenue F	Brown & Brown No. 1	12" x 12" Hinged Gate with Mechan- ical Float System	45	2,400	80	5	5	10	N/A	N/A
4	E. 34th St. and Avenue E	Brown & Brown No. 8-A	21" x 35 3/8" Hinged Gate with Mechanical Float System	215	11,600	90	5	0	5	N/A	N/A
5	Ingham Ave. and E. 5th Street	Brown & Brown No. 8-B	21" x 38 1/2" Hinged Gate with Mechanical Float System	219	10,000	40	15	35	10	N/A	N/A
6	Broadway & East 1st St.	Brown & Brown No. 1	12" x 12" Hinged Gate with Mechan- ical Float System	44	2,000	50	15	30	5	N/A	N/A
7	Avenue C & West 1st St.	Brown & Brown No. 3	12" x 18 3/4" Hinged Gate with Mechanical Float System	51	2,500	90	5	0	5	N/A	N/A

TABLE 1 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	Date	INSPECTION DATA		Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall			Operable (Yes or No)	Comments	
	Upstream	Downstream								
1	66" ϕ	72" ϕ	24" ϕ & 42" ϕ & 30" ϕ	42" ϕ & 30" ϕ	42" ϕ	Kill Van Kull	9-29-71	--	No access. An oil leak in vicinity of regulator chamber has saturated ground around chamber causing strong fumes in manhole.	11
2	72" ϕ	72" ϕ	54" ϕ	54" ϕ	54" ϕ	Kill Van Kull	9-29-71	No	Regulator gate jammed open - needs complete maintenance. Tide gate leaking -- needs cleaning.	11
3	54" ϕ	54" ϕ	30" ϕ	30" ϕ	30" ϕ	Upper New York Bay	9-29-71	No	Regulator gate jammed open, float chamber clogged. Tide gate leaking.	12
4	42" ϕ	48" ϕ	48" ϕ	Two 48" ϕ	72" ϕ	Upper New York Bay	9-29-71	No	Float chamber clogged. Regulator gate jammed in open position. Tide gate leaking.	12
5	42" ϕ	54" ϕ	60" ϕ	60" ϕ	60" ϕ	Kill Van Kull	9-29-71	Yes	Well maintained. Regulator gate and float operable. Slight flow from tide gate.	11
6	33" ϕ	36" ϕ	24" ϕ	24" ϕ	24" ϕ	Kill Van Kull	9-29-71	No	Float buried in grit. Cannot move regulator gate. Slight flow from tide gate.	11
7	30" ϕ	33" ϕ	24" ϕ	24" ϕ	24" ϕ	Kill Van Kull	9-29-71	No	Regulator gate frozen in open position.	11

TABLE 1 - BAYONNE TREATMENT PLANT DRAINAGE BASIN (Continued)

BAYONNE, NEW JERSEY

Regulator Number	Location	Manufacturer (Reference Number)	Type	Drainage Area (Acres)	Population- Residential	Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
						Res.	Com.	Ind.	Oth.		
8	Avenue A North of W. 3rd St.	Brown & Brown No. 0	7 1/2" x 15 3/8" Hinged Gate with Mechanical Float System	36	1,000	5	0	90	5	N/A	N/A
9	Avenue A South of W. 5th St.	Brown & Brown No. 1	12" x 12" Hinged Gate with Mechanical Float System	41	1,000	40	10	40	10	N/A	N/A
10	Edwards Court W. of Ave. A	Brown & Brown No. 7-0	5" x 6" Hinged Gate with Mechanical Float System	3	200	100	0	0	0	N/A	N/A
11	W. 16th St. West of Avenue A	Brown & Brown No. 4-0	7 1/2" x 7 3/4" Hinged Gate with Mechanical Float System	13	600	60	10	0	30	N/A	N/A
12	W. 22nd St. West of Avenue A	Brown & Brown No. 3	12" x 18" 3/4" Hinged Gate with Mechanical Float System	77	3,600	75	5	0	20	N/A	N/A
13	W. 24th St. West of Avenue A	Brown & Brown No. 4-0	7 1/2" x 7 3/4" Hinged Gate with Mechanical Float System	13	400	95	0	0	5	N/A	N/A
14	W. 25th St. West of Avenue A	Brown & Brown No. 3-A	12" x 21" Hinged Gate with Mechanical Float System	90	3,000	60	10	0	30	N/A	N/A
15	W. 30th St. West of Avenue A	Brown & Brown No. 6-0	5" x 7 1/2" Hinged Gate with Mechanical Float System	17	1,000	100	0	0	0	N/A	N/A

TABLE 1 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line Upstream	Interceptor Line Downstream	Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
8	24" ϕ	30" ϕ	Two 18" ϕ	24" ϕ	24" ϕ	Newark Bay	9-29-71	No	Regulator gate frozen in open position. Chain off regulator pulley. Tide gate open slightly.	11
9	--	24" ϕ	24" ϕ	24" ϕ	24" ϕ	Newark Bay	9-29-71	No	Floot covered with grit. Regulator gate not removable.	11
10	--	12" ϕ CA	12" ϕ CI	12" ϕ CI	12" ϕ CI	Newark Bay	3-27-72	--	No Access.	11
11	12" ϕ CA	18" ϕ CA	24" ϕ CI	24" ϕ CI	24" ϕ CI	Newark Bay	3-27-72	Yes	--	11
12	18" ϕ CA	24" ϕ CA	36" ϕ Steel	36" ϕ Steel	36" ϕ Steel	Newark Bay	3-27-72	Yes	--	11
13	48" ϕ CA	48" ϕ CA	16" ϕ	16" ϕ	16" ϕ	Newark Bay	3-27-72	Yes	--	12
14	42" ϕ RC	48" ϕ CA	36" ϕ Steel	36" ϕ Steel	36" ϕ Steel	Newark Bay	3-27-72	Yes	--	12
15	36" ϕ RC	42" ϕ RC	18" ϕ CI	18" ϕ CI	18" ϕ CI	Newark Bay	3-27-72	Yes	--	12

TABLE 1 - BAYONNE TREATMENT PLANT DRAINAGE BASIN (Continued)

BAYONNE, NEW JERSEY

Regulator Number	Location	Manufacturer (Reference Number)	Type	Drainage Area (Acres)	Population- Residential	Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
						Res.	Com.	Ind.	Oth.		
16	Lincoln Parkway West of Avenue A	Brown & Brown No. 6-A	16" x 30 7/8" Hinged Gate with Mechanical Float System	147	6,000	70	0	0	30	N/A	N/A
17	Hudson Blvd. & 59th St.	N/A	Hinged Gate with Mechanical Float System	109	4,300	55	20	15	10	N/A	N/A
18	E. 50th St. East of Avenue E	Brown & Brown No. 7-A	Hinged Gate with Mechanical Float System	159	7,200	70	20	5	5	N.A	N/A

NOTES FOR TABLE 1:

Regulator Data - taken from regulator detail sheets (1949-50) supplied by personnel at the Bayonne Treatment Plant.

Drainage Area Data - boundaries determined from City of Bayonne Existing Sewer Line Map (1962). Acreage calculated from the layout of drainage area boundaries.

Population Data - based on 1970 Federal Census (Census Tract P-1) supplied by personnel at Bayonne City Engineer's Office.

Land Use Data - estimated from City of Bayonne Zoning Map (1969).

Hydraulic Data - not available.

TABLE 1 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	Date	INSPECTION DATA		Figure No. for Location of Regulator
	Interceptor Line Upstream	Interceptor Line Downstream	Trunk Line	By-Pass Line	Outfall			Operable (Yes or No)	Comments	
16	36" ϕ RC	36" ϕ RC	36" ϕ CI	36" ϕ CI	36" ϕ CI	Newark Bay	3-27-72	Yes	--	12
17	--	33" ϕ	36" ϕ CB	36" ϕ CB	36" ϕ CB	Newark Bay	3-27-72	No.	This is a new regulator, recently built. It replaces Brown & Brown regulator No. 4-A which was at site and was removed because of new construction. Regulator gate was closed. Dry weather flow by-passing.	12
18	--	42" ϕ	48" ϕ	48" ϕ	48" ϕ	Upper New York Bay	9-29-71	No	Float weighted down to keep regulator gate in open position. Needs greasing and general maintenance. Tide gate jammed open -- fixed by crew while at chamber.	12

41

NOTES FOR TABLE 1 (CONTINUED):Line Size Characteristics - taken from regulator detail sheets and City of Bayonne Existing Sewer Line Map.Inspection Data - according to telephone conversation of May 19, 1972 with the Bayonne Treatment Plant Superintendent, all regulators which were found to be inoperable during inspections have been put in good condition.





FIG. II BAYONNE
HUDSON CO. N.J.
DRAINAGE BASIN
AND
REGULATOR LOCATIONS

FIG. 12 BAYONNE
HUDSON CO. N.J.
DRAINAGE BASIN
AND
REGULATOR LOCATIONS



SECTION VII

HOBOKEN SEWAGE TREATMENT PLANT DRAINAGE BASIN

HOBOKEN, N. J.

The Hoboken sewage system consists of seven regulators with two pump stations. All regulators have a dual system of mechanical float actuated hinged gates. The float position is determined by the flow height in the trunk line. All regulators bypass to the Hudson River during overflow conditions.

The regulators were designed with easy access, and all have large hinged metal doors opening to a staircase with ample head-room. Electric lighting and high ceilings provide satisfactory conditions in which to service and maintain the equipment.

The North pump station contains three electrically driven centrifugal pumps, each having a capacity of 4500 gpm. The South pump station contains three electrically driven centrifugal pumps, each having a capacity of 6200 gpm. This station has a 15" \emptyset emergency outfall.

Maintenance personnel for the Hoboken system consist of sewage treatment plant personnel. Maintenance apparatus includes a pick-up truck having limited equipment. As a result, maintenance and inspection procedures were hindered.

Inspection of the Hoboken sewage system indicated all regulators to be non-operable. A follow-up telephone conversation with the plant superintendent indicated that repair work is currently in operation on the north-end regulators.

Additional information relative to the regulators found in this drainage area is shown in Table 2 and Figure 13.

TABLE 2 - HOBOKEN TREATMENT PLANT DRAINAGE BASIN

HOBOKEN, NEW JERSEY

Regulator Number	Location	Manufacturer (Reference Number)	Type	Drainage Area (Acres)	Population- Residential	Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
						Res.	Com.	Ind.	Oth.		
1	Observer Highway & Court Alley	Brown & Brown Nos. 4-A & 5-A	12" x 26 5/16" & 16" x 25 5/8" Hinged Gates with Independent Mechanical Float Systems	124	N/A	80	5	10	5	N/A	N/A
2	River & Newark Streets	Brown & Brown Nos. 4-0 & 000	7 1/2" x 7 3/4" & 7 1/2" x 9 3/4" Hinged Gates with Independent Mechanical Float Systems	76	N/A	85	5	5	5	N/A	N/A
3	River & Third Streets	Brown & Brown Nos. 1 & 0	12" x 12" & 7 1/2" x 15 3/8" Hinged Gates with Independent Mechanical Float Systems	117	N/A	80	5	10	5	N/A	N/A
4	River & Fourth Streets	Brown & Brown Nos. 00 & 00	Two 7 1/2" x 12 3/8" Hinged Gates with Independent Mecha- nical Float Systems	114	N/A	80	5	5	10	N/A	N/A
5	Hudson & Eleventh Streets	Brown & Brown Nos. 1 & 0	12" x 12" & 7 1/2" x 15 3/8" Hinged Gates with Independent Mechanical Float Systems	177	N/A	50	5	40	5	N/A	N/A
6	Hudson & Four- teenth Streets	Brown & Brown Nos. 7-0 & 7-0	Two 5" x 6" Hinged Gates with Independent Mechanical Systems	21	N/A	60	5	30	5	N/A	N/A
7	Fourteenth Street North of Hudson Street	Brown & Brown Nos. 5-A & 0	Two 5" x 6" Hinged Gates with Independent Mechanical Systems	62	N/A	0	0	75	25	N/A	N/A

TABLE 2 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	Date	INSPECTION DATA		Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall			Operable (Yes or No)	Comments	
	Upstream	Downstream								
1	--	42" ϕ	96" x 48"	Two 48" ϕ CI	Two 48" ϕ CI	Hudson River	9-30-71	No	Regulator gate jammed open; floats under 6" of grit and debris; chains corroded.	13
2	42" ϕ	45" ϕ	42" ϕ	42" ϕ	2'-6" x 4'-0"	Hudson River	9-29-71	No	Float missing, chain broken, regulator gate jammed open. Tide gate clogged.	13
3	45" ϕ	48" ϕ	72" ϕ Brick	72" ϕ Brick	72" ϕ Brick	Hudson River	9-29-71	No	Regulator gate frozen open. Could not operate float. Debris in tide gate.	13
4	48" ϕ	48" ϕ	7'-0" x 4'-9"	7'-0" x 4'-9"	6'-0" x 4'-9" Wood	Hudson River	9-29-71	No	Could not operate float. Weight For float on work bench. Regulator gate frozen open.	13
5	36" ϕ	36" ϕ	36" ϕ & 60" ϕ	7'-0" x 4'-9"	7'-0" x 4'-9"	Hudson River	9-29-71	No	Regulator gate frozen open. Could not operate.	13
6	30" ϕ	36" ϕ	30" x 42" Brick	30" x 42" Brick	30" x 42" Brick	Hudson River	9-29-71	No	Regulator gate being held open with rope. Both floats broken.	13
7	--	30" ϕ	7'-0" x 4'-9"	7'-0" x 4'-9"	7'-0" x 4'-9"	Hudson River	9-29-71	No	Regulator gate frozen open. Grit and debris in float chamber.	13

TABLE 2 - HOBOKEN TREATMENT PLANT DRAINAGE BASIN (Continued)

HOBOKEN, NEW JERSEY

Regulator Number	Location	Manufacturer (Reference Number)	Type	Drainage Area (Acres)	Population- Residential	Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
						Res.	Com.	Ind.	Oth.		
South Pump Station	Fifth & River Streets	--	Electrically Driven Centrifugal	--	--	--	--	--	--	--	--
North Pump Station	Eleventh & Hudson Streets	--	Electrically Driven Centrifugal	--	--	--	--	--	--	--	--

NOTES FOR TABLE 2:

Regulator Data - taken from regulator detail sheets (1957) supplied by personnel at the Hoboken Treatment Plant.

Drainage Area Data - boundaries determined from City of Hoboken Existing Sewer Line Maps (1954). Acreage calculated from the layout of drainage area boundaries.

Population Data - not available.

Land Use Data - estimated from City of Hoboken Land Use Map (1950) prepared for the City of Hoboken Housing Authority.

Hydraulic Data - not available.


TABLE 2 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line Upstream	Trunk Line Downstream	By-Pass Line	Outfall	Date		Operable (Yes or No)	Comments		
South Pump Station	--	24" ϕ Force Main	--	15" ϕ	15" ϕ	Hudson River	9-30-71	Yes	Three Pumps with 6200 GPM Capacity Each.	13
North Pump Station	--	48" ϕ Force Main	--	--	--	--	9-30-71	Yes	Three Pumps with 4500 GPM Capacity Each.	13

NOTES FOR TABLE 2 (CONTINUED):

Line Size Characteristics - taken from regulator detail sheets and City of Hoboken Existing Sewer Line Maps.

Inspection Data - according to telephone conversation of May 19, 1972 with the Hoboken Treatment Plant Superintendent, plant personnel have been working on North End regulators since inspection.



SECTION VIII

JERSEY CITY EAST SIDE SEWAGE TREATMENT PLANT

DRAINAGE BASIN, JERSEY CITY, N.J.

The sewage system for the Jersey City, East Side drainage basin consists of twenty-one mechanical float actuated regulators. The float position for these regulators is determined by the height of flow in the upstream interceptor line. When overflow occurs, all regulators bypass to the Hudson River.

Regulator maintenance is performed by a five-man field crew. Their work assignments include servicing both the East Side and West Side treatment plant regulators (there are thirteen regulators in the West Side system). Maintenance equipment includes two trucks specially fitted for such work, as well as other necessary tools and gear to satisfactorily maintain the system.

Of the system's twenty-one regulators, eleven were found to be operable, seven were non-operable, and three could not be inspected since heavy equipment was not available to remove the concrete slab over access manhole covers.

A follow-up telephone conversation with the plant superintendent indicated that all regulators had been put in operable condition since our field investigation.

Additional information regarding the regulators with this drainage area is found in Table 3 and Figures 14 through 16.

TABLE 3 - JERSEY CITY, EAST SIDE TREATMENT PLANT DRAINAGE BASIN

JERSEY CITY, NEW JERSEY

Regulator Number	Location	Manufacturer (Reference Number)	Type	Drainage Area (Acres)	Population- Residential	Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
						Res.	Com.	Ind.	Oth.		
E-1	Brown Place East of Princeton Ave.	Brown & Brown No. 7	16" x 34 1/4" Hinged Gate with Mechanical Float System	207	15,500	70	15	10	5	N/A	N/A
E-2	Foot of Richard Street	Brown & Brown No. 5-A	16" x 24" Hinged Gate with Mechanical Float System	246	16,000	55	15	15	15	N/A	N/A
E-3	Foot of Phillip Street West of N. J. Tpk. overpass	Brown & Brown No. 5-A	16" x 24" Hinged Gate with Mechanical Float System	317	14,100	60	15	20	5	N/A	N/A
E-4	Foot of Phillip St. West of N. J. Tpk. overpass	Brown & Brown No. 1	12" x 12" Hinged Gate with Mechanical Float System								
E-5	Off Johnson St. Foot of Big Basin (Pine St. Regulator)	Brown & Brown No. 2	12" x 15" Hinged Gate with Mechanical Float System	203	4,300	35	15	40	10	N/A	N/A
E-6	Off Johnson St. Foot of Big Basin (Mill Creek Regulator)	Brown & Brown No. 9-B	21" x 47 5/8" Hinged Gate with Mechanical Float System	153	1,800	80	5	5	10	N/A	N/A
E-7	Washington St. South of Essex Street	Brown & Brown No. 7-0	5" x 6" Hinged Gate with Mechanical Float System	7	200	30	10	60	0	N/A	N/A

56

(Combined data for regulators E-3 and E-4)

TABLE 3 - (Continued)

Regu- lator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
E-1	--	42" ϕ RC	60" ϕ CB	60" ϕ CB	60" ϕ CB	Upper N.Y. Bay	9-22-71	No	Regulator gate jammed open. Float chamber flooded and filled with rocks & debris.	14
E-2	42" ϕ RC	54" ϕ RC	48" ϕ CI & 36" ϕ CI	54" ϕ CB	54" ϕ CB	Upper N.Y. Bay	9-7-71	--	No access - need heavy equipment to remove concrete slab over manhole cover.	14
E-3	54" ϕ RC	--	96" ϕ STEEL	96" ϕ STEEL	96" ϕ STEEL	Upper N.Y. Bay	9-22-71	Yes	Operable condition; however, heavy accumulation of grit & debris needs to be removed.	15
E-4	--	66" ϕ RC	72" ϕ CONC	72" ϕ CONC	72" ϕ CONC	Upper N.Y. Bay	9-22-71	Yes	Operable condition; however, heavy accumulation of grit & debris needs to be removed.	15
E-5	84" ϕ RC	84" ϕ RC	18'-0" x 7'-8" STEEL ARCH	18'-0" x 7'-8" STEEL ARCH	18'-0" x 7'-8" STEEL ARCH	Hudson River	9-23-71	--	Unable to make judgement since Crane necessary to lift cover & see floats.	15
(Data applies to regulators E-5 & E-6)										
E-6						Hudson River	9-23-71	--	Unable to make judgement since Crane necessary to lift cover & see floats.	15
E-7	36" ϕ RC BR INT	24" ϕ RC BR INT to 36" ϕ BR INT	48" x 36" OB	48" x 36" OB	48" x 36" OB	Hudson River	9-22-71	Yes	Clean and well maintained. Tide gate open slightly.	15

TABLE 3 - JERSEY CITY, EAST SIDE PLANT DRAINAGE BASIN (Continued)

JERSEY CITY, NEW JERSEY

Regulator Number	Location	Manufacturer (Reference Number)	Type	Drainage Area (Acres)	Population- Residential	Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
						Res.	Com.	Ind.	Oth.		
E-8	Essex St. East of Rudson St.	Brown & Brown No. 2	12" x 15" Hinged Gate with Mechanical Float System	26	1,000	10	5	75	10	N/A	N/A
E-9	Sussex St. East of Rudson St.	Brown & Brown No. 1	12" x 12" Hinged Gate with Mechanical Float System	3	100	5	5	90	0	N/A	N/A
E-10	Grand St. West of Bulkhead	Brown & Brown No. 4-0	7 1/2" x 7 3/4" Hinged Gate with Mechanical Float System	550	31,000	80	5	10	5	N/A	N/A
E-11	York St. West of Bulkhead	Brown & Brown No. 3	12" x 18 3/4" Hinged Gate with Mechanical Float System	233	8,400	55	15	15	15	N/A	N/A
E-12	Exchange Pl. West of Bulkhead	Brown & Brown No. 5	16" x 21 5/8" Hinged Gate with Mechanical Float System	6	0	0	70	0	30	N/A	N/A
E-13	Pearl St. East of Washington St.	Brown & Brown No. 5-0	5" x 9 1/4" Hinged Gate with Mechanical Float System	22	0	10	5	25	60	N/A	N/A
E-14	Foot of Bay St. & Penn R.R.	Brown & Brown No. 2	12" x 15" Hinged Gate with Mechanical Float System	54	2,800	0	30	30	40	N/A	N/A

TABLE 3 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
E-8	36" ϕ RC BR INT	24" ϕ RC BR INT to 36" ϕ RC BR INT	36" ϕ CB	36" ϕ CB	36" ϕ CB	Hudson River	9-23-71	Yes	Clean and well maintained. Tide gate open slightly.	15
E-9	36" ϕ RC BR INT	36" ϕ RC BR INT	30" x 20" OB	30" x 20" OB	30" x 20" OB	Hudson River	9-23-71	No	Regular gate chain for pulley off track making gate inoperable. Tide gate open.	15
E-10	36" ϕ RC BR INT	18" ϕ RC BR INT To 36" ϕ RC BR INT	84" ϕ CB	84" ϕ CB	84" ϕ CB	Hudson River	9-24-71	No	Float frozen in down position causing regulator gate to remain in open position.	15
E-11	30" ϕ RC BR INT	36" ϕ RC BR INT	36" x 48" OB	36" x 48" OB	36" x 48" OB	Hudson River	9-23-71	Yes	Good condition, clean and well maintained.	15
E-12	--	30" ϕ RC BR INT	36" x 48" OB	36" x 48" OB	36" x 48" OB	Hudson River	9-23-71	Yes	Only very slight back flow from tide gate.	15
E-13	24" ϕ RC	24" ϕ RC BR INT to 72" ϕ RC	30" x 36" OB	30" x 36" OB	30" x 36" OB	Hudson River	9-23-71	No	Blockage in regulator gate. Needs cleaning of regulator gate and float chamber.	15
E-14	72" ϕ RC	24" ϕ RC BR INT to 72" ϕ RC	30" x 40" OB	30" x 40" OB	30" x 40" OB	Hudson River	9-23-71	No	Float Chamber full of debris. Tide gate lodged open slightly.	15

TABLE 3 - JERSEY CITY, EAST SIDE PLANT DRAINAGE BASIN (Continued)

JERSEY CITY, NEW JERSEY

Regulator Number	Location	Manufacturer (Reference Number)	Type	Drainage Area (Acres)	Population- Residential	Percent Land Use				Trunk Line MWF (cfs)	Interceptor Design Capacity (cfs)
						Res.	Com.	Ind.	Oth.		
E-15	Second & Provost Streets	Brown & Brown No. 3	12" x 18 3/4" Hinged Gate with Mechanical Float	88	6,600	55	40	0	5	N/A	N/A
E-16	Foot of Sixth Street	Brown & Brown No. 00	7 1/2" x 12 3/8" Hinged Gate with Mechanical Float System	54	1,600	60	20	15	5	N/A	N/A
E-17	Eight & Provost Streets	Brown & Brown No. 8	21" x 32 5/8" Hinged Gate with Mechanical Float System	93	4,700	40	10	15	35	N/A	N/A
E-18	Twelfth & Henderson Streets	Brown & Brown No. 2	12" x 15" Hinged Gate with Mechanical Float System	240	19,600	0	40	40	20	N/A	N/A
E-19	Boyle Pl. North of Holland Tunnel exit	Brown & Brown No. 6	16" x 27 1/2" Hinged Gate with Mechanical Float System	16	2,200	60	10	20	10	N/A	N/A
E-20	Boyle Pl. North of Holland Tunnel exit	Brown & Brown No. 000	7 1/2" x 9 3/4" Hinged Gate with Mechanical Float System	127	--	0	0	100	0	N/A	N/A
E-21	Boyle Pl. North of Holland Tunnel exit	Brown & Brown No. 5-A	16" x 24" 5/8" Hinged Gate with Mechanical Float System	270	25,100	90	5	0	5	N/A	N/A

TABLE 3 (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line Upstream	Downstream	Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
E-15	72" ϕ RC	72" ϕ RC	48" ϕ CB	48" ϕ CB	48" ϕ CI	Hudson River	9-23-71	No	Telltale pipe clogged. Debris and grit holding float in down position. Tide gate open slightly.	15
E-16	--	18" ϕ RC BR INT to 36" ϕ RC BR INT	48" ϕ CB	48" ϕ CB	48" ϕ CB	Hudson River	9-23-71	Yes	Bar screens need cleaning. Tide gate open slightly.	16
E-17	--	36" ϕ RC BR INT	Two 3'-0" x 4'-0" OB	48" ϕ CB	48" ϕ CB	Hudson River	9-23-71	Yes	Needs cleaning. Tide gate jammed open slightly.	16
E-18	60" ϕ RC	66" ϕ RC	3'-0" x 4'-0" OB	96" ϕ STEEL	96" ϕ STEEL	Hudson River	9-23-71	Yes	Needs Cleaning.	16
E-19	--	--	5'-0" ϕ STEEL	5'-0" ϕ STEEL	5'-0" ϕ STEEL	Hudson River	9-23-71	Yes	Needs Cleaning.	16
E-20	--	42" ϕ RC	48" ϕ RC	3'-0" x 4'-0" OB	3'-0" x 4'-0" OB	Hudson River	9-23-71	No	Regulator in open position at all times due to trash & grit clogging float chamber.	16
E-21	--	--	66" ϕ	66" ϕ	66" ϕ	Hudson River	9-23-71	Yes	Bar screen needs cleaning. Tide gate closed.	16

NOTES FOR TABLE 3 (CONTINUED):

Line Size Characteristics - taken from regulator detail sheets and Jersey City Existing Sewer Plans.

Inspection Data - according to telephone conversation on May 19, 1972 with the Jersey City Treatment Plant Superintendent, all regulators which were found to be inoperable during inspection have been put in good condition.

TABLE 3 - JERSEY CITY, EAST SIDE PLANT DRAINAGE BASIN (Continued)

JERSEY CITY, NEW JERSEY

Regulator Number	Location	Manufacturer (Reference Number)	Type	Drainage Area (Acres)	Population- Residential	Percent Land Use				Trunk Line MDF (cfs)	Interceptor Design Capacity (cfs)
						Res.	Com.	Ind.	Oth.		

NOTES FOR TABLE 3:

Regulator Data - taken from regulator detail sheets (1954) supplied by personnel at the Jersey City Treatment Plant.


Drainage Area Data - boundaries determined from City of Jersey City Existing Sewer Plans supplied by Chief Engineer, Jersey City. Acreage calculated from the layout of drainage area boundaries.

Population Data - based on 1970 Federal Census data supplied by the Jersey City Division of Planning.

Land Use Data - estimated from Existing Land Use Map in The City: A Time for Change - A Report on Jersey City's Comprehensive Master Plan (1966).


Hydraulic Data - not available.

FIG-14 JERSEY CITY (EAST SIDE)
HUDSON CO. N.-J.
DRAINAGE BASIN
AND
REGULATOR LOCATIONS



© Hagstrom Co.

FIG. 16 JERSEY CITY (EAST SIDE)
HUDSON CO. N.J.
DRAINAGE BASIN
AND
REGULATOR LOCATIONS



FOR ADJOINING AREA SEE FIG. 14 PAGE

FOR ADJOINING AREA SEE FIG. 15 PAGE

SECTION IX

WEST NEW YORK SEWAGE TREATMENT PLANT

DRAINAGE BASIN, WEST NEW YORK, N. J.

The West New York combined sewage system is a gravity flow type having no pump stations. There is only one regulator in the system. This regulator is a diversion chamber located on Hillside Road, east of Kennedy Boulevard. Sewage from West New York, the northern part of Union City, and Weehawken Heights flows into this regulator.

At the time of inspection, the chamber's bar screens, which precede the influent line to the treatment plant, were clean, with no sewage bypassing over the stationary weir.

Treatment plant personnel are used to maintain this regulator, on a regularly scheduled basis.

Additional information regarding the regulator within this drainage area is found in Table 4 and Figure 17.

TABLE 4 - WEST NEW YORK TREATMENT PLANT DRAINAGE BASIN

WEST NEW YORK, NEW JERSEY

Regulator Number	Location	Manufacturer (Reference Number)	Type	Drainage Area (Acres)	Population- Residential	Percent Land Use				Trunk Line MDF (cfs)	Interceptor Design Capacity (cfs)
						Res.	Com.	Ind.	Oth.		
1	Hillside Road East of John F. Kennedy Boulevard	--	Bar screen over fixed orifice	738	N/A	50	20	20	10	N/A	N/A

NOTES FOR TABLE 4:

Regulator Data - taken from detail sheets in Interstate Sanitation Commission files.

Drainage Area Data - boundaries determined from (West New York) Plan Map of Drainage Area. Acreage calculated from the layout of the drainage area boundaries.

Population Data - not available.


Land Use Data - estimated from Official Zoning Map - Town of West New York (1965).

Hydraulic Data - not available.

Table 4 - (Continued)

Regu- lator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk	By-Pass	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream	Line	Line						
1	--	27" ϕ RC	48" ϕ RC	54" ϕ RC	54" ϕ RC	Hudson River	10-15-71	Yes	Bar screen clean; all flow to plant--No flow to outfall.	17

NOTES FOR TABLE 4 (CONTINUED):Line Size Characteristics - taken from regulator detail sheets.



**FIG. 17 WEST NEW YORK
HUDSON CO. N.J.
DRAINAGE BASIN
AND
REGULATOR LOCATIONS**

© Hagstrom Co.

SECTION X
NEWTOWN CREEK SEWAGE TREATMENT PLANT
DRAINAGE BASIN,
BROOKLYN, MANHATTAN, QUEENS, N.Y.

The Newtown Creek Treatment Plant services three drainage areas: Brooklyn, Manhattan, and Queens. The Brooklyn drainage area contains eighteen regulators -- ten with hydraulic float systems, two with mechanical float systems, and six with manual operated sluice gates. The Manhattan drainage area contains forty regulators -- all with hydraulic float systems. The Queens drainage area contains one regulator and utilizes a hydraulic float system for flow control.

Field inspections were made only on those regulators located in Brooklyn and Queens. The results of these inspections showed that two of the nineteen regulators were inoperable. In a follow-up telephone conversation with the Acting Chief of the Division of Plant Operations for New York City, one regulator has been repaired and repairs on the other are in progress.

The Manhattan regulator chambers were not inspected since they were purposely flooded to protect equipment while construction proceeds on the Manhattan pump station. This pump station, which will be operational in the Spring of 1973, will pump sewage from the Manhattan drainage area under the East River to Newtown Creek Treatment Plant in Brooklyn. The regulator maintenance crews for the Newtown Creek system consist of personnel from the New York City Department of Public Works, Bureau of Sewers. They utilize a specially equipped truck to aid personnel in the inspection and the maintenance of the regulators.

Additional information regarding the regulators within this drainage area is found in Tables 5-B, 5-Q, and 5-M and Figures 18 through 26.

TABLE 5 (B) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN

BROOKLYN, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
B-1	Johnson Avenue East of Morgan Avenue	TWO 4'-0" x 3'-0" Sluice Gates with Hydraulic Float Systems	3,143	N/A	N/A	N/A	80	0	15	5	N/A	N/A
B-1 A	Johnson Avenue East of Morgan Avenue	Diversion and Tide Gate Chamber	(Combined Data for B-1 & B-1A)									
B-2	Metropolitan & Onderdonk Avenues	12" x 12" Sluice Gate with Hydraulic Float System	116	N/A	N/A	N/A	90	0	10	0	N/A	N/A
B-3	Taylor Street & Kent Avenue	Diversion & Tide Gate Chambers	498	N/A	N/A	N/A	65	0	25	10	N/A	N/A
B-4	Kent Avenue & Taylor Street	4'-0" x 3'-0" Sluice Gate with Hydraulic Float System	(Combined Data for B-3 & B-4)									
B-5	Kent Avenue & Division Street	4'-0" x 3'-0" Sluice Gate with Hydraulic Float System	2,679	250,000	N/A	N/A	75	0	15	10	N/A	N/A
B-5 A	South 8th St. & Kent Avenue	12" x 12" Sluice Gate with Hydraulic Float System	273	N/A	N/A	N/A	30	0	70	0	N/A	N/A
B-6	Kent Avenue & South 5th St.	3'-0" x 2'-0" Sluice Gate with Hydraulic System	273	55,000	N/A	N/A	70	0	25	5	N/A	N/A

TABLE 5 (B) - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
B-1	---	6'-9" x 6'-9" x BR INT To 90" ϕ	---	---	---	---	10-27-71	Yes	---	19
B-1 A	---	---	TWO 216" RC	TWO 216" RC	TWO 216" RC	English Kill	10-27-71	Yes	---	19
B-2	---	18" ϕ VP BR INT To REG B-1	36" ϕ RC	36" ϕ RC	36" ϕ RC	Newtown Creek	10-27-71	No	Water supply valve to hydraulic equipment out of order. Regulator gate held open with stick.	19
B-3	---	6'-0" x 4'-6" x BR INT To REG B-4	216" ϕ RC	216" ϕ RC	216" ϕ RC	East River	---	---	---	18
B-4	6'-0" x 4'-6" x BR INT FROM REG B-3	6'-0" x 5'-0" x	---	---	---	---	10-4-71	Yes	No inflow through tide gates visible.	18
B-5	6'-0" ϕ	60" BR INT To 7'-0" x 6'-6" x	108" ϕ BRICK	108" ϕ BRICK	108" ϕ BRICK	East River	10-4-71	Yes	Good condition. Slight inflow from two tide gates.	18
B-5 A	7'-0" x 6'-6" x	12" ϕ BR INT To 7'-0" x 6'-6" x	36" ϕ VP	36" ϕ VP	36" ϕ VP	East River	10-4-71	Yes	Good condition.	18
B-6	7'-0" x 6'-6" x	42" ϕ BR INT To 7'-6" x 7'-6" x	144" ϕ BRICK	144" ϕ BRICK	144" ϕ BRICK	East River	10-4-71	Yes	Visible accumulation of grease in float chamber. Slight leak from tide gates.	18

TABLE 5 (B) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN (Continued)

BROOKLYN, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
B-6 A	East River & Grand Street	10" x 10" Manual Operated Sluice Gate	149	800	N/A	N/A	20	0	80	0	N/A	N/A
B-7	Metropolitan Avenue & East River	18" x 18" Sluice Gate with Hydraulic Float System	132	30,000	N/A	N/A	30	35	30	5	N/A	N/A
B-8	North 5th St. & Kent Avenue	12" x 12" Sluice Gate with Hydraulic Float System	62	6,000	N/A	N/A	0	0	100	0	N/A	N/A
B-9	North 12th St. & Kent Avenue	3'-0" x 2'-0" Sluice Gate with Hydraulic Float System	880	60,000	N/A	N/A	40	0	60	0	N/A	N/A
B-10	Quay & West Streets	7-1/2" x 15-3/8" Hinged Gate with Mechanical Float System	62	9,000	N/A	N/A	20	20	60	0	N/A	N/A
B-11	Foot of Greenpoint Avenue	10" x 10" Manually Operated Sluice Gate	25	1,200	N/A	N/A	0	0	100	0	N/A	N/A
B-12	Huron & West Streets	16" x 21-5/8" Hinged Gate with Mechanical Float System	477	15,000	N/A	N/A	30	0	70	0	N/A	N/A
B-13	Green & West Streets	10" x 10" Manually Operated Sluice Gate	15	800	N/A	N/A	0	0	100	0	N/A	N/A

TABLE 5 (B) - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
B-6 A	7'-6" x 7'-6"	12" ϕ BR INT To 7'-6" x 7'-6"	12" ϕ	12" ϕ	12" ϕ	East River	10-4-71	Yes	Slight leak around tide gate (not seated properly).	18
B-7	7'-6" x 7'-6"	24" ϕ BR INT To 7'-6" x 7'-6"	60" ϕ BRICK	60" ϕ BRICK	60" ϕ BRICK	East River	10-4-71	Yes	Slight leak around tide gate (not seated properly).	18
B-8	7'-6" x 7'-6"	18" ϕ BR INT To 7'-6" x 7'-6"	45" x 36" BRICK	45" x 36" BRICK	45" x 36" BRICK	East River	10-4-71	Yes	Gate blocked by heavy grease accumulation -- corrected by crew.	18
B-9	7'-6" x 7'-6"	8'-0" x 7'-6"	TWIN 11'-2" x 8'-0" RC	TWIN 11'-2" x 8'-0" RC	TWIN 11'-2" x 8'-0" RC	East River	10-4-71	Yes	Slight flow from bottom seal of all four tide gates.	18
B-10	8'-0" x 7'-6"	18" ϕ BR INT To 8'-0" x 7'-6"	66' ϕ RC	66" ϕ RC	66" ϕ RC	East River	10-5-71	Yes	Some grit in float chamber. Medium seepage from tide gate bottom seal.	18
B-11	36" ϕ	12" ϕ BR INT To 36" ϕ	24" ϕ	24" ϕ	24" ϕ	East River	10-5-71	Yes	Stoppage in line in diversion chamber corrected by crew.	18
B-12	24" ϕ	30" ϕ BR INT To 36" ϕ	8 1/2" ϕ BRICK	8 1/2" ϕ BRICK	8 1/2" ϕ BRICK	East River	10-5-71	Yes	One tide gate leaking slightly.	18
B-13	24" ϕ	12" ϕ BR INT To 24" ϕ	30" x 24" EGG SHAPED BRICK	30" x 24" EGG SHAPED BRICK	30" x 24" EGG SHAPED BRICK	East River	10-5-71	Yes	A 2 x 4 piece of wood stuck in tide gate -- cleared by crew. Slight leak from tide gate.	18

TABLE 5 (B) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN (Continued)

BROOKLYN, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
B-14	West & Freeman Streets	10" x 10" Manually Operated Sluice Gate	31	1,300	N/A	N/A	30	0	70	0	N/A	N/A
B-15	Dupont & West Streets	10" x 10" Manually Operated Sluice Gate	19	400	N/A	N/A	0	0	70	30	N/A	N/A
B-16	Clay & Commercial Streets	10" x 10" Manually Operated Sluice Gate	31	1,800	N/A	N/A	20	0	80	0	N/A	N/A
B-17	Oakland & Ash Streets	12" x 12" Sluice Gate with Hydraulic Float System	25	4,000	N/A	N/A	0	0	100	0	N/A	N/A

08

NOTES FOR TABLE 5 (B):

Regulator Data - taken from regulator detail sheets (1966) supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control.

Drainage Area Data - boundaries determined from Existing Sewer Line Map of Brooklyn. Acreage calculated from the layout of the drainage area boundaries.

Population Data - from data supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control (for the year 1970).

Land Use Data - estimated from Land Use Policy Maps in Plan for New York City, A Proposal - 1969, Volume 3-Brooklyn prepared by the New York City Planning Commission.

Hydraulic Data - not available.

TABLE 5 (B) - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
B-14	24" ϕ	24" ϕ	TWO 12" ϕ VP & 18" ϕ	31" x 20" EGG SHAPED BRICK	31" x 20" EGG SHAPED BRICK	East River	10-5-71	Yes	Blockage in line to interceptor -- cleared by crew.	18
B-15	24" ϕ	12" ϕ BR INT To 24" ϕ	12" ϕ	12" ϕ	12" ϕ	East River	10-27-71	---	Dry hole - regulator has never been used.	18
B-16	18" ϕ	12" ϕ CI BR INT To 24" ϕ	12" ϕ & 18" ϕ	24" ϕ	24" ϕ	East River	10-27-71	---	Temporarily no-access to manhole (automobile parked over manhole). Tide gate closed and in good condition.	18
B-17	---	18" ϕ	42" ϕ & 5'-0" x 4'-6"	6'-3" x 4'-6"	6'-3" x 4'-6"	East River	10-27-71	Yes	Tide gate open slightly at bottom.	18

81

NOTES FOR TABLE 5 (B) (CONTINUED):Line Size Characteristics - taken from regulator detail sheets and Existing Sewer Line Map of Brooklyn.Inspection Data - according to telephone conversation on June 2, 1972 with Acting Chief of the Division of Plant Operations, New York Environmental Protection Administration, Division of Water Resources and Water Pollution Control, repairs are being made on regulator B-2.

TABLE 5 (q) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN

QUEENS, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
Q-1	Rust Street & 56th Drive	24" x 24" Sluice Gate with Hydraulic Float System	2,549	N/A	N/A	N/A	75	10	10	5	N/A	N/A

NOTES FOR TABLE 5 (q):

Regulator Data - taken from regulator detail sheets (1956) supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control.

Drainage Area Data - boundaries determined from Existing Sewer Line Map of Queens. Acreage calculated from the layout of the drainage area boundaries.

Population Data - not available.

Land Use Data - estimated from Land Use Policy Maps in Plan for New York City, A Proposal-1969, Volume 5-Queens prepared by the New York City Planning Commission.

Hydraulic Data - not available.

TABLE 5 (Q) - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
Q-1	---	3' 9" ϕ	TWO 8'-0" x 7'-0" x RC & 7'-6" x 7'-0" x RC & 7'-0" x 5'-6" x RC	TWO 8'-0" x 7'-0"	TWO 8'-0" x 7'-0"	Maspeth Creek	10-27-71	No	Regulator in open position due to debris & grease in float chamber.	19

NOTES FOR TABLE 5 (Q) (CONTINUED):

Line Size Characteristics - taken from regulator detail sheets and Existing Sewer Line Map of Queens.

Inspection Data - according to telephone conversation on June 2, 1972 with Acting Chief of the Division of Plant Operations, New York Environmental Protection Administration, Division of Water Resources and Water Pollution Control, regulator Q-1 has been placed into operable condition.

© Hagstrom Co.




FIG. 18 NEWTOWN CREEK
BROOKLYN, NEW YORK
DRAINAGE BASIN AND
REGULATOR LOCATIONS

PAGE
FIG. 19
SEE

SEE FIG. 21 PAGE




FIG. 19 NEWTOWN CREEK
 BROOKLYN, NEW YORK
 DRAINAGE BASIN AND
 REGULATOR LOCATIONS

SEE FIG. 19 PAGE

FOR ADJOINING AREA

PAGE

PORTION OF B1
DRAINAGE BASIN

PORTION OF B3
DRAINAGE BASIN

FIG. 21

SEE

ADJOINING

FOR



FIG. 20 NEWTOWN CREEK
BROOKLYN, NEW YORK
DRAINAGE BASIN AND
REGULATOR LOCATIONS

Hagstrom Co.




FIG. 21 NEWTOWN CREEK
 BROOKLYN, NEW YORK
 DRAINAGE BASIN AND
 REGULATOR LOCATIONS

© Hagstrom Co.

THIS PAGE LEFT INTENTIONALLY BLANK

TABLE 5 (M) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
M-1	West Street & Clarkson Street	2'-6" x 1'-6" Sluice Gate with Hydraulic Float System	450	53,200	N/A	N/A	70	10	15	5	23.83	N/A
M-2	West Street & Clarkson Street	30" x 24" Sluice Gate with Hydraulic Float System	246	11,400	N/A	N/A	0	70	30	0	8.82	N/A
M-3	Vestry Street & West Street	18" x 12" Sluice Gate with Hydraulic System	54	200	N/A	N/A	0	0	100	0	1.26	N/A
M-4	West Street & Duane Street	24" x 18" Sluice Gate with Hydraulic Float System	124	1,600	N/A	N/A	0	99	0	1	4.00	N/A
M-5	West Street & Vesey Street	14" x 14" Sluice Gate with Hydraulic Float System	47	300	N/A	N/A	0	99	0	1	2.20	N/A
M-6	West Street & Albany Street	12" x 12" Sluice Gate with Hydraulic Float System	16	200	N/A	N/A	0	100	0	0	0.44	N/A
M-7	West Street & Rector Street	18" x 12" Sluice Gate with Hydraulic Float System	32	600	N/A	N/A	0	100	0	0	1.35	N/A

TABLE 5 (M) - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
M-1	---	36" ϕ PRCP BR INT To 54" ϕ FTRC	6'-3" x 12'-0" FTRC	6'-3" x 12'-0" FTRC	6'-3" x 12'-0" FTRC	Hudson River	1-18-72	Yes	---	22
M-2	54" ϕ PRCP	36" ϕ PRCP BR INT To 66" ϕ PRCP	6'-0" x 16'-0" FTRC	6'-0" x 16'-0" FTRC	6'-0" x 16'-0" FTRC	Hudson River	1-18-72	---	Chamber flooded for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	23
M-3	66" ϕ	24" ϕ RC BR INT To 72" ϕ	5'-0" x 3'-6" ELLIP BRICK	5'-0" x 3'-6" ELLIP BRICK	5'-0" x 3'-6" ELLIP BRICK	Hudson River	1-18-72	---	Chamber flooded for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	23
M-4	72" ϕ	30" ϕ PRCP BR INT To 78" ϕ	4'-1 1/2" x 8'-10" RC	4'-1 1/2" x 8'-10" RC	4'-1 1/2" x 8'-10" RC	Hudson River	1-18-72	---	Chamber flooded for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	23
M-5	78" ϕ	24" ϕ PRCP BR INT To 78" ϕ	5'-0" x 5'-0" FTRC	4'-0" ϕ BRICK	4'-0" ϕ BRICK	Hudson River	1-18-72	---	Chamber flooded for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	23
M-6	78" ϕ	78" ϕ	4'-0" ϕ BRICK	4'-0" ϕ BRICK	4'-0" ϕ BRICK	Hudson River	1-18-72	---	Chamber flooded for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	23
M-7	78" ϕ	78" ϕ	5'-0" x 6'-0" RC	5'-0" x 6'-0" RC	5'-0" x 4'-0" FTRC	Hudson River	1-18-72	---	Chamber flooded for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	23

TABLE 5 (M) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
M-8	West Street & Morris Street	12" x 12" Sluice Gate with Hydraulic Float System	28	400	N/A	N/A	0	85	0	15	1.25	N/A
M-9	West Street & Battery Place	12" x 12" Sluice Gate with Hydraulic Float System	(Combined Data for Regulators M-8 & M-9)									
M-10	South & Broad Streets	24" x 24" Sluice Gate with Hydraulic Float System	96	3,000	145,100	96,800	0	99	0	1	9.912	N/A
M-11	South St. & Coenties Slip West	18" x 12" Sluice Gate with Hydraulic Float System	20	700	55,100	36,800	0	100	0	0	3.620	N/A
M-12	South Street & Old Slip	Tide Gate	(Combined Data for Regulators M-11 & M-12)									
M-13	South & Fletcher Streets	18" x 18" Sluice Gate with Hydraulic Float System	53	500	98,100	65,300	0	100	0	0	6.222	N/A
M-14	South & John Streets	Tide Gate	(Combined Data for Regulators M-13, M-14, M-15 & M-16)									

TABLE 5 (M) - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
M-8	78" ϕ	78" ϕ	4'-0" ϕ RC	4'-0" ϕ RC	4'-0" ϕ RC	Hudson River	---	- -	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	23
M-9	78" ϕ	18" ϕ BR INT To 78" ϕ	5'-0" x 4'-0" ϕ PTRC	5'-0" x 4'-0" ϕ PTRC	5'-0" x 4'-0" ϕ PTRC	Hudson River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	23
M-10	5'-0" x 8'-0"	30" ϕ BR INT To 5'-0" x 8'-0"	5'-0" x 7'-6" ϕ PTRC	5'-0" x 7'-6" ϕ PTRC	5'-0" x 7'-6" ϕ PTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	24
M-11	5'-0" x 8'-0"	21" ϕ BR INT To 5'-0" x 8'-0"	4'-0" ϕ BRICK	4'-6" x 3'-8" ϕ WOOD	4'-6" x 3'-8" ϕ WOOD	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	24
M-12	---	---	4'-0" ϕ BRICK	4'-0" ϕ BRICK	4'-0" ϕ BRICK	East River	---	---	---	-
M-13	5'-0" x 8'-0"	27" ϕ PRCP BR INT To 6'-0" x 8'-0"	4'-0" ϕ	4'-0" ϕ	4'-0" ϕ	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	24
M-14	---	---	4'-0" ϕ BRICK	4'-0" ϕ BRICK	4'-0" ϕ BRICK	East River	---	---	---	-

TABLE 2 (M) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)	
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.			
M-15	South & Fulton Streets	Tide Gate	(Combined Data for Regulators M-13, M-14, M-15 & M-16)										
M-16	South Street & Peck Slip	Tide Gate											
M-17	South St. & Robert F. Wagner, Senior Place	24" x 12" Sluice Gate with Hydraulic Float System	93	8,300	33,500	22,300	35	60	0	5	4.624	N/A	
M-18	South St. & Catherine Slip	Tide Gate Chamber	(Combined Data for Regulators M-17 & M-18)										
M-19	South St. & Catherine Slip	24" x 24" Sluice Gate with Hydraulic Float System	166	31,100	26,300	17,600	20	65	15	0	11.245	N/A	
M-20	South St. & Market Slip	18" x 12" Sluice Gate with Hydraulic Float System	38	9,900	4,200	2,800	60	35	0	5	3.328	N/A	
M-21	South St. & Jefferson St.	24" x 18" Sluice Gate with Hydraulic Float System	139	26,000	7,000	4,700	70	28	0	2	8.482	N/A	

TABLE 5 (M)-(Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
M-15	---	---	4'-0" x 4'-0" PTRC	4'-0" x 4'-0" PTRC	4'-0" x 4'-0" PTRC	East River	---	---	---	-
M-16	---	---	4'-0" ϕ BRICK	4'-0" ϕ BRICK	4'-0" ϕ BRICK	East River	---	---	---	-
M-17	6'-0" x 8'-0"	24" ϕ PRCF BR INT To 6'-0" x 8'-0"	6'-0" SEMI-CIRC PTRC & 4'-0" x 4'-0" PTRC	6'-0" SEMI-CIRC PTRC	6'-0" SEMI-CIRC PTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	24
M-18	---	---	5'-0" x 9'-0" PTRC	5'-0" x 9'-0" PTRC	5'-0" x 9'-0" PTRC	East River	---	---	---	-
M-19	6'-0" x 8'-0"	36" ϕ BR INT To 6'-0" x 8'-0"	4'-6" x 4'-0" PTRC	4'-6" x 4'-0" PTRC	4'-6" x 4'-0" PTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	24
M-20	7'-0" x 8'-0"	21" ϕ BR INT To 7'-0" x 8'-0"	4'-6" ϕ BRICK	4'-6" ϕ BRICK	4'-6" ϕ BRICK	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	24
M-21	7'-0" x 8'-0"	30" ϕ BR INT To 7'-0" x 8'-0"	4'-0"	4'-0" ϕ WOOD	4'-0" ϕ WOOD	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	24

TABLE 5 (M) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trans Line MMF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
M-22	South St. & Couverneur Slip.	Diversion & Tide Gate Chambers	14	N/A	N/A	N/A	80	20	0	0	N/A	N/A
M-23	South St. & Jackson St.	Diversion & Tide Gate Chambers	12	2,300	200	100	90	0	0	10	N/A	N/A
M-24	East River Park - East of Jackson Street	12" x 12" Sluice Gate with Hydraulic Float System	28	2,300	200	100	90	0	0	10	N/A	N/A
M-25	East River Park & Grand Street	Diversion & Tide Gate Chambers	48	1,600	100	100	80	20	0	0	0.975	N/A
M-26	East River Park & Grand Street	18" x 18" Sluice Gate with Hydraulic Float System	75	16,500	1,700	1,100	80	20	0	0	5.204	N/A
M-27	East River Park & Broome Street	Tide Gate	(Combined Data for M-26 & M-27)									
M-28	East River Park & Delancey Street	Tide Gate	(Combined Data for M-28 & M-29)									

TABLE 5 (N)-(Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
M-22	---	15" ϕ VP BR INT	TWO 4'-0" ϕ BRICK	4'-0" ϕ BRICK	4'-0" ϕ BRICK	East River	---	---	---	24
M-23	---	15" ϕ VP BR INT	4'-0" x 3'-0" ELLIP & 15" ϕ VP	4'-0" x 3'-0" ELLIP	4'-0" x 3'-0" ELLIP	East River	---	---	---	24
M-24	9'-0" ϕ	21" ϕ PRCP BR INT To 9'-0" ϕ	---	---	---	---	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	24
M-25	---	12" ϕ VP BR INT	5'-0" x 4'-0" PTRC	5'-0" x 4'-0" PTRC	5'-0" x 4'-0" PTRC	East River	---	---	---	24
M-26	9'-0" ϕ	24" ϕ BR INT To 9'-0" ϕ	5'-6" x 2'-8" PTRC	5'-6" x 2'-8" PTRC	5'-6" x 2'-8" PTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25
M-27	---	---	4'-0" x 4'-0" PTRC	4'-0" x 4'-0" PTRC	4'-0" x 4'-0" PTRC	East River	---	---	---	-
M-28	---	---	4'-0" x 4'-0"	4'-0" x 4'-0"	4'-0" x 4'-0"	East River	---	---	---	-

TABLE 5 (M) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
M-29	East River Park & Rivington St.	18" x 18" Sluice Gate with Hydraulic Float System	(Combined Data for M-28 & M-29)									
M-30	East River Park & Stanton Street	18" x 18" Sluice Gate with Hydraulic Float System	61	14,500	1,100	700	70	30	0	0	4.533	N/A
M-31	East River Park & E.Houston St.	Tide Gate	(Combined Data for M-31 & M-32)									
M-32	East River Park & East 3rd St.	24" x 18" Sluice Gate with Hydraulic Float System	147	38,600	4,000	2,700	90	10	0	0	12.170	N/A
M-33	East River Park & East 6th St.	12" x 12" Sluice Gate with Hydraulic Float System	11	2,100	100	100	70	0	0	30	0.642	N/A
M-34	East River Park & East 8th St.	12" x 12" Sluice Gate with Hydraulic Float System	17	4,000	100	100	85	0	5	10	1.216	N/A
M-35	East River Park & East 11th St.	12" x 12" Sluice Gate with Hydraulic Float System	18	4,300	300	200	85	0	5	10	1.341	N/A

TABLE 5 (M)-(Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA		Figure No. for Location of Regulator	
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)		Comments
	Upstream	Downstream								
M-29	42" ϕ BR INT	27" ϕ & 48" ϕ BR INTS	5'-0" x 5'-0" PRCP	5'-0" x 5'-0" PRCP	5'-0" x 5'-0" PRCP	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25
M-30	33" ϕ BR INT	27" ϕ PRCP BR INT To 42" ϕ BR INT	5'-6" x 5'-0" FTRC	5'-6" x 5'-0" FTRC	5'-6" x 5'-0" FTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25
M-31	---	---	4'-6" x 6'-0" FTRC	4'-6" x 6'-0" FTRC	4'-6" x 6'-0" FTRC	East River	---	---	---	-
M-32	---	33" ϕ PRCP BR INT	6'-0" x 6'-6" FTRC	6'-0" x 6'-6" FTRC	6'-0" x 6'-6" FTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25
M-33	---	12" ϕ	5'-6" x 4'-0" FTRC	5'-6" x 4'-0" FTRC	5'-6" x 4'-0" FTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25
M-34	12" ϕ VP BR INT	15" ϕ VP BR INT To 18" ϕ VP BR INT	5'-0" x 6'-6" FTRC	5'-0" x 6'-6" FTRC	5'-0" x 6'-6" FTRC	East River	---	---	Chamber flooded (assumed) for protection of Hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25
M-35	---	15" ϕ VP BR INT	5'-0" x 8'-9" FTRC	5'-0" x 8'-9" FTRC	5'-0" x 8'-9" FTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25

TABLE 5 (M) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
M-36	East 14th St. & Franklin D. Roosevelt Drive	36" x 24" Sluice Gate with Hydraulic Float System	272	73,700	14,000	9,400	90	10	0	0	17.50	N/A
M-37	Marginal St. South of 29th Street	2'-0" x 2'-6" Sluice Gate with Hydraulic Float System	220	42,400	65,000	43,200	40	50	5	5	21.421	N/A
M-38	Marginal St. North of 20th Street	12" x 30" Sluice Gate with Hydraulic Float System	68	10,400	39,800	26,600	40	60	0	0	5.665	N/A
M-39	West of Franklin D. Roosevelt Drive & South of E. 25th St.	24" x 12" Sluice Gate with Hydraulic Float System	67	12,600	12,600	8,400	50	50	0	0	4.678	N/A
M-39 A	Franklin D. Roosevelt Drive & South of E. 25th St.	Diversion & Tide Gate Chambers	(Combined Data for M-39 & M-39A)									
M-40	Bellerue Hospital North of E. 25th St.	24" x 24" Sluice Gate with Hydraulic Float System	150	20,200	150,200	100,100	70	30	0	0	15.555	N/A
M-41	Franklin D. Roosevelt Drive & East 30th Street	12" x 12" Sluice Gate with Hydraulic Float System	37	4,900	4,200	2,800	100	0	0	0	1.761	N/A

TABLE 5 (M)-(Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Watervay	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
M-36	108" ϕ	48" ϕ BR INT To 108" ϕ	6'-0" x 9'-0" x FTRC & 12" ϕ VP	6'-0" x 9'-0"	TWO 6'-0" x 9'-0" x FTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25
M-37	108" ϕ	42" ϕ BR INT To 108" ϕ	TWO 6'-0" x 3'-0" RC	6"-0" x 3'-0" & 6'-0" x 8'-0" RC	6'-0" x 3'-0" & 6'-0" x 8'-0" RC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25
M-38	108" ϕ	30" ϕ BR INT To 108" ϕ	5'-0" x 4'-0" x BRICK	5'-0" x 4'-0" x BRICK	5'-0" x 4'-0" x BRICK	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25
M-39	---	24" ϕ BR INT To 48" ϕ BR INT	48" ϕ BRICK & 18" ϕ VP BR INT	48" ϕ BRICK	48" ϕ BRICK	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25
M-39 A	---	18" ϕ VP BR INT To REGULATOR M-39	5'-0" x 2'-4" x FTRC	5'-0" x 2'-4" x FTRC	48" ϕ BRICK	East River	---	---		25
M-40	---	36" ϕ BR INT To 48" ϕ BR INT	TWO 6'-6" x 6'-0" x FTRC & 5'-0" x 4'-0" x FTRC	TWO 6'-6" x 6'-0" x FTRC & 5'-0" x 4'-0" x FTRC	TWO 6'-6" x 6'-0" x FTRC & 5'-0" x 4'-0" x FTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25
M-41	96" ϕ	21' ϕ VP BR INT To 102" ϕ	4'-0" x 2'-4" x FTRC & 18" ϕ VP BR INT	4'-0" x 2'-4" x FTRC	4'-0" x 2'-4" x FTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25

TABLE 5 (M) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
M-41 A	Franklin D. Roosevelt Drive & E. 27th St.	Diversion & Tide Gate Chambers	(Combined Data for M-41 & M-41A)									
M-42	East 33rd St. & First Avenue	24" x 18" Sluice Gate with Hydraulic Float System	150	25,100	47,000	31,300	70	0	30	0	10.00	N/A
M-43	Franklin D. Roosevelt Drive & E. 36th St.	24" x 12" Sluice Gate with Hydraulic Float System	55	6,700	14,200	5,500	85	15	0	0	3.73	N/A
M-43 A	Franklin D. Roosevelt Drive & E. 37th St.	Diversion & Tide Gate Chambers	(Combined Data for M-43, M-43A & M-43 B)									
M-43 B	Franklin D. Roosevelt Drive & E. 39th St.	Diversion & Tide Gate Chambers	(Combined Data for M-43, M-43A & M-43 B)									
M-44	E. 41st St. East of First Avenue	30" x 24" Sluice Gate with Hydraulic Float System	159	26,200	228,300	152,200	95	5	0	0	16.00	N/A

TABLE 5 (M)-(Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
M-41 A	---	18" ϕ VP BR INT To REGULATOR M-41	4'-0" ϕ BRICK	5'-6" x 4'-0" PTRC	5'-6" x 4'-0" PTRC	East River	---	---	---	25
M-42	96" ϕ	3'-0" BR INT	TWO 6'-0" x 8'-0" PTRC	TWO 6'-0" x 8'-0" PTRC 96" ϕ	TWO 6'-0" x 8'-0" PTRC 96" ϕ	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25
M-43	96" ϕ	24" ϕ PRCP BR INT To 96" ϕ	3'-6" x 2'-4" EGG SHAPED & 24" ϕ PRCP BR INT & 12" ϕ VP BR INT	3'-6" x 2'-4" EGG SHAPED	5'-6" x 2'-8" PTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	25
M-43 A	---	24" ϕ BR INT	3'-6" x 2'-4" BRICK & 24" ϕ BR INT FROM M-43 B	5'-6" x 2'-8" PTRC	5'-6" x 2'-8" PTRC	East River	---	---	---	25
M-43 B	---	24" ϕ BR INT	5'-0" ϕ BRICK	5'-0" ϕ BRICK	30" ϕ BRICK & 5'-0" x 4'-0" PTRC	East River	---	---	---	25
M-44	84" ϕ	3'-6" x 4'-6" BR INT To 90" ϕ	8'-0" x 8'-0" PTRC	8'-0" x 8'-0" PTRC	7'-0" x 9'-0" PTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	26

TABLE 5 (M) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)	
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.			
M-45	Franklin D. Roosevelt Drive & E. 41st St.	12" x 12" Sluice Gate with Hydraulic Float System	(Combined Data for M-44 & M-45)										
M-46	First Avenue & E. 46th St.	12" x 12" Sluice Gate with Hydraulic Float System	8	700	24,900	16,600	0	100	0	0	2.00	N/A	
M-47	Franklin D. Roosevelt Drive & E. 47th St.	42" x 36" Sluice Gate with Hydraulic Float System	471	35,300	113,500	75,700	30	70	0	0	23.50	N/A	
M-48	E. 54th St. & Sutton Place South	12" x 18" Sluice Gate with Hydraulic Float System	28	5,900	2,600	1,700	100	0	0	0	2.50	N/A	
M-48 A	Franklin D. Roosevelt Drive & E. 53rd St.	Diversion & Tide Gate Chambers	5	700	400	300	100	0	0	0	0.40	N/A	
M-49	E. 57th St. & Sutton Place South	12" x 12" Sluice Gate with Hydraulic Float System	13	3,000	1,200	800	90	10	0	0	1.25	N/A	

TABLE 5 (M)-(Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
M-45	---	18" ϕ BR INT	4'-0" x 2'-8" PTRC & 8" ϕ FORCE MAIN	4'-0" x 2'-8" PTRC	4'-0" x 2'-8" PTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	26
M-46	84" ϕ	14" ϕ CI DROP LINE To 84" ϕ	6'-0" ϕ BRICK LINED	6'-0" ϕ BRICK LINED	6'-0" ϕ BRICK LINED	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	26
M-47	72" ϕ	6'-0" x 5'-0" BR INT To 84" ϕ	9'-0" x 8'-6" BRICK	9'-0" x 8'-6" BRICK	4'-6" ϕ WOOD	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	26
M-48	72" ϕ	21" ϕ BR INT To 72" ϕ	4'-0" x 2'-8" BRICK & 12" ϕ BR INT	4'-0" x 2'-8" BRICK	5'-0" x 4'-0" PTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	26
M-48 A	---	12" ϕ BR INT To REGULATOR M-48	3'-6" x 2'-4" EGG SHAPED BRICK & 12" ϕ	3'-6" x 2'-4" EGG SHAPED BRICK	4'-0" x 2'-4" PTRC	East River	---	---	---	26
M-49	72" ϕ	15" ϕ BR INT To 72" ϕ	3'-6" x 2'-4" EGG SHAPED BRICK	3'-6" x 2'-4" EGG SHAPED BRICK	3'-6" x 2'-4" EGG SHAPED BRICK	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	26

TABLE 5 (M) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDNP (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
M-50	Franklin D. Roosevelt Drive & E. 61st St.	24" x 36" Sluice Gate with Hydraulic Float System	540	54,800	53,800	106,600	90	10	0	0	29.26	N/A
M-51	Franklin D. Roosevelt Drive & E. 70th St.	12" x 12" Sluice Gate with Hydraulic Float System	6	1,400	0	1,000	100	0	0	0	0.50	N/A
M-51 A	Franklin D. Roosevelt Drive & E. 70th St.	Diversion & Tide Gate Chambers	(Combined Data for M-51, M-51A & M-51B)									
M-51 B	Franklin D. Roosevelt Drive & E. 70th St.	Diversion & Tide Gate Chambers										
M-51 C	Franklin D. Roosevelt Drive & E. 70th St.	Diversion & Tide Gate Chambers	4	1,000	0	0	40	0	60	0	0.30	N/A

NOTES FOR TABLE 5 (M):

Regulator Data - taken from regulator detail sheets (1959) supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control.

TABLE 5 (M)-(Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
M-50	24" ϕ PRCP	3'-6" x 6'-10" FTRC BR INT To 72" ϕ	TWO 5'-0" x 6'-6" FTRC & 15" ϕ VP BR INT	TWO 5'-0" x 6'-6" FTRC	TWO 5'-0" x 6'-6" FTRC	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	26
M-51	---	24" ϕ PRCP BR INT To 72" ϕ	3'-6" x 2'-4" EGG SHAPED BRICK & 24" ϕ BR INT	3'-6" x 2'-4" EGG SHAPED BRICK	3'-6" x 2'-4" EGG SHAPED BRICK	East River	---	---	Chamber flooded (assumed) for protection of hydraulic equipment. Regulator will be put into service when Manhattan Pump Station is completed.	26
M-51 A	---	24" ϕ BR INT To M-51	30" ϕ VP & 24" ϕ PRCP BR INT	30" ϕ VP	30" ϕ VP	East River	---	---	---	26
M-51 B	---	24" ϕ BR INT To M-51 A	3'-0" x 2'-0" BRICK & 15" ϕ BR INT	3'-0" x 2'-0" BRICK	3'-0" x 2'-0" BRICK	East River	---	---	---	26
M-51 C	---	15" ϕ BR INT To M-51 B	2'-0" x 3'-0" BRICK & 8" SANIT. & 8" ACID & 10" STORM	2'-0" x 3'-0" BRICK	2'-0" x 3'-0" BRICK	East River	---	---	---	26

111

NOTES FOR TABLE 5 (M) (CONTINUED):

Line Size Characteristics - taken from regulator detail sheets and Existing Sewer Line Maps of New York.

TABLE 5 (M) - NEWTOWN CREEK TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		


NOTES FOR TABLE 5 (M) (CONTINUED):

Drainage Area Data - for regulators M-47, M-48, M-48A, M-49, M-50 & M-51: boundaries determined from Existing Sewer Line Map of New York City. Acreage calculated from the layout of the drainage area boundaries. for the remaining regulators: taken from records supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control.

Population Data - from data supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control.

Land Use Data - estimated from Land Use Policy Maps in Plan for New York City, A Proposal - 1969, Volume 4-Manhattan prepared by the New York City Planning Commission.

Hydraulic Data - Trunk Line MDWF Data: supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control. For regulators M-1 through M-9 and M-37 through M-51, flows are estimated for the year 2000. For regulators M-10 through M-36, flows are estimated for the year 1970. Interceptor Design Capacity Data: not available.






FIG. 23 NEWTOWN CREEK
 NEW YORK CITY N. Y.
 DRAINAGE BASIN
 AND
 REGULATOR LOCATIONS

FOR






FIG. 24 NEWTOWN CREEK
 NEW YORK CITY N. Y.
 DRAINAGE BASIN
 AND
 REGULATOR LOCATIONS



© Hagstrom Co.

FIG 26 NEWTOWN CREEK NEW YORK CITY N. Y. DRAINAGE AND REGULATOR LOCATIONS



SECTION XI

NORTH RIVER SEWAGE TREATMENT PLANT

DRAINAGE BASIN, NEW YORK, N.Y.

The drainage area contributory to the future North River Sewage Treatment Plant (presently under construction) contains sixty-one regulator structures. Thirty-five consist of sluice gates with hydraulic float systems, twenty are simple diversion or tide gate chambers, four are manual sluice gates with provisions for hydraulic systems. These regulators are in various stages of construction and as such no field inspections were conducted in this drainage area.

The North River Sewage Treatment Plant (operational 1979) will receive influents from four interceptors (expected completion 1974) and will treat approximately 220 million gallons per day of waste.

Additional information regarding the regulators within this drainage area is found in Table 6 and Figures 27 through 32.

TABLE 6 - NORTH RIVER TREATMENT PLANT DRAINAGE BASIN

Regulator Number	Location	Type	NEW YORK, NEW YORK								Trunk Line MDMF (cfs)	Interceptor Design Capacity (cfs)
			Drainage Area (Acres)	Population			Percent Land Use					
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
N-1	Harlem River Dr. near 10th Ave.	12" ϕ Manually Operated Sluice Gate	44	1,000	N/A	N/A	70	0	0	30	0.271	N/A
N-2	Academy Street & W. 201st St.	Tide Gate Chamber	229	47,800	N/A	N/A	85	10	0	5	12.94	N/A
N-3	W. 201st St. & Harlem River Dr.	30" x 24" Sluice Gate With Hydraulic Float System										
N-4	W. 203rd St. & Harlem River Dr.	12" ϕ Manually Operated Sluice Gate with Provisions for Future Hydraulic System	6	100	N/A	N/A	5	0	95	0	0.028	N/A
N-5	W. 205th St. & Harlem River Dr.	12" ϕ Manually Operated Sluice Gate with Provisions for Future Hydraulic System	10	300	N/A	N/A	30	0	70	0	0.080	N/A
N-6	W. 206th St. & Harlem River Dr.	12" ϕ Manually Operated Sluice Gate	3	100	N/A	N/A	30	0	70	0	0.028	N/A
N-7	W. 207th St. & Harlem River Dr.	12" ϕ Manually Operated Sluice Gate	4	100	N/A	N/A	5	0	95	0	0.028	N/A

TABLE 6 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
N-1	--	12" ϕ BR INT	24" ϕ CI	24" ϕ CI	4'-0" ϕ BRICK	Harlem River	--	--	Under Construction	31
N-2	--	--	Two 6'-0"x 7'-0" FTRC	Two 6'-0"x 7'-0" FTRC	Two 6'-0"x 7'-0" FTRC	Harlem River	--	--	Under Construction	-
N-3	--	42" ϕ BR INT	6'-0"x 4'-0"	6'-0"x 4'-0"	6'-0"x 4'-0"	Harlem River	--	--	Under Construction	31
N-4	42" ϕ PRCP	15" ϕ VP BR INT To 42" ϕ PRCP	3'-6"x 2'-4" BRICK	3'-6"x 2'-4" BRICK	3'-6"x 2'-4" BRICK	Harlem River	--	--	Under Construction	31
N-5	42" ϕ PRCP	15" ϕ VP BR INT To 42" ϕ PRCP	4'-0" ϕ BRICK	4'-0" ϕ BRICK	4'-0" ϕ BRICK	Harlem River	--	--	Under Construction	31
N-6	42" ϕ PRCP	15" ϕ VP BR INT To 42" ϕ PRCP	3'-6"x 2'-4" BRICK	3'-6"x 2'-4" BRICK	3'-6"x 2'-4" BRICK	Harlem River	--	--	Under Construction	31
N-7	42" ϕ PRCP	15" ϕ VP BR INT To 42" ϕ PRCP	3'-6"x 2'-4" BRICK	3'-6"x 2'-4" BRICK	3'-6"x 2'-4" BRICK	Harlem River	--	--	Under Construction	31

TABLE 6 - NORTH RIVER TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
N-8	W. 207th St. & Harlem River Dr.	Diversion (Weir) & Tide Gate Chambers	(See Regulator N-7 For Combined Data)									
N-9	IND Subway Yard, South End of Inspection Shed (W. 209th St.)	18" x 12" Sluice Gate With Hydraulic Float System	88	6,800	N/A	N/A	30	10	60	0	1.866	N/A
N-10	IND Subway Yard, East of Inspection Shed (W. 211th St.)	Diversion Chamber (Drop Manhole)										
N-11	IND Subway Yard, East of Inspection Shed (W. 211th St.)	Tide Gate										
N-12	IND Subway Yard, North of Inspection Shed (W. 213th St.)	Diversion (Drop Manhole) & Tide Gate Chambers										
N-13	W. 215th St. & Harlem River Dr.	Diversion Chamber	3	100	N/A	N/A	0	0	100	0	0.028	N/A
N-14	W. 216th St. & Harlem River Dr.	Diversion Chamber	73	3,400	N/A	N/A	0	10	90	0	0.920	N/A

TABLE 6 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
N-8	--	--	3'-6" x 2'-4" x BRICK	3'-6" x 2'-4" x BRICK	5'-0" x 2'-4"	Harlem River	--	--	Under Construction	31
N-9	24" ϕ PRCP	24" ϕ PRCP	3'-6" x 2'-4" x BRICK	3'-6" x 2'-4" x BRICK	4'-0" ϕ BRICK	Harlem River	--	--	Under Construction	31
N-10	18" ϕ VP	24" ϕ VP	4'-6" ϕ BRICK	4'-6" ϕ BRICK	4'-6" ϕ BRICK	Harlem River	--	--	Under Construction	31
N-11	--	--	4'-6" ϕ BRICK	4'-6" ϕ BRICK	4'-6" ϕ BRICK	Harlem River	--	--	Under Construction	-
N-12	18" ϕ VP	18" ϕ VP	4'-0" x 2'-8" x BRICK	4'-0" x 2'-8" x BRICK	4'-0" x 2'-8" x BRICK	Harlem River	--	--	Under Construction	31
N-13	18" ϕ VP	18" ϕ VP	3'-6" x 2'-4" x BRICK	3'-6" x 2'-4" x BRICK	3'-6" x 2'-4" x BRICK	Harlem River	--	--	Under Construction	31
N-14	--	18" ϕ VP BR INT	5'-0" x 4'-0" x BRICK	5'-0" x 4'-0" x BRICK	5'-0" x 4'-0" x BRICK	Harlem River	--	--	Under Construction	31

TABLE 6 - NORTH RIVER TREATMENT PLANT DRAINAGE BASIN (Continued)

Regulator Number	Location	Type	NEW YORK, NEW YORK								Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
			Drainage Area (Acres)	Population			Percent Land Use					
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
N-15	W. 218th St. & Indian Road	12" x 12" Sluice Gate With Hydraulic Float System	69	3,800	N/A	N/A	15	5	0	80	1.029	N/A
N-16	Dyckman St. & Hudson River	30" x 24" Sluice Gate With Hydraulic Float System	494 (Combined Data For Regulators N-16 & N-16A)	40,100	N/A	N/A	45	5	5	45	10.855	N/A
N-16A	Dyckman & Henshaw Streets	Tide Gate & Diversion Chambers										
N-17	W. 190th St. & Riverside Dr.	12" ϕ Manually Operated Shear Gate	26	800	N/A	N/A	10	0	0	90	0.217	N/A
N-18	W. 172nd St. & Fort Washington Park	30" x 34" Sluice Gate With Hydraulic Float System	292	41,200	N/A	N/A	70	0	0	30	12.747	N/A
N-19	W. 158th St & Riverside Dr.	24" x 18" Sluice Gate With Hydraulic Float System	117	31,300	N/A	N/A	70	5	0	25	9.684	N/A
N-20	W. 155th St. & Riverside Dr.	12" x 12" Sluice Gate With Hydraulic Float System	86 (Combined Data For Regulators N-20 Through N-21B)	11,600	N/A	N/A	75	3	0	22	3.589	N/A

TABLE 6 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
N-15	6'-6" x 5'-0"	21" ϕ VP BR INT To 6'-6" x 5'-0" BRICK	2'-4" x 4'-0" FTRC	2'-4" x 4'-0" FTRC	2'-4" x 4'-0" FTRC	Harlem River	--	--	Under Construction	31
N-16	6'-6" x 5'-0"	48" ϕ FRCP BR INT To 6'-6" x 5'-0"	TWO 5'-0" x 7'-0" FTRC	TWO 5'-0" x 7'-0" FTRC	TWO 5'-0" x 7'-0" FTRC	Hudson River	--	--	Under Construction	31
N-16A	--	--	3'-0" ϕ BRICK	3'-0" ϕ BRICK	3'-0" ϕ BRICK	Hudson River	--	--	Under Construction	31
N-17	6'-6" x 6'-6"	15" ϕ VP BR INT To 6'-6" x 6'-6"	16" ϕ CI	16" ϕ CI	16" ϕ CI	Hudson River	--	--	Under Construction	31
N-18	6'-6" x 6'-0"	42" ϕ FRCP BR INT To 6'-6" x 6'-0"	5'-0" x 5'-0" FTRC	5'-0" x 5'-0" FTRC	5'-0" x 5'-0" FTRC	Hudson River	--	--	Under Construction	30
N-19	7'-0" x 6'-6"	1'-9" x 6'-0" BR INT To 7'-0" x 6'-6"	5'-0" x 5'-0" FTRC	5'-0" x 5'-0" FTRC	4'-0" ϕ	Hudson River	--	--	Under Construction	30
N-20	7'-0" x 6'-6"	24" ϕ BR INT To 7'-0" x 6'-6"	3'-6" x 2'-4" BRICK	3'-6" x 2'-4" BRICK	3'-0" ϕ	Hudson River	--	--	Under Construction	30

TABLE 6 - NORTH RIVER TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
N-21	W. 152nd St. & Riverside Dr.	12" x 12" Sluice Gate With Hydraulic Float System	(See Regulator N-20 For Combined Data)									
N-21A	W. 151st St. & Riverside Dr.	Diversion Chamber (Weir)										
N-21B	W. 153rd St. & Riverside Dr.	Diversion Chamber (Weir)										
N-22	W. 138th St & Twelfth Ave.	12" x 12" Sluice Gate With Hydraulic Float System	45	7,400	N/A	N/A	60	0	30	10	2.290	N/A
N-23	St. Clair Place	Two 36" x 24" Sluice Gates With Independent Hydraulic Float Systems	614	167,300	N/A	N/A	60	0	25	15	51.763	N/A
N-24	W. 115th St. & Riverside Dr.	12" x 18" Sluice Gate With Hydraulic Float System	100	13,800	N/A	N/A	65	0	0	35	4.270	N/A
N-25	W. 108th St. & Riverside Dr.	18" x 18" Sluice Gate With Hydraulic Float System	80	22,600	N/A	N/A	80	0	0	20	6.992	N/A

TABLE 6 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
N-21	7'-0" x 6'-6"	15' ϕ BR INT To 7'-0" x 6'-6"	3'-0" BRICK	3'-0" BRICK	3'-0" BRICK	Hudson River	--	--	Under Construction	30
N-21A	--	--	3'-6" x 2'-4"	3'-6" x 2'-4"	3'-0" ϕ	Hudson River	--	--	Under Construction	30
N-21B	--	--	3'-6" x 2'-4"	3'-6" x 2'-4"	3'-0" ϕ	Hudson River	--	--	Under Construction	30
N-22	16'-0" x 16'-0"	24" ϕ BR INT To 16'-0" x 16'-0"	36" ϕ BRICK	36" ϕ BRICK	36" ϕ BRICK	Hudson River	--	--	Under Construction	30
N-23	14'-6" x 14'-6"	4'-3" x 7'-6" BR INT To 16'-0" x 16'-0"	TWO 7'-0" x 8'-8" PTRC	TWO 7'-0" x 8'-8" PTRC	TWO 7'-0" x 8'-8" PTRC	Hudson River	--	--	Under Construction	30
N-24	14'-6" x 14'-6"	30" ϕ BR INT To 14'-6" x 14'-6"	4'-0" x 3'-0" BRICK	4'-0" x 3'-0" BRICK	4'-0" x 3'-0" BRICK	Hudson River	--	--	Under Construction	29
N-25	14'-0" x 14'-0"	36" ϕ BR INT To 14'-6" x 14'-6"	4'-0" ϕ BRICK	4'-0" ϕ BRICK	4'-0" ϕ BRICK	Hudson River	--	--	Under Construction	29

TABLE 6 - NORTH RIVER TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
N-26	W. 96th St. & Riverside Park	Two 30" x 24" Sluice Gates With Independent Hydraulic Float Systems	561 (Combined Data For Regulators N-26 & N-26A)	103,300	N/A	N/A	75	0	0	25	31.961	N/A
N-26A	W. 96th St. & Riverside Park	Diversion & Tide Gate Chambers										
N-27	W. 90th St. & Riverside Dr.	12" x 12" Sluice Gate With Hydraulic Float System	27	3,600	N/A	N/A	20	0	0	80	1.114	N/A
N-28	W. 80th St. & Riverside Park	36" x 42" Sluice Gate With Hydraulic Float System	418	93,100	N/A	N/A	60	15	0	25	28.805	N/A
N-29	W. 72nd St. West of Riverside Dr.	36" x 36" Sluice Gate With Hydraulic Float System	667 (Combined Data For Regulators N-29 & N-29A)	106,500	N/A	N/A	40	30	0	30	32.951	N/A
N-29A	W. 66th St. & Freedom Place	24" x 36" Sluice Gate With Hydraulic Float System										
N-30	W. 59th St. & Twelfth Ave.	12" x 18" Sluice Gate With Hydraulic Float System	96	9,400	12,400	22,300	5	0	95	0	4.004	N/A

TABLE 6 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
N-26	14'-0" x 14'-0"	14'-0" x 14'-0"	--	--	--	--	--	Under Construction	29	
N-26A	--	54" ϕ RC BR INT To N-26	6'-0" x 10'-0"	6'-0" x 10'-0"	6'-0" x 10'-0"	Hudson River	--	--	Under Construction	29
N-27	14'-0" x 14'-0"	18" ϕ BR INT To 14'-0" x 14'-0"	3'-6" x 2'-8" BRICK	3'-6" x 2'-8" BRICK	3'-6" x 2'-8" BRICK	Hudson River	--	--	Under Construction	29
N-28	11'-6" x 11'-6"	5'-0" x 5'-0" BR INT To 14'-0" x 14'-0"	6'-0" x 10'-6" PTRC	6'-0" x 10'-6" PTRC	6'-0" x 10'-6" PTRC	Hudson River	--	--	Under Construction	28
N-29	11'-6" x 11'-6"	6'-0" x 5'-0" BR INT To 11'-6" x 11'-6"	4'-0" x 5'-0" & 7'-0" x 7'-0" PTRC	7'-0" x 7'-0" PTRC	TWO 3'-0" x 4'-0"	Hudson River	--	--	Under Construction	28
N-29A	10'-6" x 10'-6"	60" ϕ BR INT To 11'-6" x 11'-6"	5'-0" x 5'-6" PTRC	5'-0" x 5'-6" PTRC	5'-0" x 5'-6" PTRC	Hudson River	--	--	Under Construction	28
N-30	10'-6" x 10'-6"	30" ϕ BR INT To 10'-6" x 10'-6"	5'-3" x 5'-3" PTRC	5'-3" x 5'-3" PTRC	5'-3" x 5'-3" PTRC	Hudson River	--	--	Under Construction	28

TABLE 6 - NORTH RIVER TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
N-31	W. 56th St. & Twelfth Ave.	12" x 12" Sluice Gate With Hydraulic Float System	52	2,700	10,100	12,100	25	0	70	5	1.569	N/A
N-32	W. 50th St. & Twelfth Ave.	12" x 12" Sluice Gate With Hydraulic Float System	33	2,100	3,500	7,700	0	10	85	5	0.982	N/A
N-33	W. 48th St. & Twelfth Ave.	Two 2'-6" x 3'-6" Sluice Gates With Independent Hydraulic Float Systems	571	100,500	378,300	252,200	15	60	20	5	54.502	N/A
(Combined Data For Regulators N-33 through N-35)												
N-34	W. 48th St. & Twelfth Ave.	Tide Gate										
N-35	W. 47th St. & Twelfth Ave.	Tide Gate										
N-36	W. 46th St. & Twelfth Ave.	12" x 12" Sluice Gate With Hydraulic Float System	26	2,100	4,700	4,300	0	0	100	0	0.964	N/A
(Combined Data For Regulators N-36 & N-37)												
N-37	W. 46th St. & Twelfth Ave.	Tide Gate										
N-38	W. 44th St. & Twelfth Ave.	12" x 12" Sluice Gate With Hydraulic Float System	19	700	2,500	4,400	0	0	100	0	0.421	N/A

TABLE 6 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
N-31	10'-6" x 10'-6"	18" ϕ BR INT To 10'-6" x 10'-6"	4'-6" x 6'-0" FIRC	4'-6" x 6'-0" FIRC	3'-0" ϕ	Hudson River	--	--	Under Construction	28
N-32	8'-6" x 8'-6"	10'-6" x 10'-6"	4'-0" x 4'-0" FIRC	4'-0" x 4'-0" FIRC	TWO 4'-0" x 4'-0"	Hudson River	--	--	Under Construction	28
N-33	8'-6" x 8'-6"	8'-0" x 8'-0" BR INT To 10'-6" x 10'-6"	4'-0" x 9'-0" FIRC	4'-0" x 9'-0" FIRC	4'-0" x 2'-8"	Hudson River	--	--	Under Construction	28
N-34	--	--	4'-0" x 2'-8" FIRC	4'-0" x 2'-8" FIRC	4'-0" x 2'-8" FIRC	Hudson River	--	--	Under Construction	28
N-35	--	--	4'-0" x 2'-8" FIRC	4'-0" x 2'-8" FIRC	4'-0" x 2'-8" FIRC	Hudson River	--	--	Under Construction	-
N-36	8'-6" x 8'-6"	15" ϕ VP BR INT To 8'-6" x 8'-6"	4'-0" ϕ RC	4'-0" ϕ RC	4'-0" ϕ WOOD	Hudson River	--	--	Under Construction	28
N-37	--	--	TWO 6'-6" x 8'-6" FIRC	TWO 6'-6" x 8'-6" FIRC	TWO 6'-6" x 8'-6" FIRC	Hudson River	--	--	Under Construction	-
N-38	8'-6" x 8'-6"	15" ϕ BR INT To 8'-6" x 8'-6"	4'-6" ϕ RC	4'-6" ϕ RC	4'-6" ϕ RC	Hudson River	--	--	Under Construction	28

TABLE 6 - NORTH RIVER TREATMENT PLANT DRAINAGE BASIN (Continued)

Regulator Number	Location	Type	NEW YORK, NEW YORK								Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
			Drainage Area (Acres)	Population			Percent Land Use					
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
N-39	W. 43rd St. & Twelfth Ave.	12" x 12" Sluice Gate With Hydraulic Float System	31 (Combined Data For Regulators N-39 Through N-41)	900	3,000	7,200	0	0	100	0	0.575	N/A
N-40	W. 42nd St. & Twelfth Ave.	Diversion (Weir) & Tide Gate Chambers										
N-41	W. 42nd St. & Twelfth Ave.	Tide Gate										
N-42	W. 40th St. & Twelfth Ave.	12" x 12" Sluice Gate With Hydraulic Float System	23	400	1,000	5,400	0	0	100	0	0.295	N/A
N-43	W. 36th St. & Twelfth Ave.	5'-0" x 3'-0" Sluice Gate With Hydraulic Float System	48 (Combined Data For Regulators N-43 & N-44)	6,100	34,600	11,200	0	10	90	0	3.753	N/A
N-44	W. 33rd St. & Twelfth Ave.	Tide Gate										
N-45	N. 30th St. & Twelfth Ave.	Two 24" x 30" Sluice Gates With Independent Hydraulic Float Systems	347	42,200	284,000	189,300	5	55	40	0	30.631	N/A

TABLE 6 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
N-39	8'-6" x 8'-6"	18" ϕ VP BR INT To 8'-6" x 8'-6"	4'-0" x 2'-8" BRICK	4'-0" x 2'-8" BRICK	4'-0" x 2'-8" BRICK	Hudson River	--	--	Under Construction	26
N-40	--	--	4'-6" x 9'-0" SEMI- CIRC BRICK	4'-6" x 9'-0" SEMI- CIRC BRICK	4'-6" x 9'-0" SEMI- CIRC BRICK	Hudson River	--	--	Under Construction	26
N-41	--	--	TWO 2'-0" x 8'-0" BRICK	TWO 2'-0" x 8'-0" BRICK	TWO 2'-0" x 8'-0" BRICK	Hudson River	--	--	Under Construction	-
N-42	8'-6" x 8'-6"	15" ϕ BR INT To 8'-6" x 8'-6"	5'-6" x 2'-8" FTRC	5'-6" x 2'-8" FTRC	5'-6" x 2'-8" FTRC	Hudson River	--	--	Under Construction	26
N-43	8'-0" x 8'-0"	24" ϕ BR INT To 8'-0" x 8'-0"	4'-0" ϕ BRICK	4'-0" ϕ BRICK	4'-0" ϕ BRICK	Hudson River	--	--	Under Construction	27
N-44	--	--	4'-6" x 4'-9"	4'-6" x 4'-9"	4'-6" x 4'-9"	Hudson River	--	--	Under Construction	-
N-45	8'-0" x 8'-0"	6'-0" x 6'-0" BR INT To 8'-0" x 8'-0"	4'-0" ϕ BRICK & 4'-0" ϕ CONC & 6'-0" x 11'-0" FTRC	4'-0" ϕ BRICK & 4'-0" ϕ CONC & 6'-0" x 11'-0" FTRC	6'-0" x 11'-0" & 4'-0" ϕ BRICK	Hudson River	--	--	Under Construction	27

TABLE 6 - NORTH RIVER TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
N-46	W. 26th St. & Twelfth Ave.	18" x 12" Sluice Gate With Hydraulic Float System	78	10,600	13,400	18,200	60	10	20	10	4.313	N/A
N-47	W. 23rd St. & Twelfth Ave.	24" x 12" Sluice Gate With Hydraulic Float System	67	12,600	6,800	17,300	50	50	0	0	4.616	N/A
N-48	W. 21st St. & Eleventh Ave.	12" x 18" Sluice Gate With Hydraulic Float System	66 (Combined Data For Regulators N-48 & N-49)	11,500	4,600	15,400	70	0	30	0	4.127	N/A
N-49	W. 21st St. & Eleventh Ave.	Tide Gate & Diversion (Weir) Chambers										
N-50	W. 18th St. & Eleventh Ave.	3'-0" x 2'-6" Sluice Gate With Hydraulic Float System	166	10,600	126,000	84,000	10	50	40	0	11.046	N/A
N-51	W. 17th St. & Eleventh Ave.	18" x 24" Sluice Gate With Hydraulic Float System	110 (Combined Data For Regulators N-51 & N-52)	16,500	34,200	25,700	10	40	50	0	7.286	N/A
N-52	W. 14th St. & Eleventh Ave.	Tide Gate										
N-53	Bloomfield & West Streets	Tide Gate & Diversion Chamber	26 (Combined Data For Regulators N-53 & N-54)	1,800	6,700	6,100	2	8	90	0	1.009	N/A

TABLE 6 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
N-46	7'-0" x 7'-0"	30" ϕ BR INT To 8'-0" x 8'-0"	5'-7" x 6'-3" BRICK	5'-7" x 6'-3" BRICK	5'-7" x 6'-3" BRICK	Hudson River	--	--	Under Construction	27
N-47	7'-0" x 7'-0"	30" ϕ BR INT To 7'-0" x 7'-0"	5'-6" x 6'-6"	5'-6" x 6'-6"	4'-0" ϕ	Hudson River	--	--	Under Construction	27
N-48	7'-0" x 7'-0"	30" ϕ BR INT To 7'-0" x 7'-0"	4'-0" ϕ BRICK	4'-0" ϕ BRICK	4'-0" ϕ BRICK	Hudson River	--	--	Under Construction	27
N-49	--	--	6'-4" x 4'-6" PTRC	6'-4" x 4'-6" PTRC	4'-0" ϕ	Hudson River	--	--	Under Construction	27
N-50	5'-6" x 5'-0"	60" ϕ BR INT To 7'-0" x 7'-0"	5'-6" x 8'-0" PTRC	5'-6" x 8'-0" PTRC	5'-0" x 3'-9" & 5'-0" x 4'-6"	Hudson River	--	--	Under Construction	27
N-51	30" ϕ	36" ϕ BR INT To 5'-0" x 5'-0"	4'-6" ϕ BRICK	4'-6" ϕ BRICK	4'-6" ϕ BRICK	Hudson River	--	--	Under Construction	27
N-52	--	--	4'-0" x 6'-0"	4'-0" x 6'-0"	4'-0" x 6'-0"	Hudson River	--	--	Under Construction	-
N-53	30" ϕ	12" ϕ VP BR INT To 30" ϕ	4" ϕ CI & 5" ϕ CI	12" ϕ VP	3'-6" x 2'-4" BRICK	Hudson River	--	--	Under Construction	27

TABLE 6 - NORTH RIVER TREATMENT PLANT DRAINAGE BASIN (Continued)

NEW YORK, NEW YORK												
Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
N-54	Gansevoort St. & North River	12" x 12" Sluice Gate With Hydraulic Float System	(See Regulator N-53 For Combined Data)									
N-55	West & Jane Streets	18" x 12" Sluice Gate With Hydraulic Float System	56	7,500	10,700	13,000	50	5	45	0	3.117	N/A
N-56	West & Bank Streets	12" x 12" Sluice Gate With Hydraulic Float System	19	2,100	3,700	4,400	70	10	20	0	0.917	N/A

140

NOTES FOR TABLE 6:

Regulator Data - taken from regulator detail sheets (1965) supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control.

Drainage Area Data - for regulators N-1, N-18, N-32 & N-38 through N-42: boundaries determined from Existing Sewer Line Maps of New York City. Acreage calculated from the layout of the drainage area boundaries.
for the remaining regulators: taken from records supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control.

Population Data - from data supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control (for the year 2000).

Land Use Data - estimated from Land Use Policy Maps in Plan for New York City, A Proposal-1969, Volume 4-Manhattan prepared by the New York City Planning Commission.


Hydraulic Data - taken from data supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control (projected for the year 2000).

TABLE 6 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk	By-Pass	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream	Line	Line						
N-54	30" ϕ	18" ϕ BR INT To 30" ϕ	4'-0" x 2'-8" BRICK	4'-0" x 2'-8" BRICK	4'-0" ϕ BRICK	Hudson River	--	--	Under Construction	27
N-55	30" ϕ	24" ϕ BR INT To 30" ϕ	4'-0" x 3'-8" PTRC	4'-0" x 3'-8" PTRC	4'-0" ϕ	Hudson River	--	--	Under Construction	27
N-56	--	18" ϕ BR INT To 18" ϕ	4'-0" x 3'-8"	4'-0" x 3'-8"	4'-0" ϕ	Hudson River	--	--	Under Construction	27

141

NOTES FOR TABLE 6 (CONTINUED):Line Size Characteristics - taken from regulator detail sheets and Existing Sewer Line Maps of New York City.






FIG. 28 NORTH RIVER
 NEW YORK CITY
 DRAINAGE BASIN AND
 REGULATOR LOCATIONS

FOR

ADJOINING

AREA

SEE

FIG. 30

PAGE



PORTION OF N23 DRAINAGE BASIN

N24

14'-6" X 14'-6"

N25

14'-6" X 14'-6"

DIV. & T.G.

N26d

FIG. 29 NORTH RIVER
NEW YORK CITY N. Y.
DRAINAGE BASIN AND
REGULATOR LOCATIONS

N26

N27

PORTION OF N28 DRAINAGE BASIN

14'-0" X 14'-0"

FOR

ADJOINING


AREA

SEE

FIG. 28

PAGE

FOR ADJOINING AREA SEE FIG. 31 PAGE



SCALE IN FEET
0 1000 2000 3000

FIG. 30 NORTH RIVER
NEW YORK CITY N. Y.
DRAINAGE BASIN AND
REGULATOR LOCATIONS

FOR ADJOINING AREA SEE FIG. 29 PAGE





FIG. 31 NORTH RIVER
 NEW YORK CITY N. Y.
 DRAINAGE BASIN AND
 REGULATOR LOCATIONS

FOR ADJOINING AREA SEE FIG. 30 PAGE



SECTION XII

OWLS HEAD SEWAGE TREATMENT PLANT

DRAINAGE BASIN, BROOKLYN, N. Y.

The Owls Head drainage basin contains eight regulators; six with hydraulic float systems and two with manually operated sluice gates.

The system is maintained by the Oakwood Beach regulator crew. This crew also maintains the Port Richmond Treatment Plant regulator system. A specially prepared truck with sufficient equipment is utilized to assist in the inspection and maintenance of the system.

Seven of the eight regulators inspected were found to be inoperable. According to a follow-up telephone conversation with the Acting Chief of the Division of Plant Operations for New York City, one of the non-operable regulators has been put back into service.

Additional information regarding the regulators within this drainage area is found in Table 7 and Figures 33 through 37.

TABLE 7 - OWLS HEAD TREATMENT PLANT DRAINAGE BASIN

BROOKLYN, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
1	92nd Street & Shore Parkway	Two 6'-0" x 4'-0" Sluice Gates with Independent Hydraulic Float Systems	2,700 (Combined Data For Regulators 1 & 9)	580,000	N/A	N/A	80	10	5	5	N/A	109.5
2	82nd Street East of Shore Parkway	16" x 16" Manually Operated Sluice Gate	93	N/A	N/A	N/A	95	0	0	5	N/A	N/A
3	79th Street East of Shore Parkway	2'-0" x 3'-0" Sluice Gate With Hydraulic Float System	513	85,000	N/A	N/A	85	10	0	5	N/A	15.6
4	71st Street East of Shore Parkway	1'-6" x 2'-0" Sluice Gate With Hydraulic Float System	159	20,000	N/A	N/A	90	10	0	0	N/A	3.8
5	69th Street & Shore Road	1'-4" x 1'-4" Manually Operated Sluice Gate	9	N/A	N/A	N/A	90	10	0	0	N/A	N/A
6	First Avenue & 64th Street	Two 5'-0" x 3'-0" Sluice Gates With Independent Hydraulic Float Systems	5,122 (Combined Data For Regulators 6, 8, 8-A, 8-B and 9-A)	697,500	N/A	N/A	70	15	10	5	N/A	128.7
7	First Avenue & 49th Street	5'-0" x 3'-0" Sluice Gate With Hydraulic Float System	1,836 (Combined Data For Regulators 7 Thru 7-D)	200,000	N/A	N/A	70	15	15	0	N/A	39.0

TABLE 7 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
1	--	96" ϕ Arch	11'-0" ϕ Brick	Three 7'-4" x 7'-4" Brick	Three 7'-4" x 7'-4" Brick	Upper New York Bay	11-4-71	No	Originally designed as a hydraulic regulator; however, all equipment and mechanical devices are missing. Regulator crew has built a weir at entrance to outfall line.	34
2	96" ϕ Arch	16" ϕ CI BR INT to 96" ϕ Arch	30" x 45" Brick	30" x 45" Brick	30" x 45" Brick	Upper New York Bay	11-4-71	No	Unable to move sluice gates due to rusted condition of equipment.	34
3	96" ϕ Arch	36" ϕ BR INT to 108" ϕ Arch	12'-0" x 7'-0" Brick Lined Conc	12'-0" x 7'-0" Brick Lined Conc	12'-0" x 7'-0" Brick Lined Conc	Upper New York Bay	11-4-71	No	Heavy water leakage from relief pressure valve on hydraulic system hookup. Tide gate leaking.	34
4	9'-0" Arch	24" ϕ CI INT BR to 9'-0" Arch	60" Oval Brick	60" Oval Brick	60" Oval Brick	Upper New York Bay	11-4-71	No	Needs maintenance and repair. City water supply leaking from elbow on hydraulic system hookup. Tide gate leaking slightly.	35
5	9'-0" Arch	9'-0" Arch	36" ϕ	36" ϕ	36" ϕ	Upper New York Bay	11-4-71	No	Unable to move sluice gates due to rusted condition of equipment. Tide gate in good condition.	35
6	6'-0" ϕ RC	9'-0" x 7'-0" RC BR INT to 12'-6" x 8'-0" RC	15'-0" ϕ Brick & 42" Brick Egg-shaped	Three 7'-6" Brick Arch & 30" Brick Egg-shaped	Three 7'-6" Brick Arch	Upper New York Bay	11-4-71	No	Hydraulic system does not operate because there is no City Water supply to operate system. Tide gates in good condition.	35
7	--	6'-0" ϕ RC	--	--	10'-0" ϕ Brick	Upper New York Bay	11-4-71	No	Four-way valve is missing (being repaired). Regulator gate is being held open. Seals on tide gate need repair.	35

TABLE 7 - OWLS HEAD TREATMENT PLANT DRAINAGE BASIN (Continued)

BROOKLYN, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
7-A	First Avenue & 49th Street	Diversion Chamber (Weir)	(See Regulator 7 For Combined Data)									
7-B	First Avenue & 49th Street	Diversion Chamber (Weir)	(See Regulator 7 For Combined Data)									
7-C	First Avenue & 49th Street	Diversion Chamber (Weir)	(See Regulator 7 For Combined Data)									
7-D	First Avenue & 43rd Street	Diversion Chamber (Weir)	(See Regulator 7 For Combined Data)									
8	Rogers Avenue & Martense Street	3'-0" x 2'-0" Sluice Gate With Hydraulic Float System	(See Regulator 6 For Combined Data)									
8-A	Flatbush & Bedford Avenues	Diversion Chamber	(See Regulator 6 For Combined Data)									
8-B	Foster Avenue & East 21st Street	Diversion Chamber	(See Regulator 6 For Combined Data)									
9	17th & Bath Avenues	Diversion Chamber (Weir)	(See Regulator 1 For Combined Data)									
9-A	17th Avenue & 60th Street	Diversion Chamber (Weir)	(See Regulator 6 For Combined Data)									

TABLE 7 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
7-A	--	--	9'-0" ϕ Brick	9'-0" ϕ Brick	10'-0" ϕ Brick	Upper New York Bay	--	--	--	-
7-B	--	--	60" Brick Egg-shaped	60" Brick Egg-shaped & 6'-0" ϕ RC	10'-0" ϕ Brick	Upper New York Bay	--	--	--	-
7-C	--	--	30" Brick Egg-shaped	30" Brick Egg-shaped & 4'-0" ϕ RC	10'-0" ϕ Brick	Upper New York Bay	--	--	--	-
7-D	--	--	9'-0" ϕ Brick	60" ϕ Brick	60" ϕ Brick	Upper New York Bay	11-4-71	Yes	Needs cleaning. No rungs in chamber -- need ladder for access.	35
8	--	--	8'-0" x 8'-6" RC & 24" ϕ VP	8'-0" x 8'-6" RC	--	--	11-4-71	Yes	Diversion chamber with regulator. If flow to Owls Head plant too great flow is diverted to Coney Island plant. Regulator has no direct discharge.	37
8-A	--	--	--	--	--	--	--	--	--	37
8-B	--	--	--	--	--	--	11-3-71	Yes	--	37
9	--	--	15'-0" ϕ	15'-0" ϕ	21'-0" ϕ	Gravesend Bay	11-3-71	Yes	--	34
9-A	--	--	--	--	--	--	11-3-71	Yes	--	33

TABLE 7 - OWLS HEAD TREATMENT PLANT DRAINAGE BASIN (Continued)

Regulator Number	Location	Type	BROOKLYN, NEW YORK				Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
			Drainage Area (Acres)	Population			Res.	Com.	Ind.	Oth.		
				Residential	Working	Transient						
Avenue V Pump Station	Avenue V & 86th Street	--	1,666	N/A	N/A	N/A	55	20	20	5	N/A	N/A

NOTES FOR TABLE 7:

Regulator Data - taken from regulator detail sheets (1942) supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control.

Drainage Area Data - boundaries determined from Existing Sewer Line Maps of Brooklyn. Acreage calculated from the layout of the drainage area boundaries.

Population Data - from data supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control (for the year 1970).

Land Use Data - estimated from Land Use Policy Maps in Plan for New York City, A Proposal-1969, Volume 3-Brooklyn prepared by the New York City Planning Commission.

Hydraulic Data - taken from data supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control (for the year 1970).

TABLE 7 - (Continued)

Regu- lator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	Date	INSPECTION DATA		Figure No. for Location of Regulator
	Interceptor Line Upstream	Downstream	Trunk Line	By-Pass Line	Outfall			Operable (Yes or No)	Comments	
Avenue V Pump Station	--	24" ϕ CI Force Main & 30" ϕ CI Force Main	48" ϕ & 24" ϕ & 42" ϕ & Three 36" ϕ	Two 36" ϕ CI	Two 36" ϕ CI	Coney Island Creek	11-3-71	Yes	Pump capacities: 2 @ 3500 GPM 1 @ 5000 GPM; 1 @ 6000 GPM 1 @ 9000 GPM; 3 @ 11,000 GPM	33

NOTES FOR TABLE 7 (CONTINUED):

Line Size Characteristics - taken from regulator detail sheets and Existing Sewer Line Maps of Brooklyn.

Inspection Data - according to telephone conversation on June 2, 1972 with the Acting Chief of the Division of Plant Operations, New York Environmental Protection Administration, Division of Water Resources and Water Pollution Control, regulator 7 has been placed into operable condition.




FIG. 33 OWLS HEAD
 BROOKLYN, NEW YORK
 DRAINAGE BASIN AND
 REGULATOR LOCATIONS





FIG. 34 OWLS HEAD
 BROOKLYN, NEW YORK
 DRAINAGE BASIN AND
 REGULATOR LOCATIONS

© Hagstrom Co.

FIG. 35 OWLS HEAD
 BROOKLYN, NEW YORK
 DRAINAGE BASIN AND
 REGULATOR LOCATIONS





© Hagstrom Co.


FOR ADJOINING AREA SEE FIG. 34 PAGE

SEE FIG. 36 PAGE

FIG. 37 OWLS HEAD
 BROOKLYN, NEW YORK
 DRAINAGE BASIN AND
 REGULATOR LOCATIONS







SECTION XIII

PORT RICHMOND SEWAGE TREATMENT

DRAINAGE BASIN, STATEN ISLAND, N.Y.

The Port Richmond drainage system contains forty-three regulators. Nine of these regulators have been placed into service - the others are either under construction or proposed. The nine existing regulators consist of three hydraulically operated types, one mechanical float type, three manually operated types and two weir types.

Three of the nine regulators inspected were found to be inoperable. According to a follow-up telephone conversation with the Acting Chief of the Division of Plant Operations for New York City, two of these regulators have been placed into an operable condition and one is being repaired.

The system is maintained by the Oakwood Beach regulator crew. A specially equipped truck is utilized to assist crews in the inspection and maintenance of the system.

Additional information regarding the regulators within this drainage area is found in Table 8 and Figures 38 through 43.

TABLE 6 - PORT RICHMOND TREATMENT PLANT DRAINAGE BASIN
STATEN ISLAND, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
R-1 (Contract 2)	Richmond Terrace West of Holland Avenue	12" ϕ Manually Operated Shear Gate	208	400	0	N/A	30	0	40	30	0.186	5.053
R-2 (Contract 2)	Richmond Terrace and South Avenue	12" ϕ Manually Operated Shear Gate	20	300	0	N/A	80	0	20	0	0.100	5.317
R-3 (Contract 2)	Harbor Road North of Richmond Terrace	24" x 12" Sluice Gate With Hydraulic Float System	430	10,700	500	N/A	70	5	10	15	5.673	36.735
R-4 (Contract 2)	Union Avenue North of Richmond Terrace	12" ϕ Manually Operated Shear Gate	45	900	400	N/A	90	0	10	0	0.310	37.665
R-5 (Contract 2)	Richmond Terrace & Housman Avenue	1'-0" x 1'-0" Sluice Gate With Hydraulic Float System	132	2,100	600	N/A	60	0	40	0	1.628	41.385
R-6 (Contract 2)	Richmond Terrace & Nicholas Avenue	30" x 24" Sluice Gate With Hydraulic Float System	1,932	23,600	2,200	N/A	75	0	10	15	6.153	69.130
R-1 (Contract 4-A)	Nautilus Court North of Cliff Street	1'-0" x 1'-0" Sluice Gate With Hydraulic Float System	476	5,900	400	300	52	0	0	42	1.352	10.193

(Combined Data for Regulators R-1, R-2 & R-3 (Contract 4-A))

TABLE 8 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
R-1 (Cont. 2)	18" ϕ VP	24" ϕ VP	Two 12" ϕ VP	15" ϕ VP	15" ϕ VP	Newark Bay	12-3-71	Yes	Tide gate leaking	41
R-2 (Cont. 2)	24" ϕ VP	12" ϕ VP BR INT To 24" ϕ VP	8" ϕ VP	8" ϕ VP	10" ϕ CI	Newark Bay	12-3-71	Yes	--	41
R-3 (Cont. 2)	42" ϕ PRCP	30" ϕ RC BR INT To 54" ϕ PRCP	52" ϕ CONC & 15" ϕ VP	52" ϕ CONC & 15" ϕ VP	52" ϕ CONC & 15" ϕ VP	Newark Bay	12-3-71	No	Blockage in return line to interceptor has caused closing of sluice gate and overflow to bay.	41
R-4 (Cont. 2)	54" ϕ PRCP	15" ϕ VP BR INT to 60" ϕ PRCP	37" X 62" SEMI-CIRC RC & 12" ϕ VP	37" X 62" SEMI-CIRC RC & 12" ϕ VP	37" X 62" SEMI-CIRC RC & 12" ϕ VP	Newark Bay	12-3-71	Yes	--	41
R-5 (Cont. 2)	60" ϕ RC	60" ϕ RC	12" ϕ & TWIN 71 1/2" X 33" RC	TWIN 71 1/2" X 33" RC	TWIN 71 1/2" X 33" RC	Newark Bay	12-3-71	No	Piston for hydraulic apparatus missing - was defective - Gate being kept in open position - Maximum flow to plant. Tide gate leaking.	41
R-6 (Cont. 2)	60" ϕ RC	54" ϕ RC	TWIN 104" X 60" PTRC	TWIN 104" X 60" PTRC	TWIN 104" X 60" PTRC	Kill Van Kull	12-3-71	Yes	--	40
R-1 (Cont. 4-A)	--	12" ϕ VP BR INT	6'-6"X 5'-11" SEMI-CIRC PTRC & 36" ϕ PRCP	7'-6" X 5'-0" RC with SEMI-CIRC NOTCH	7'-6"X 5'-11" with SEMI-CIRC NOTCH	Upper New York Bay	--	--	To be constructed	38

TABLE 8 - PORT RICHMOND TREATMENT PLANT DRAINAGE BASIN (Continued)

STATEN ISLAND, NEW YORK													
Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)	
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.			
R-2 (Contract 4-A)	Nautilus Court North of Cliff Street	----	(SEE REGULATOR R-1 (CONTRACT 4-A) FOR COMBINED DATA)										
R-3 (Contract 4-A)	Nautilus Street East of Bay Street	1'-0" X 2'-0" Sluice Gate with Hydraulic Float System	(SEE REGULATOR R-1 (CONTRACT 4-A) FOR COMBINED DATA)										
R-4 (Contract 4-A)	Hylan Boulevard & Edgewater Street	12" ϕ Manually Operated Shear Gate	9	100	0	0	100	0	0	0	0.026	10.475	
R-5 (Contract 4-A)	Edgewater Street North of Sylva Lane	12" ϕ Manually Operated Shear Gate with Provisions for Future Hydraulic Float System	18	200	100	100	13	0	87	0	0.071	10.751	
R-6 (Contract 4-A)	Edgewater Street North of Sylvaton Terrace	12" ϕ Manually Operated Shear Gate with Provisions for Future Hydraulic Float System	2	0	N/A	N/A	0	0	100	0	0.003	10.758	
R-7	Lynhurst Avenue & Edgewater Street	2'-0" X 1'-0" Sluice Gate with Hydraulic Float System	326	5,900	200	100	67	0	17	16	2.213	17.288	
R-8	Edgewater Street North of Camden Street	12" ϕ Manually Operated Shear Gate	50	600	0	100	39	0	61	0	0.197	18.372	

TABLE 8 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
R-2 (CONT. 4-A)	12" ϕ VP BR INT	12" ϕ DI BR INT	--	--	--	--	--	To Be Constructed	38	
R-3 (CONT. 4-A)	--	30" ϕ PRCP	6'-4" ϕ RC & 12" ϕ VP	6'-4" ϕ RC	--	--	--	To Be Constructed	38	
R-4 (CONT. 4-A)	30" ϕ PRCP	30" ϕ PRCP	10" ϕ VP & 12" ϕ	10" ϕ VP	10" ϕ VP	Upper New York Bay	--	To Be Constructed	38	
R-5 (CONT. 4-A)	30" ϕ PRCP	30" ϕ PRCP	18" ϕ VP & 15" ϕ VP	15" ϕ VP	18" ϕ VP	Upper New York Bay	--	To Be Constructed	38	
R-6 (CONT. 4-A)	30" ϕ PRCP	12" ϕ BR INT To 30" ϕ PRCP	12" ϕ VP	16" ϕ VP	16" ϕ VP	Upper New York Bay	--	To Be Constructed	39	
R-7	30" ϕ PRCP	24" ϕ BR INT To 36" ϕ PRCP	TWIN 3'-6" x 6'-4" RC 20" ϕ VP & 12" ϕ VP	TWIN 3'-6" x 6'-4" RC	TWIN 3'-6" x 6'-4" RC	Upper New York Bay	--	To Be Constructed	39	
R-8	36" ϕ PRCP	42" ϕ PRCP	TWO 18" ϕ VP & 24" ϕ PRCP	36" ϕ PRCP	36" ϕ PRCP	Upper New York Bay	--	To Be Constructed	39	

177

TABLE 8 - PORT RICHMOND TREATMENT PLANT DRAINAGE BASIN (Continued)

Regulator Number	Location	Type	STATEN ISLAND, NEW YORK								Trunk Line MDWP (cfs)	Interceptor Design Capacity (cfs)
			Drainage Area (Acres)	Population			Percent Land Use					
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
R-9	Stapleton Terminal East of Norwood Avenue	1'-0" X 1'-0" Sluice Gate with Hydraulic Float System	72	1,100	100	100	83	0	17	0	0.325	21.554
R-10	Stapleton Terminal East of United States Marine Hospital	12" ϕ Manually Operated Shear Gate with Provisions for Future Hydraulic System	992	12,200	4,800	3,200	81	3	0	16	3.206	52.212
R-11	Stapleton Terminal East of Dock Street	12" ϕ Manually Operated Shear Gate with Provisions for Future Hydraulic System										
R-12	Thompson Street West of Front Street	12" ϕ Manually Operated Shear Gate										
R-13	Canal Street West of Front Street	2'-6" X 2'-6" Sluice Gate With Hydraulic Float System										
R-14	Water Street West of Front Street	12" ϕ Manually Operated Shear Gate	43	200	100	100	24	60	7	0	0.003	52.532

TABLE 8 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
R-9	42" ϕ PRCP	18" ϕ BR INT To 42" ϕ PRCP	48" ϕ PRCP	48" ϕ PRCP	48" ϕ PRCP	Upper New York Bay	--	--	To Be Constructed	39
R-10	42" ϕ PRCP	12" ϕ VP BR INT To 42" ϕ PRCP	16" ϕ VP	16" ϕ VP	16" ϕ VP	Upper New York Bay	--	--	To Be Constructed	39
R-11	42" ϕ PRCP	12" ϕ VP BR INT To 42" ϕ PRCP	3'-6" X 2'-4" BRICK EGG-SHAPED	3'-6" X 2'-4" BRICK EGG-SHAPED	3'-6" X 2'-4" BRICK EGG-SHAPED	Upper New York Bay	--	--	To Be Constructed	39
R-12	42" ϕ PRCP	12" ϕ BR INT To 42" ϕ PRCP	N/A	10" ϕ To R-13	--	--	--	--	To Be Constructed	39
R-13	42" ϕ PRCP	60" ϕ PRCP	TWIN 4'-0" X 9'-5" RC & 36" ϕ & 12" ϕ VP & 15" ϕ VP	TWIN 4'-0" X 9'-5" RC & 36" ϕ	TWIN 4'-0" X 9'-5" RC & 36" ϕ	Upper New York Bay	--	--	To Be Constructed	39
R-14	60" ϕ PRCP	12" ϕ BR INT To 60" ϕ PRCP	N/A	15" ϕ To R-13	--	--	--	--	To Be Constructed	39

TABLE 8 - PORT RICHMOND TREATMENT PLANT DRAINAGE BASIN (Continued)

Regulator Number	Location	Type	STATEN ISLAND, NEW YORK							Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)	
			Drainage Area (Acres)	Population			Percent Land Use					
				Residential	Working	Transient	Res.	Com.	Ind.			Oth.
R-15	Stapleton Terminal East of Baltic Street	1'0"x1'-0" Sluice Gate with Hydraulic Float System	239	3,300	100	100	57	0	43	0	1.006	56.620
R-16	Murray Hulbert Avenue South of Victory Boulevard	2'-6"x2'-6" Sluice Gate with Hydraulic Float System	464	13,000	1,700	1,500	84	4	6	6	3.237	76.544
R-17	Victory Boulevard East of Murray Hulbert Avenue	---	2	0	N/A	N/A	0	35	65	0	0.002	76.602
R-18	Hamilton Avenue & Richmond Terrace	18"x12" Sluice Gate with Hydraulic Float System	36	1,500	1,500	1,000	32	68	0	0	0.379	80.520
R-19	Saint Peters Place & Richmond Terrace	18"x12" Sluice Gate with Hydraulic Float System	61	3,200	3,100	2,100	92	0	0	8	0.805	86.600
R-20	Jersey Street & Richmond Terrace	18"x18" Sluice Gate with Hydraulic Float System	138	7,300	0	0	93	0	7	0	1.662	91.938
R-21	Franklin Avenue & Richmond Terrace	Diversion Chamber (Weir)	33	900	0	0	76	0	24	0	0.231	92.884
R-22	Lafayette Avenue & Richmond Terrace	12" ϕ Shear Gate with Hydraulic Float System	46	1,500	0	0	79	0	21	0	0.351	94.442

TABLE 8 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
R-15	60" ϕ PRCP	66" ϕ PRCP	TWIN 6'-2" X 3'-6" RC & 15" ϕ VP	TWIN 6'-2" X 3'-6" RC & 15" ϕ VP	TWIN 6'-2" X 3'-6" RC & 15" ϕ VP	Upper New York Bay	--	--	To Be Constructed	39
R-16	36" ϕ PRCP	36" ϕ PRCP	2'-0" ϕ RC & 12" ϕ VP	2'-0" ϕ RC	2'-0" ϕ RC	Upper New York Bay	--	--	To Be Constructed	39
R-17	--	36" ϕ PRCP	72" ϕ BRICK	72" ϕ BRICK	72" ϕ BRICK	Upper New York Bay	--	--	To Be Constructed	39
R-18	78" ϕ	24" ϕ PRCP BR INT To 78" ϕ	15" ϕ VP & 24" ϕ PRCP	30" ϕ	1'-10" x 2'-9"	Upper New York	--	--	Under Construction	39
R-19	78" ϕ	24" ϕ PRCP BR INT To 78" ϕ	30" ϕ CI	30" ϕ CI	30" ϕ CI	Upper New York Bay	--	--	Under Construction	39
R-20	78" ϕ	36" ϕ PRCP BR INT To 78" ϕ	4'-6" X 6'-0"	4'-6" X 6'-0"	4'-6" X 6'-0"	Kill Van Kull	--	--	Under Construction	39
R-21	78" ϕ	15" ϕ BR INT To 78" ϕ	6" ϕ	6" ϕ	6" ϕ	Kill Van Kull	--	--	Under Construction	39
R-22	78" ϕ	12" ϕ VP BR INT To 78" ϕ	24" ϕ VP	24" ϕ VP	24" ϕ VP	Kill Van Kull	--	--	Under Construction	39

TABLE 8 - PORT RICHMOND TREATMENT PLANT DRAINAGE BASIN (Continued)

Regulator Number	Location	Type	Drainage Area (Acres)	STATEN ISLAND, NEW YORK			Percent Land Use				Trans Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Population			Res.	Com.	Ind.	Oth.		
				Residential	Working	Transient						
R-23	Richmond Terrace & Clinton Avenue	12" ϕ Shear Gate With Hydraulic Float System	72	1,300	200	200	48	0	10	42	0.322	96.062
R-24	Tysen Street & Richmond Terrace	Diversion Chamber (Weir)	20	700	0	0	68	0	8	24	0.152	96.676
R-25	Richmond Terrace West of Tysen Street	Diversion Chamber (Weir)	8	100	N/A	N/A	100	0	0	0	0.039	96.958
R-26	Richmond Terrace West of Tysen Street	Diversion Chamber (Weir)	12	100	100	100	100	0	0	0	0.051	97.186
R-27	Richmond Terrace & Sailors Smug Harbor	18" x 12" Sluice Gate With Hydraulic Float System	33	100	N/A	N/A	100	0	0	0	0.071	97.400
R-28	Kissel Avenue & Richmond Terrace	18" x 12" Sluice Gate With Hydraulic Float System	292	5,200	700	500	88	0	0	12	1.418	103.732
R-29	Bard Avenue & Richmond Terrace	12" ϕ Shear Gate With Hydraulic Float System	125	3,200	0	0	91	0	5	4	0.801	106.796
R-30	Davis Avenue & Richmond Terrace	Diversion Chamber (Weir)	72	1,700	0	0	96	0	4	0	0.433	108.794

TABLE 8 - (Continued)

Regu- lator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
R-23	78" ϕ	78" ϕ	36" ϕ BRICK	36" ϕ BRICK	36" ϕ BRICK	Kill Van Kull	--	--	Under Construction	40
R-24	--	18" ϕ VP BR INT To R-25	20" ϕ	20" ϕ	20" ϕ	Kill Van Kull	--	--	Under Construction	40
R-25	--	18" ϕ VP BR INT To R-26	15" ϕ	15" ϕ	15" ϕ	Kill Van Kull	--	--	Under Construction	40
R-26	--	18" ϕ VP BR INT To R-27	24" ϕ	24" ϕ	24" ϕ	Kill Van Kull	--	--	Under Construction	40
R-27	78" ϕ	24" ϕ	15" ϕ	18" ϕ VP BR INT From R-26 & 15" ϕ	15" ϕ	Kill Van Kull	--	--	Under Construction	40
R-28	78" ϕ	24" ϕ	20" ϕ	20" ϕ CI	20" ϕ CI	Kill Van Kull	--	--	Under Construction	40
R-29	78" ϕ	18" ϕ VP BR INT To 78" ϕ	8" ϕ VP & 18" ϕ VP	18" ϕ VP	18" ϕ VP	Kill Van Kull	--	--	Under Construction	40
R-30	--	24" ϕ BR INT To 78" ϕ	21" ϕ	12" ϕ	12" ϕ	Kill Van Kull	--	--	Under Construction	40

TABLE 8 - PORT RICHMOND TREATMENT PLANT DRAINAGE BASIN (Continued)

Regulator Number	Location	Type	STATEN ISLAND, NEW YORK							Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)	
			Drainage Area (Acres)	Population			Percent Land Use					
				Residential	Working	Transient	Res.	Com.	Ind.			Oth.
R-31	Elizabeth Avenue & Richmond Terrace	12" ϕ Shear Gate With Hydraulic Float System	5	100	0	0	82	0	18	0	0.028	109.510
R-32	Bement Avenue & Richmond Terrace	12" ϕ Shear Gate With Hydraulic Float System	206	5,200	100	0	96	0	2	0	1.312	114.650
R-33	Broadway & Richmond Terrace	12" x 12" Sluice Gate With Hydraulic Float System	178	4,700	100	100	87	0	13	0	1.187	119.418
R-34	Richmond Terrace East of Taylor Street	18" x 18" Sluice Gate With Hydraulic Float System	177	6,200	N/A	N/A	86	6	8	0	1.471	125.312
R-35	Bodine Street & Richmond Terrace	21" x 40 3/4" Sluice Gate With Mechanical Float System	1,575 (Combined Data for Regulators R-35, R-36 & R-37)	N/A	N/A	N/A	65	5	10	20	N/A	N/A
R-36	Rector Street & Richmond Terrace	Diversion Chamber (Weir) & Tidegate Chamber										
R-37	Richmond Avenue North of Richmond Terrace	Diversion Chamber (Weir)										

TABLE 8 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					INSPECTION DATA				Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall	Receiving Waterway	Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
R-31	78" ϕ	12" ϕ VP BR INT To 84" ϕ	12" ϕ VP Inside 36" ϕ CONC	12" ϕ VP Inside 36" ϕ CONC	12" ϕ VP Inside 36" ϕ CONC	Kill Van Kull	--	--	Under Construction	40
R-32	84" ϕ	18" ϕ VP BR INT To 84" ϕ	12" ϕ VP	12" ϕ VP	12" ϕ VP	Kill Van Kull	--	--	Under Construction	40
R-33	84" ϕ	24" ϕ PRCP BR INT To 84" ϕ	6" ϕ CI & 15" ϕ VP	15" ϕ VP	15" ϕ VP	Kill Van Kull	--	--	Under Construction	40
R-34	84" ϕ	18" ϕ DROP LINE To 84" ϕ	12" ϕ VP & 18" ϕ VP	18" ϕ VP	20" ϕ	Kill Van Kull	--	--	Under Construction	40
R-35	72" ϕ	72" ϕ	16" ϕ CI	16" ϕ CI	16" ϕ CI	Kill Van Kull	11-29-71	Yes	--	40
R-36	54" ϕ	72" ϕ	36" ϕ	4'-0" x 9'-0"	4'-0" x 9'-0"	Kill Van Kull	11-29-71	Yes	--	40
R-37	54" ϕ	15" ϕ BR INT To 54" ϕ	TWIN 16" ϕ CI	TWIN 16" ϕ CI	TWIN 16" ϕ CI	Kill Van Kull	11-29-71	No	Grit and debris blocking flow to interceptor	40

TABLE 8 - PORT RICHMOND TREATMENT PLANT DRAINAGE BASIN (Continued)

STATEN ISLAND, NEW YORK												
Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		

NOTES FOR TABLE 8:

Regulator Data - taken from regulator detail sheets (for regulators R-1 (Contract 2) through R-6 (Contract 2): 1966; for regulator R-1 (Contract 4-A) through R-6 (Contract 4-A) and regulators R-7 through R-34: 1970; for regulators R-35 through R-38: 1950) supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control.

Drainage Area Data - boundaries and acreage taken from maps and data supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control.

Population Data - from data supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control (for regulators R-1 (Contract 2) through R-6 (Contract 2): for the year 1960; for the remaining regulators: for the year 1965).

Land Use Data - for regulators R-1 (Contract 2) through R-6 (Contract 2): estimated from Land Use Policy Maps in Plan for New York City, A Proposal-1969, Volume 6-Statens Island prepared by the New York City Planning Commission. for the remaining regulators: calculated from data (1966) supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control.

Hydraulic Data - taken from data supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control (for the year 1965).

TABLE 8 - (Continued)

Regu- lator Number	LINE SIZE CHARACTERISTICS					INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall	Receiving Waterway	Date	Operable (Yes or No)	

NOTES FOR TABLE 8 (CONTINUED):

Line Size Characteristics - taken from regulator detail sheets and Existing Sewer Line Maps of Staten Island.

Inspection Data - according to telephone conversation on June 2, 1972 with the Acting Chief of the Division of Plant Operations, New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control, regulator R-5 (Contract 2) and R-37 have been placed into operable condition and regulator R-3 (Contract 2) is being repaired.





FIG-38 PORT RICHMOND
STATEN ISLAND, N.Y.
DRAINAGE BASIN
AND
REGULATOR LOCATIONS

FIG 39 PORT RICHMOND
STATEN ISLAND, N.Y.
DRAINAGE BASIN
AND
REGULATOR LOCATIONS








FIG. 40 PORT RICHMOND
STATEN ISLAND, N.Y.
DRAINAGE BASIN
AND
REGULATOR LOCATIONS





**FIG. 42 PORT RICHMOND
STATEN ISLAND, N.Y.
DRAINAGE BASIN
AND
REGULATOR LOCATIONS**

FOR ADJOINING AREA SEE FIG. 40 PAGE




FIG. 43 PORT RICHMOND
STATEN ISLAND, N.Y.
DRAINAGE BASIN
AND
REGULATOR LOCATIONS

SECTION XIV

RED HOOK SEWAGE TREATMENT PLANT

DRAINAGE BASIN, BROOKLYN, N.Y.

The drainage area for the proposed Red Hook Treatment Plant will consist of a sewage system containing twenty-four regulator structures. Nine will consist of sluice gates with hydraulic float systems, nine will be manually actuated shear or sluice gates, two will have sluice gates with mechanical float systems, three will be simple tide or diversion chambers and one will be a manually operated shear gate with provisions for a future hydraulic system. These regulators are all to be constructed and as such no field inspections were conducted in this drainage area.

Additional information regarding the regulators within this drainage area is found in Table 9 and Figures 44 through 45.

TABLE 9 - RED HOOK TREATMENT PLANT DRAINAGE BASIN

BROOKLYN, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
R-1	Van Brunt Street South Of Reed Street	12" x 12" Sluice Gate With Hydraulic Float System	34	1,000	1,700	1,100	0	0	100	0	0.314	N/A
R-2	Wolcott & Ferris Streets	36" x 34" & 36" x 24" Sluice Gates With Independent Mechanical Float Systems	1,218	123,900	54,400	36,300	50	0	40	10	31.032	N/A
R-3	Sullivan Street West of Ferris Street	12" ϕ Manually Operated Shear Gate	6	100	300	200	50	0	40	10	0.029	N/A
R-4	Ferris & King Streets	12" ϕ Manually Operated Shear Gate With Provisions for Future Hydraulic System	10	200	400	300	50	0	40	10	0.060	N/A
R-5	Pioneer & Conover Streets	12" ϕ Manually Operated Shear Gate	10	200	300	200	5	0	95	0	0.070	N/A
R-6	Verona Street West of Inlay Street	12" ϕ Manually Operated Shear Gate	6	200	300	200	5	0	95	0	0.059	N/A
R-7	Commerce Street West of Inlay Street	12" ϕ Manually Operated Shear Gate	6	200	300	200	5	0	95	0	0.220	N/A

TABLE 9 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					INSPECTION DATA				Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall	Receiving Waterway	Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
R-1	--	15" ϕ VP BR INT To 60" ϕ Hor. Ellip. PRCP	30" ϕ BRICK	30" ϕ BRICK	30" ϕ BRICK	Buttermilk Channel	--	--	To Be Constructed	44
R-2	--	60" ϕ Hor. Ellip. PRCP	72" ϕ BRICK & 30" ϕ PRCP	72" ϕ BRICK	72" ϕ BRICK	Buttermilk Channel	--	--	To Be Constructed	44
R-3	--	15" ϕ BR INT To 60" ϕ Hor. Ellip. PRCP	15" ϕ BRICK & 6" ϕ VP	15" ϕ BRICK	15" ϕ BRICK	Buttermilk Channel	--	--	To Be Constructed	44
R-4	--	15" ϕ BR INT To 60" ϕ Hor. Ellip. PRCP	36" ϕ BRICK	36" ϕ BRICK	36" ϕ BRICK	Buttermilk Channel	--	--	To Be Constructed	44
R-5	60" ϕ Hor. Ellip PRCP	15" ϕ BR INT To 60" ϕ Hor. Ellip. PRCP	15" ϕ & 24" ϕ & 12" ϕ	30" ϕ BRICK	30" ϕ BRICK	Buttermilk Channel	--	--	To Be Constructed	44
R-6	60" ϕ Hor. Ellip PRCP	15" ϕ BR INT To 60" ϕ Hor. Ellip PRCP	24" ϕ	24" ϕ	24" ϕ	Buttermilk Channel	--	--	To Be Constructed	44
R-7	60" ϕ Hor. Ellip PRCP	15" ϕ BR INT To 60" ϕ Hor. Ellip. PRCP	24" ϕ	24" ϕ	24" ϕ	Buttermilk Channel	--	--	To Be Constructed	44

TABLE 9 - RED HOOK TREATMENT PLANT DRAINAGE BASIN (Continued)

Regulator Number	Location	Type	Drainage Area (Acres)	BROOKLYN, NEW YORK							Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Population			Percent Land Use					
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
R-8	Bowne Street West of Inlay Street	12" ϕ Manually Operated Sluice Gate	11	300	400	300	5	0	95	0	0.097	N/A
R-9	Hamilton Avenue & Ferry Place	14" x 14" Sluice Gate With Hydraulic Float System	51	3,600	600	400	30	0	70	0	0.928	N/A
R-9A	Sackett Street & Ferry Place	Diversion & Tide Gate Chambers	7	700	300	200	10	0	90	0	0.162	N/A
R-10	Degrain & Van Brunt Streets	12" ϕ Manually Operated Shear Gate	7	500	400	200	15	0	80	5	0.248	N/A
R-11	Kane & Van Brunt Streets	18" x 12" Sluice Gate With Mechanical Float System	50	2,000	700	500	0	0	100	0	0.520	N/A
R-12	Amity & Columbia Streets	42" x 24" Sluice Gate With Hydraulic System	259	35,000	11,700	7,800	50	10	40	0	8.027	N/A

TABLE 9 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line	Trunk Line	By-Pass Line	Outfall	Date		Operable (Yes or No)	Comments		
R-8	60" ϕ Hor. Ellip PRCP	15" ϕ BR INT To 60" ϕ Hor. Ellip. PRCP	24" ϕ	24" ϕ	24" ϕ	Buttermilk Channel	--	--	To Be Constructed	44
R-9	60" ϕ Hor. Ellip. PRCP	21" ϕ BR INT To 66" ϕ PRCP	6'-0" x 7'-3" x BRICK & 15" ϕ BR INT From R-9A	6'-0" x 8'-6" x BRICK	6'-0" x 8'-6" x BRICK	Buttermilk Channel	--	--	To Be Constructed	44
R-9A	--	15" ϕ BR INT To 66" ϕ PRCP	4'-0" ϕ CI	4'-0" ϕ CI	4'-0" ϕ CI	Buttermilk Channel	--	--	To Be Constructed	44
R-10	--	15" ϕ BR INT To 66" ϕ PRCP	TWO 12" ϕ & 15" ϕ VP	18" ϕ	18" ϕ	Buttermilk Channel	--	--	To Be Constructed	44
R-11	66" ϕ PRCP	24" ϕ BR INT To 66" ϕ PRCP	18" ϕ & 54" EGG- SHAPED BRICK	54" EGG- SHAPED BRICK	54" EGG- SHAPED BRICK	East River	--	--	To Be Constructed	44
R-12	102" ϕ Hor. Ellip.	108" ϕ PRCP	90" ϕ FIRC	8'-6" x 8'-6" x FIRC	8'-6" x 8'-6" x FIRC	East River	--	--	To Be Constructed	44

TABLE 9 - RED HOOK TREATMENT PLANT DRAINAGE BASIN (Continued)

BROOKLYN, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
R-13	Atlantic Avenue West of Columbia Street	12" x 12" Manually Operated Sluice Gate	10	400	1,000	700	60	10	20	10	0.136	N/A
R-14	Joralemon Street West of Furman Street	12" ϕ Manually Operated Shear Gate	2	0	300	200	0	0	100	0	0.012	N/A
R-15	Montague Street West of Furman Street	18" x 12" Sluice Gate With Hydraulic Float System	36	5,700	1,000	700	50	10	38	2	1.283	N/A
R-16	Furman & Orange Streets	12" x 12" Sluice Gate With Hydraulic Float System	12	100	1,200	800	60	10	15	15	0.074	N/A
R-17	Fulton & Furman Streets	18" x 30" Sluice Gate with Hydraulic Float System	131	10,400	19,100	12,700	60	10	15	15	2.967	N/A
R-18	Main & Plymouth Streets	18" x 12" Sluice Gate with Hydraulic Float System	13	100	3,900	2,600	10	0	80	10	0.141	N/A
R-18 A	Washington & Plymouth Streets	Diversion & Tide Gate Chambers	21	200	3,300	2,200	10	0	80	10	1.221	N/A

TABLE 9 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
R-13	108" ϕ	12" ϕ VP BR INT To 108" ϕ	24" ϕ	24" ϕ	24" ϕ	East River	--	--	To Be Constructed	44
R-14	108" ϕ	12" ϕ VP BR INT To 108" ϕ PRCP	18" ϕ VP	18" ϕ VP	18" ϕ VP	East River	--	--	To Be Constructed	44
R-15	108" ϕ	24" ϕ PRCP BR INT To 108" ϕ PRCP	4'-0" x 4'-0"	4'-0" x 4'-0"	4'-0" x 4'-0"	East River	--	--	To Be Constructed	44
R-16	108" ϕ	108" ϕ	TWO 15" ϕ VP	18" ϕ VP	18" ϕ VP	East River	--	--	To Be Constructed	44
R-17	108" ϕ Tunnel	42" ϕ BR INT To 108" ϕ Tunnel	6'-0" x 6'-0" FTRC & 18" ϕ VP	6'-0" x 6'-0" FTRC	6'-0" x 6'-0" FTRC	East River	--	--	To Be Constructed	44
R-18	108" ϕ Tunnel	24" ϕ BR INT To 108" ϕ Tunnel	24" ϕ BRICK & 24" ϕ RC FROM R-18 A	36" ϕ RC	36" ϕ RC	East River	--	--	To Be Constructed	44
R-18 A	--	24" ϕ RC To REG. R-18	36" ϕ BRICK	36" ϕ BRICK	36" ϕ BRICK	East River	--	--	To Be Constructed	44

TABLE 9 - RED HOOK TREATMENT PLANT DRAINAGE BASIN (Continued)

BROOKLYN, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
R-19	John & Adams Streets	12" ϕ Manually Operated Shear Gate	3	0	600	400	0	0	100	0	0.025	N/A
R-19 A	John & Pearl Streets	Diversion & Tide Gate Chambers	47	600	5,700	3,800	15	0	85	0	0.551	N/A
R-20	Gold & Plymouth Streets	TWO 36" x 40" Sluice Gates with Hydraulic Float Systems	963	114,400	78,700	52,500	40	20	35	5	28.421	N/A
R-21	Hudson & Plymouth Streets	12" x 12" Sluice Gate with Hydraulic Float System	17	0	1,200	800	0	0	100	0	0.087	N/A

NOTES FOR TABLE 9:

Regulator Data - taken from regulator detail sheets (1970) supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control.

Drainage Area Data - boundaries determined from Existing Sewer Line Map of Brooklyn. Acreage taken from data (1962) supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control.

Population Data - from data supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control (for the year 2000).

Land Use Data - estimated from Land Use Policy Maps in Plan for New York City, A Proposal-1969, Volume 3-Brooklyn prepared by the New York City Planning Commission.

Hydraulic Data - taken from data supplied by New York City Environmental Protection Administration, Division of Water Resources and Water Pollution Control (for the year 2000).


TABLE 9 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
R-19	108" ϕ Tunnel	108" ϕ BR INT To 108" ϕ Tunnel	15" ϕ BRICK & 18" ϕ VP FROM R-19A	15" ϕ BRICK	15" ϕ BRICK	East River	--	--	To Be Constructed	44
R-19 A	--	18" ϕ VP To REG R-19	36" ϕ BRICK	36" ϕ BRICK	36" ϕ BRICK	East River	--	--	To Be Constructed	44
R-20	108" ϕ Tunnel	6'-0" x 7'-0" PIRC BR INT To 108" ϕ Tunnel	13'-6" ϕ BRICK	13'-6" ϕ BRICK	13'-6" ϕ BRICK	East River	--	--	To Be Constructed	45
R-21	108" ϕ Tunnel	18" ϕ VP BR INT To 108" ϕ Tunnel	4'-6" x 7'-3" BRICK & 18" ϕ VP	4'-6" x 7'-3" BRICK	4'-6" x 7'-3" BRICK	East River	--	--	To Be Constructed	45


NOTES FOR TABLE 9 (CONTINUED):Line Size Characteristics - taken from regulator detail sheets and Existing Sewer Line Maps of Brooklyn.

FIG. 44
 BROOKLYN,
 DRAINAGE
 BASIN AND
 REGULATOR

RED HOOK
 NEW YORK
 BASIN AND
 LOCATIONS



© Hagstrom Co.



PAGE

FIG. 44

SEE

AREA

FOR ADJOINING

THE

AREA

FIG. 45 RED HOOK NEW YORK DRAINAGE BASIN AND REGULATOR LOCATIONS

SCALE IN FEET 0 1000 2000 3000 4000

N

SECTION XV

YONKERS JOINT MEETING SEWAGE TREATMENT PLANT

DRAINAGE BASIN, YONKERS, N.Y.

The sewage system for Yonkers Joint Meeting drainage basin consists of eighteen regulators. Fourteen regulators are mechanical float actuated, three regulators are electrically operated, and one regulator has a stationary weir.

A special crew from the Yonkers Department of Public Works is used to inspect and maintain the regulators on a routine basis.

During the field inspection by the Commission, five of the regulators were found to be non-operable. According to a follow-up telephone conversation with the Chief of Regulator Maintenance, Westchester County Department of Environmental Facilities, repair work is continuing on those regulators which are inoperable.

Additional information regarding the regulators within this drainage area is found in Table 10 and Figures 46 through 47.

TABLE 10 - YONKERS TREATMENT PLANT DRAINAGE BASIN

YONKERS, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWP (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
1	W. of Lamartine Ave. & N. of Babcock Place (In Railroad Yd.)	Stationary Gate with Mechanical Float Actuated 3.6" x 4.8" Moveable Flume	300	7,000	N/A	N/A	70	5	15	10	N/A	N/A
2	Lamartine Ave. West of Woodworth Ave.	Hinged Gate with Mechanical Float System										
3	Ashburton Ave. and Alexander St.	Stationary Gate with Mechanical Float Actuated 4.8" x 4.8" Moveable Flume	170	4,000	N/A	N/A	70	5	20	5	N/A	N/A
4	Ashburton Ave. East of Woodworth Ave.	Hinged Gate with Mechanical Float System										
5	Woodworth Ave. North of Ashburton Ave.	Hinged Gate with Mechanical Float System										
6	Ravine Ave. North of Lamartine Ave.	Hinged Gate with Mechanical Float System	(See Regulator 1 for Combined Data)									
7	Warburton Ave. W. of Fire House (Near Railroad Tracks)	18" x 24" Sluice Gate with Electrically Operated Hydraulic System.	730	4,000	N/A	N/A	80	0	10	10	N/A	N/A

TABLE 10 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
1	---	20" ϕ CI	48" ϕ CI	48" ϕ CI	48" ϕ CI	Hudson River	6/7/72	Yes	---	46
2	66" ϕ RC	16" ϕ CI BR To 72" ϕ RC	30" x 44" EGG SHAPED BRICK	30" x 44" EGG SHAPED BRICK	30" x 44" EGG SHAPED BRICK	Hudson River	6/7/72	No	Float Actuated Hinged Gate Missing.	46
3	20" ϕ CI	12" ϕ CI BR INT To 24" ϕ CI	12" ϕ CI and 48" ϕ BRICK	48" ϕ BRICK	48" ϕ BRICK	Hudson River	6/7/72	Yes	---	46
4	72" ϕ RC	12" ϕ CI BR INT To 72" ϕ RC	24" x 36" EGG SHAPED BRICK	24" x 36" EGG SHAPED BRICK	24" x 36" EGG SHAPED BRICK	Hudson River	6/7/72	Yes	---	46
5	72" ϕ RC	10" ϕ CI BR INT To 72" ϕ RC	18" ϕ	18" ϕ	48" ϕ BRICK	Hudson River	6/7/72	Yes	---	46
6	66" ϕ RC	10" ϕ CI BR INT To 66" ϕ RC	18" ϕ VP	18" ϕ VP	48" ϕ	Hudson River	6/7/72	No	Needs Maintenance.	46
7	66" ϕ RC	66" ϕ RC	48" ϕ CI	48" ϕ CI	48" ϕ CI	Hudson River	6/7/72	--	Not Able to Locate.	47

TABLE 10 - YONKERS TREATMENT PLANT DRAINAGE BASIN (Continued)

YONKERS, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
8	W. of 719 - Warburton Ave. (Near Railroad Tracks)	18" x 18" Sluice Gate with Electrically Operated Hydraulic System.	15	320	N/A	N/A	90	0	10	0	N/A	N/A
9	Roberts Lane East of Railroad Tracks	Sluice Gate with Electrically Operated Hydraulic System	330	3,700	N/A	N/A	80	5	10	5	N/A	N/A
10	Warburton Ave. South of Odell Ave.	Stationary Weir	200	1,500	N/A	N/A	40	5	15	40	N/A	N/A
11	Pier St. Between Bridge & Fernbrook Sts.	Sluice Gate with Mechanical Float System	490 (Combined Data for Regulators 11, 12 & 16)	15,400	N/A	N/A	60	15	10	15	N/A	N/A
12	Pier Street West of Hawthorne Ave.	16" x 34-1/2" Hinged Gate with Mechanical Float System										
13	Ashton Road East of Sunnyside Dr.	16" x 27-1/2" Shear Gate with Mechanical Float System	180	6,100	N/A	N/A	60	15	10	15	N/A	N/A
14	Herriot St. & Buena Vista	18" ϕ Hinged Gate with Mechanical Float System	130	4,200	N/A	N/A	65	10	15	10	N/A	N/A

TABLE 10 - (Continued)

Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
8	66" ϕ RC	18" ϕ CI BR INT To 66" ϕ RC	30" ϕ CI	30" ϕ CI	30" ϕ CI	Hudson River	6/8/72	- -	Not Able to Locate.	47
9	66" ϕ RC	24" ϕ CI BR INT To 66" ϕ RC	30" ϕ CI	30" ϕ CI	30" ϕ CI	Hudson River	6/7/72	No	Equipment Corroded. Gate Frozen in Open Position. Difficult Access.	47
10	60" ϕ RC	12" ϕ CI BR INT To 60" ϕ RC	4'-0" x 4'-0" RC	4'-0" x 4'-0" RC	4'-0" x 4'-0" RC	Hudson River	6/7/72	Yes	- - -	47
11	---	14" ϕ CI BR INT To LUDLOW PUMP HOUSE	3'-1" x 3'-6" EGG SHAPED BRICK & 54" ϕ BRICK	7'-0" x 4'-6" SEMI- CIRCULAR BRICK	7'-0" x 4'-6" SEMI- CIRCULAR BRICK	Hudson River	6/8/72	Yes	- - -	46
12	---	42" ϕ CI BR INT	54" ϕ BRICK	54" ϕ BRICK	54" ϕ BRICK	Hudson River	6/8/72	No	Hinged Gate Frozen in Open Position. No Connection Between Gate and Float.	46
13	---	30" ϕ CI BR INT To 60" ϕ RC	48" ϕ BRICK	48" ϕ BRICK	48" ϕ BRICK	Hudson River	6/8/72	Yes	Difficult to Maintain Equipment Properly Because of Restricted Working Space.	46
14	---	20" ϕ CI BR INT	3'-6" x 2'-7" EGG SHAPED BRICK	3'-6" x 2'-7" EGG SHAPED BRICK	3'-6" x 2'-7" EGG SHAPED BRICK	Hudson River	6/7/72	No	Equipment Corroded.	46

TABLE 10 - YONKERS TREATMENT PLANT DRAINAGE BASIN (Continued)
YONKERS, NEW YORK

Regulator Number	Location	Type	Drainage Area (Acres)	Population			Percent Land Use				Trunk Line MDWF (cfs)	Interceptor Design Capacity (cfs)
				Residential	Working	Transient	Res.	Com.	Ind.	Oth.		
15	Main St. at Railroad Tracks (Inside Pump Station)	Hinged Gate with Mechanical Float System	825	37,900	N/A	N/A	70	10	5	15	N/A	N/A
16	Hawthorne Ave. North of Pier Street	Stationary Gate with Mechanical Float Actuated Moveable Flume	(See Regulator 11 for Combined Data)									
17	New Main St. At Getty Square	36" ϕ Hinged Gate with Mechanical Float System	(See Regulator 15 for Combined Data)									
18	Wells Ave. At Alexander Street	Hinged Gate with Mechanical Float System	80	1,000	N/A	N/A	65	10	10	15	N/A	N/A

NOTES FOR TABLE 10:

Regulator Data - taken from regulator detail sheets (1934) supplied by Westchester County Department of Environmental Facilities.

Drainage Area Data - boundaries taken from Existing Sewer Line Map of Yonkers (1934) supplied by the City of Yonkers Engineering Office. Acreage calculated from Yonkers Census Tract Map supplied by the (Yonkers) City Planning Board.

Population Data - taken from Census Tract Map (for the year 1970) supplied by the (Yonkers) City Planning Board.

Land Use Data - estimated from map in Community Facility Plan adopted June, 1961 by the (Yonkers) City Planning Board.

Hydraulic Data - not available.


TABLE 10 - (Continued)


Regulator Number	LINE SIZE CHARACTERISTICS					Receiving Waterway	INSPECTION DATA			Figure No. for Location of Regulator
	Interceptor Line		Trunk Line	By-Pass Line	Outfall		Date	Operable (Yes or No)	Comments	
	Upstream	Downstream								
15	---	14" ϕ CI BR INT To MAIN ST. PUMP STATION	6'-9" x 6'-9" FLAT TOP BRICK & CONC.	6'-9" x 6'-9" FLAT TOP BRICK & CONC.	6'-9" x 6'-9" FLAT TOP BRICK & CONC.	Hudson River	6/7/72	Yes	---	46
16	---	20" ϕ CI BR INT	28" x 42" EGG SHAPED BRICK	28" x 42" EGG SHAPED BRICK	28" x 42" EGG SHAPED BRICK	Hudson River	6/7/72	Yes	---	46
17	78" ϕ	36" ϕ CI BR INT To 78" ϕ	48" ϕ BRICK	48" ϕ BRICK	48" ϕ BRICK	Hudson River	6/8/72	Yes	---	46
18	---	14" ϕ CI BR INT	48" ϕ BRICK	48" ϕ BRICK	48" ϕ BRICK	Hudson River	6/7/72	Yes	---	46

NOTES FOR TABLE 10 (CONTINUED):

Line Size Characteristics - taken from regulator detail sheets and Existing Sewer Line Map of Yonkers.

Inspection Data - According to phone conversation of June 30, 1972 with Chief of Regulator Maintenance, Westchester County Department of Environmental Facilities, repair work is continuing on those regulators which are inoperable. Also, the two regulators which were not located during the field inspection, were said to be in similar condition as regulator 9.





SECTION XVI

REGULATOR SAMPLINGS AND ANALYSES




It is generally realized that the combined sewer overflows from regulators have an adverse impact upon receiving waters. Nevertheless, there appeared to be a lack of quantitative data within the Interstate Sanitation District to support this contention. Therefore, following inspection of the regulators, the Commission undertook a limited sampling and analysis study of two regulators. (Analyses of all samples were performed by laboratory methods specified in "Standard Methods for the Examination of Water and Wastewater", (2).) One regulator was located in the Bayonne Sewage Treatment Plant drainage and had a mean dry weather flow of approximately 5 MGD (Regulator No. 5). The other regulator (No. B-1) served the Newtown Creek Sewage Treatment Plant drainage basin and had a mean dry weather flow of approximately 50 MGD.

A land use map for Regulator No. 5 located at Ingham Avenue south of East 5th Street in Bayonne is shown on Figure 48, and the land use and demographic characteristics of the drainage basin for this regulator are shown in Table 11. The table shows that this drainage basin is approximately 50% residential and 30% industrial. A location plan of the regulator is shown in Figure 49. Figures 50-A and 50-B are photographs showing flows associated with the regulator.

A 24-hour dry weather sampling of regulator flow consisting of grab samples taken at 3-hour intervals was conducted on Wednesday, April 5, 1972. During this sampling period, no bypass was observed and no precipitation occurred. The regulator gate was fully open with flow variations noted on the field records. On Wednesday, April 12, 1972, a 12-hour dry weather grab sampling was undertaken at this regulator at 3-hour intervals. Again no bypassing was observed and no precipitation occurred during sampling. The analyses of the samples obtained are given in Tables 12 and 13 for April 5 and April 12, respectively.

The data developed is of interest in several respects. The time sequence of samples clearly shows a distinct variation of many of the parameter readings in the daytime compared to nighttime. For instance, the composite sample of the total suspended solids for the daytime period on April 5, 1972, (0900 to 2100) was 156 Mg/L while for the nighttime and early morning hours (2100 to 0900) it was 55 Mg/L (see Table 12). The daytime values on April 12, 1972, for suspended solids given in Table 13 for daylight hours are comparable to those presented in Table 12, although each of the samplings shows a large variability as a function of time.

FIG. 48 LAND USE MAP FOR
REGULATOR "5" INGHAM AVE.
SOUTH OF EAST 5th STREET

-  COMMERCIAL
-  RESIDENTIAL
-  INDUSTRIAL
-  PARKS & OTHER




TABLE 11
 LAND USE AND DEMOGRAPHIC
 CHARACTERISTICS OF DRAINAGE BASIN
 (Regulator 5 - Bayonne)

Population	10,760 (residential)
Area (Acres)	219.0
Population Density	491 people/acre
Land Use	
% residential	50
% commercial	15
% industrial	30
% other	5
Streets	
Total Length (Miles)	9.36
Estimated number of catch basins	175




FIG.49
LOCATION PLAN REG.5
INGHAM AVENUE
AND
EAST FIFTH STREET



FIG. 50-A, TRUNK LINE FLOW TO REGULATOR CHAMBER AT REGULATOR 5, INGHAM AVENUE AND EAST 5TH STREET, BAYONNE, NEW JERSEY



FIG. 50-B, OUTFALL FOR REGULATOR 5, INGHAM AVENUE AND EAST 5TH STREET, BAYONNE, NEW JERSEY

TABLE 12 - REGULATOR 5, EAST 5th STREET AND INGHAM AVENUE

DRY WEATHER SAMPLING RESULTS FOR APRIL 4, 5, 1972

SUMMARY OF THE ANALYSES OF SAMPLES TAKEN WITHIN
 BAYONNE DRAINAGE AREA REGULATOR: 5
 EAST 5TH STREET AND INGHAM AVENUE
 BAYONNE NEW JERSEY 07002

DISCHARGE WATERWAY: KILL VAN KULL I.S.C. WATER CLASSIFICATION: B2

DATE OF SAMPLING: 4/5/72 & 4/6/72 NUMBER OF SAMPLES TAKEN: 11

SAMPLED BY: INTERSTATE SANITATION COMMISSION
 ANALYSES PERFORMED BY: INTERSTATE SANITATION COMMISSION
 I.S.C. INVESTIGATION NUMBER: 8938

PARAMETER	SAMPLE 1 POINT 1 4/5-0900	SAMPLE 2 POINT 1 4/5-1200	SAMPLE 3 POINT 1 4/5-1500	SAMPLE 4 POINT 1 4/5-1800	SAMPLE 5 POINT 1 4/5-2100	SAMPLE 6 POINT 1 4/5-0900 TO 2100
TOTAL SUSPENDED SOLIDS	138	204	242	100	104	156
SETTLABLE SOLIDS	36	54	5	24	8	47
COLIFORM DENSITY	*****	>100000	*****	>100000	*****	*****
BIOCHEMICAL OXYGEN DEMAND	150	185	145	258	212	196
TEMPERATURE	16.0	14.0	14.0	14.0	15.0	*****
PH	7.8	8.2	7.7	7.6	7.2	*****
CHLORIDES	162	118	224	146	143	165
TOTAL CARBON	20	26	30	13	20	22
TOTAL ORGANIC CARBON	13	21	30	13	15	17
OIL AND GREASE	*****	36.6	*****	32.8	*****	*****
TURBIDITY(UNSETTLED SAMPLE) ...	98	460	590	93	85	*****
TURBIDITY(SETTLED SAMPLE)	*****	*****	*****	*****	*****	*****
ORTHO PHOSPHATE - P	7.20	8.44	5.86	3.45	4.36	5.86
AMMONIA - N	16.40	13.30	11.30	12.30	10.60	12.30
NITRITE - N	0.58	0.40	0.52	0.12	0.18	0.30
NITRATE - N	0.56	0.54	0.88	0.22	0.45	0.56
COPPER	*****	0.10	*****	0.10	*****	0.10
ZINC	*****	0.18	*****	0.12	*****	0.12
CHROMIUM	*****	<0.05	*****	<0.05	*****	<0.05
LEAD	*****	0.40	*****	0.20	*****	0.40
NICKEL	*****	<0.10	*****	<0.10	*****	<0.10
CADMIUM	*****	<0.02	*****	<0.02	*****	<0.02
MANGANESE	*****	0.44	*****	0.48	*****	0.48
MERCURY	*****	0.0350	*****	0.0030	*****	0.0270
SILVER	*****	<0.05	*****	<0.05	*****	<0.05
COBALT	*****	<0.05	*****	<0.05	*****	<0.05

TABLE 12 - (CONTINUED)

PARAMETER	SAMPLE 7 POINT 1 4/5-2400	SAMPLE 8 POINT 1 4/6-0300	SAMPLE 9 POINT 1 4/6-0600	SAMPLE 10 POINT 1 4/6-0900	SAMPLE 11 POINT 1 4/5-2100 TO 4/6-0900
TOTAL SUSPENDED SOLIDS	98	64	46	99	55
SETTLABLE SOLIDS	38	*****	2	39	20
COLIFORM DENSITY	*****	*****	>100000	*****	*****
BIOCHEMICAL OXYGEN DEMAND	78	35	42	168	185
TEMPERATURE	10.7	10.0	11.0	12.1	*****
PH	6.4	7.1	7.3	7.6	*****
CHLORIDES	2031	6409	882	314	1498
TOTAL CARBON	9	8	8	16	12
TOTAL ORGANIC CARBON	8	8	4	16	8
OIL AND GREASE	9.4	*****	5.6	*****	*****
TURBIDITY(UNSETTLED SAMPLE) ...	35	16	23	*****	*****
TURBIDITY(SETTLED SAMPLE)	*****	*****	*****	*****	*****
ORTHO PHOSPHATE - P	1.98	0.61	1.17	5.31	2.21
AMMONIA - N	7.30	4.00	5.80	18.90	8.70
NITRITE - N	0.17	0.21	0.21	0.24	0.23
NITRATE - N	0.39	0.47	0.67	0.56	0.45
COPPER	0.05	*****	0.02	*****	0.05
ZINC	0.06	*****	0.06	*****	0.12
CHROMIUM	<0.05	*****	<0.05	*****	<0.05
LEAD	0.20	*****	<0.20	*****	0.20
NICKEL	<0.10	*****	<0.10	*****	<0.10
CADMIUM	<0.02	*****	<0.02	*****	<0.02
MANGANESE	1.12	*****	0.78	*****	0.70
MERCURY	0.0018	*****	0.0020	*****	0.0016
SILVER	<0.05	*****	<0.05	*****	<0.05
COBALT	<0.05	*****	<0.05	*****	<0.05

NOTES:

- (1) POINT 1 SAMPLES TAKEN FROM REGULATOR CHAMBER
POINT 2 SAMPLES TAKEN FROM TIDE GATE CHAMBER
- (2) ALL UNITS ARE MILLIGRAMS PER LITER EXCEPT PH AND THE FOLLOWING:
TEMPERATURE - DEGREES CENTIGRADE
COLIFORM DENSITY - FECAL COLIFORM ORGANISMS PER 100 MILLILITERS
TURBIDITY - JACKSON TURBIDITY UNITS
- (3)

SAMPLE	TYPE OF SAMPLE	FLOW TO INTERCEPTOR LINE (APPROX)
1	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
2	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
3	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
4	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
5	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
6	DRY WEATHER-COMPOSITE	FLOW NOT ESTIMATED
7	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
8	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
9	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
10	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
11	DRY WEATHER-COMPOSITE	FLOW NOT ESTIMATED

TABLE 13 - REGULATOR 5, EAST 5TH STREET AND INGHAM AVENUE

DRY WEATHER SAMPLING RESULTS FOR APRIL 12, 1972

SUMMARY OF THE ANALYSES OF SAMPLES TAKEN WITHIN
 BAYONNE DRAINAGE AREA REGULATOR: 5
 EAST 5TH STREET AND INGHAM AVENUE
 BAYONNE NEW JERSEY 07002

DISCHARGE WATERWAY: KILL VAN KULL I.S.C. WATER CLASSIFICATION: B2

DATE OF SAMPLING: 4/12/72 NUMBER OF SAMPLES TAKEN: 6

SAMPLED BY: INTERSTATE SANITATION COMMISSION
 ANALYSES PERFORMED BY: INTERSTATE SANITATION COMMISSION
 I.S.C. INVESTIGATION NUMBER: 8951

PARAMETER	SAMPLE 1	SAMPLE 2	SAMPLE 3	SAMPLE 4	SAMPLE 5	SAMPLE 6
	POINT 1 0900	POINT 1 1200	POINT 1 1500	POINT 1 1800	POINT 1 2100	POINT 1 0900-2100
TOTAL SUSPENDED SOLIDS	210	324	188	70	36	171
SETTLABLE SOLIDS	72	76	32	40	6	34
COLIFORM DENSITY	*****	>100000	*****	8900	*****	*****
BIOCHEMICAL OXYGEN DEMAND	180	277	194	26	100	150
TEMPERATURE	12.0	13.0	13.0	6.2	10.0	*****
PH	7.7	7.8	7.7	7.6	6.9	*****
CHLORIDES	2862	1968	525	10192	7644	4998
TOTAL CARBON	15	22	13	6	11	14
TOTAL ORGANIC CARBON	11	21	15	4	8	10
OIL AND GREASE	*****	6.5	*****	0.4	*****	*****
TURBIDITY(UNSETTLED SAMPLE) ..	*****	*****	*****	*****	65	220
TURBIDITY(SETTLED SAMPLE)	70	400	250	25	60	190
ORTHO PHOSPHATE - P	6.32	7.66	6.16	0.06	1.30	3.70
AMMONIA - N	29.00	11.10	15.50	0.80	2.10	12.10
NITRITE - N	0.23	0.20	0.19	0.09	0.15	0.16
NITRATE - N	0.43	0.41	0.48	0.20	0.37	0.33
COPPER	*****	0.02	*****	0.05	*****	0.05
ZINC	*****	0.16	*****	0.06	*****	0.12
CHROMIUM	*****	<0.05	*****	<0.05	*****	0.70
LEAD	*****	0.40	*****	0.40	*****	0.02
NICKEL	*****	<0.10	*****	<0.10	*****	<0.10
CADMIUM	*****	<0.02	*****	<0.02	*****	<0.02
MANGANESE	*****	0.44	*****	0.10	*****	0.22
MERCURY	*****	0.1720	*****	0.0009	*****	0.0484
SILVER	*****	<0.05	*****	<0.05	*****	<0.05
COBALT	*****	<0.05	*****	<0.05	*****	<0.05

NOTES:

- (1) POINT 1 SAMPLES TAKEN FROM REGULATOR CHAMBER
 POINT 2 SAMPLES TAKEN FROM TIDE GATE CHAMBER
- (2) ALL UNITS ARE MILLIGRAMS PER LITER EXCEPT PH AND THE FOLLOWING:
 TEMPERATURE - DEGREES CENTIGRADE
 COLIFORM DENSITY - FECAL COLIFORM ORGANISMS PER 100 MILLILITERS
 TURBIDITY - JACKSON TURBIDITY UNITS
- (3)

SAMPLE	TYPE OF SAMPLE	FLOW TO INTERCEPTOR LINE (APPROX)
1	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
2	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
3	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
4	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
5	DRY WEATHER-GRAB	FLOW NOT ESTIMATED
6	DRY WEATHER-COMPOSITE	FLOW NOT ESTIMATED

The values of the mercury concentrations also show a time dependent variation and in both sampling periods, the highest values occurred at the 12 noon sample which may indicate that the discharge of the mercury into the sewer lines was probably associated with industrial batch processes. This matter is being investigated. Due to lack of extensive rainfall during the scheduled sampling period, wet weather sampling was not performed at this regulator.

The other regulator sampled was the Newtown Creek Regulator (No. B-1), a large regulator designed for dry weather flow of approximately 50 MGD. A land use map for this regulator is given in Figure 51, and Table 14 shows demographic characteristics of the drainage basin. This drainage area is approximately 90% residential. The land use map shows that an industrial area immediately surrounds the regulator with residential areas extending outward from the edge of the industrial area. A location plan of the regulator is shown in Figure 52, and Figure 53-A shows the hydraulically operated sluice gate at the regulator while Figure 53-B shows the outfall of the regulator. The results of the 12-hour and 24-hour samplings are given in Tables 15 and 16, respectively.

During the 12-hour sampling conducted on March 1, 1972, the flow was reasonably uniform throughout the day with a slight increase noted at 6 P.M. Flows were estimated (by measuring liquid height) to be approximately 35 MGD during the uniform flow period and approximately 50 MGD at the 6 P.M. peak. No precipitation or bypass flow occurred during sampling. Strong gaseous odors were evident from the overflow line manhole opening during the sampling period. During the 24-hour sampling which occurred on March 8 and 9, 1972, the flow during the day was fairly uniform and comparable to the previous sampling performed on March 1, 1972, with increased flow again occurring at 6 P.M. During the early morning hours of March 8, a light precipitation occurred with a slight overflow being observed at 9 A.M. As with the Bayonne regulator, large variations in pollutant concentrations occurred between daytime, nighttime, and early morning hours. This holds true not only for the parameters of usual interest such as total suspended solids and BOD, but also for many of the heavy metals such as chromium, nickel, and copper.

The Commission also conducted two wet weather sampling surveys at the Newtown Creek Regulator (No. B-1). Analytical data was developed from the samples taken during two storm periods, April 13 and June 16, 1972. The analytical data for the April 13, 1972, storm is shown in Table 17. The storm flow and pollution loading characteristics during this storm are shown in Table 18, and Figures 54, 55, and 56 show total suspended solids, BOD, and oil and grease concentrations as

FIG. 51 LAND USE MAP FOR
REGULATOR "B-1" JOHNSON AVE.
EAST OF MORGAN AVENUE




TABLE 14

LAND USE AND DEMOGRAPHIC
 CHARACTERISTICS OF DRAINAGE BASIN
 (Regulator B-1) (Newtown Creek)

Population	N/A
Area (Acres)	1408
Population Density	--
Land Use	
% residential	80
% commercial	0
% industrial	15
% other	5
Streets	
Total Length (Miles)	83
Estimated number of catch basins	1400




FIG. 52 LOCATION PLAN
 REG. B-1 JOHNSON AVENUE
 EAST OF MORGAN AVENUE




FIG. 53-A, HYDRAULICALLY OPERATED SLUICE GATE AT REGULATOR B-1,
JOHNSON AVENUE EAST OF MORGAN AVENUE, BROOKLYN, NEW YORK



FIG. 53-B, OUTFALL FOR REGULATOR B-1, JOHNSON AVENUE EAST OF MORGAN
AVENUE, BROOKLYN, NEW YORK

TABLE 15 - REGULATOR B-1, JOHNSON AVENUE EAST OF MORGAN AVENUE

DRY WEATHER SAMPLING RESULTS FOR MARCH 1, 1972

SUMMARY OF THE ANALYSES OF SAMPLES TAKEN WITHIN
 NEWTOWN CREEK DRAINAGE AREA REGULATOR: B-1
 JOHNSON AVENUE EAST OF MORGAN AVENUE
 BROOKLYN NEW YORK

DISCHARGE WATERWAY: NEWTOWN CREEK I.S.C. WATER CLASSIFICATION: B2

DATE OF SAMPLING: 3/ 1/72 NUMBER OF SAMPLES TAKEN: 6

SAMPLED BY: INTERSTATE SANITATION COMMISSION
 ANALYSES PERFORMED BY: INTERSTATE SANITATION COMMISSION
 I.S.C. INVESTIGATION NUMBER: 8897

PARAMETER	SAMPLE 1	SAMPLE 2	SAMPLE 3	SAMPLE 4	SAMPLE 5	SAMPLE 6
	POINT 1 0900	POINT 1 1200	POINT 1 1500	POINT 1 1800	POINT 1 2100	POINT 1 0900-2100
TOTAL SUSPENDED SOLIDS	185	148	112	92	172	30 30 30 30 30 30
SETTLABLE SOLIDS	69	66	68	56	95	30 30 30 30 30 30
COLIFORM DENSITY	30 30 30 30 30 30	45000	30 30 30 30 30 30	80000	30 30 30 30 30 30	30 30 30 30 30 30
BIOCHEMICAL OXYGEN DEMAND	214	246	204	183	223	193
TEMPERATURE	15.5	16.0	17.0	15.0	15.5	30 30 30 30 30 30
PH	7.6	7.9	8.0	7.5	30 30 30 30 30 30	30 30 30 30 30 30
CHLORIDES	143	208	177	148	119	161
TOTAL CARBON	150	180	137	95	96	135
TOTAL ORGANIC CARBON	137	168	126	83	84	122
OIL AND GREASE	30 30 30 30 30 30	53.1	30 30 30 30 30 30	25.8	30 30 30 30 30 30	30 30 30 30 30 30
TURBIDITY (UNSETTLED SAMPLE) ..	78	76	58	52	30 30 30 30 30 30	30 30 30 30 30 30
TURBIDITY (SETTLED SAMPLE)	55	67	50	47	30 30 30 30 30 30	30 30 30 30 30 30
ORTHO PHOSPHATE - P	6.03	3.58	2.83	2.11	1.30	2.96
AMMONIA - N	10.00	7.30	5.50	6.80	4.70	0.60
NITRITE - N	0.27	0.25	0.29	0.18	0.15	0.28
NITRATE - N	1.12	1.05	1.12	0.79	0.60	0.90
COPPER	30 30 30 30 30 30	1.75	30 30 30 30 30 30	0.45	30 30 30 30 30 30	1.30
ZINC	30 30 30 30 30 30	1.12	30 30 30 30 30 30	0.66	30 30 30 30 30 30	0.80
CHROMIUM	30 30 30 30 30 30	0.90	30 30 30 30 30 30	0.55	30 30 30 30 30 30	0.75
LEAD	30 30 30 30 30 30	<0.20	30 30 30 30 30 30	<0.20	30 30 30 30 30 30	<0.20
NICKEL	30 30 30 30 30 30	0.70	30 30 30 30 30 30	0.04	30 30 30 30 30 30	0.04
CADMIUM	30 30 30 30 30 30	0.16	30 30 30 30 30 30	0.06	30 30 30 30 30 30	0.12
MANGANESE	30 30 30 30 30 30	0.08	30 30 30 30 30 30	0.06	30 30 30 30 30 30	0.06
MERCURY	30 30 30 30 30 30	30 30 30 30 30 30	30 30 30 30 30 30	30 30 30 30 30 30	30 30 30 30 30 30	30 30 30 30 30 30
SILVER	30 30 30 30 30 30	0.40	30 30 30 30 30 30	0.02	30 30 30 30 30 30	0.02
COBALT	30 30 30 30 30 30	<0.05	30 30 30 30 30 30	<0.05	30 30 30 30 30 30	<0.05

NOTES:

- (1) POINT 1 SAMPLES TAKEN FROM REGULATOR CHAMBER
 POINT 2 SAMPLES TAKEN FROM DIVERSION CHAMBER
 - (2) ALL UNITS ARE MILLIGRAMS PER LITER EXCEPT PH AND THE FOLLOWING:
 TEMPERATURE - DEGREES CENTIGRADE
 COLIFORM DENSITY - FECAL COLIFORM ORGANISMS PER 100 MILLILITERS
 TURBIDITY - JACKSON TURBIDITY UNITS
 - (3) SAMPLE TYPE OF SAMPLE FLOW TO INTERCEPTOR LINE (APPROX)
- | | | | |
|---|-----------------------|----|-------------------------|
| 1 | DRY WEATHER-GRAB | 35 | MILLION GALLONS PER DAY |
| 2 | DRY WEATHER-GRAB | 35 | MILLION GALLONS PER DAY |
| 3 | DRY WEATHER-GRAB | 40 | MILLION GALLONS PER DAY |
| 4 | DRY WEATHER-GRAB | 40 | MILLION GALLONS PER DAY |
| 5 | DRY WEATHER-GRAB | 35 | MILLION GALLONS PER DAY |
| 6 | DRY WEATHER-COMPOSITE | 37 | MILLION GALLONS PER DAY |

TABLE 16 - REGULATOR B-1, JOHNSON AVENUE EAST OF MORGAN AVENUE

DRY WEATHER SAMPLING RESULTS FOR MARCH 8, 9, 1972

SUMMARY OF THE ANALYSES OF SAMPLES TAKEN WITHIN
 NEWTOWN CREEK DRAINAGE AREA REGULATOR: B-1
 JOHNSON AVENUE EAST OF MORGAN AVENUE
 BROOKLYN NEW YORK

DISCHARGE WATERWAY: NEWTOWN CREEK I.S.C. WATER CLASSIFICATION: B2

DATE OF SAMPLING: 3/8/72 & 3/9/72 NUMBER OF SAMPLES TAKEN: 11

SAMPLED BY: INTERSTATE SANITATION COMMISSION
 ANALYSES PERFORMED BY: INTERSTATE SANITATION COMMISSION
 I.S.C. INVESTIGATION NUMBER: 8902

PARAMETER	SAMPLE 1 POINT 1 3/8-0900	SAMPLE 2 POINT 1 3/8-1200	SAMPLE 3 POINT 1 3/8-1500	SAMPLE 4 POINT 1 3/8-1800	SAMPLE 5 POINT 1 3/8-2100	SAMPLE 6 POINT 1 3/8-0900 TO 2100
TOTAL SUSPENDED SOLIDS	168	154	116	194	84	173
SETTLABLE SOLIDS	78	46	42	82	42	86
COLIFORM DENSITY	*****	<1000	*****	3000	*****	*****
BIOCHEMICAL OXYGEN DEMAND	153	139	253	224	192	189
TEMPERATURE	14.0	14.0	16.0	16.0	15.5	*****
PH	6.7	6.9	9.2	7.9	7.2	*****
CHLORIDES	*****	*****	*****	*****	*****	*****
TOTAL CARBON	87	82	167	148	93	100
TOTAL ORGANIC CARBON	77	73	151	140	72	89
OIL AND GREASE	*****	26.4	*****	31.6	*****	*****
TURBIDITY(UNSETTLED SAMPLE)	55	57	60	69	58	60
TURBIDITY(SETTLED SAMPLE)	44	47	52	62	54	47
ORTHO PHOSPHATE - P	2.47	2.11	2.47	2.60	2.60	2.47
AMMONIA - N	6.80	5.20	6.70	7.10	8.20	7.30
NITRITE - N	0.18	0.18	0.20	0.15	0.15	0.23
NITRATE - N	0.95	0.79	0.75	0.56	0.62	2.77
COPPER	*****	1.00	*****	8.90	*****	2.20
ZINC	*****	0.76	*****	0.64	*****	0.80
CHROMIUM	*****	1.95	*****	0.65	*****	0.75
LEAD	*****	<0.20	*****	<0.20	*****	<0.20
NICKEL	*****	0.80	*****	0.50	*****	0.30
CADMIUM	*****	0.08	*****	0.06	*****	0.10
MANGANESE	*****	0.08	*****	0.06	*****	0.08
MERCURY	*****	<0.0001	*****	<0.0001	*****	<0.0001
SILVER	*****	<0.05	*****	<0.05	*****	<0.05
COBALT	*****	<0.05	*****	<0.05	*****	<0.05

TABLE 16 - (CONTINUED)

PARAMETER	SAMPLE 7 POINT 1 3/8-2400	SAMPLE 8 POINT 1 3/9-0300	SAMPLE 9 POINT 1 3/9-0600	SAMPLE 10 POINT 1 3/9-0900	SAMPLE 11 POINT 1 3/8-2100 TO 3/9-0900
TOTAL SUSPENDED SOLIDS	46	26	38	143	87
SETTLABLE SOLIDS	12	6	10	35	19
COLOFORM DENSITY	>100000	XXXXXXXXXX	>100000	>100000	XXXXXXXXXX
BIOCHEMICAL OXYGEN DEMAND	110	39	43	172	102
TEMPERATURE	14.0	12.0	11.0	11.5	XXXXXXXXXX
PH	7.3	7.9	5.6	XXXXXXXXXX	XXXXXXXXXX
CHLORIDES	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXX
TOTAL CARBON	67	41	32	99	64
TOTAL ORGANIC CARBON	56	31	28	91	56
OIL AND GREASE	12.3	XXXXXXXXXX	9.0	XXXXXXXXXX	XXXXXXXXXX
TURBIDITY(UNSETTLED SAMPLE)	38	21	XXXXXXXXXX	77	45
TURBIDITY(SETTLED SAMPLE).....	32	16	XXXXXXXXXX	75	42
ORTHO PHOSPHATE - P	1.85	1.53	<0.01	2.60	0.71
AMMONIA - N	7.60	4.80	6.40	13.10	10.90
NITRITE - N	0.16	0.13	0.15	0.10	0.22
NITRATE - N	0.56	0.60	0.58	0.90	0.52
COPPER	0.15	XXXXXXXXXX	0.10	XXXXXXXXXX	0.15
ZINC	0.64	XXXXXXXXXX	0.78	XXXXXXXXXX	0.70
CHROMIUM	0.15	XXXXXXXXXX	0.10	XXXXXXXXXX	0.20
LEAD	<0.20	XXXXXXXXXX	<0.20	XXXXXXXXXX	<0.20
NICKEL	0.10	XXXXXXXXXX	<0.10	XXXXXXXXXX	0.10
CADMIUM	0.08	XXXXXXXXXX	0.10	XXXXXXXXXX	0.10
MANGANESE	0.04	XXXXXXXXXX	0.10	XXXXXXXXXX	0.06
MERCURY	<0.0001	XXXXXXXXXX	<0.0001	XXXXXXXXXX	0.0004
SILVER	<0.05	XXXXXXXXXX	<0.05	XXXXXXXXXX	<0.05
COBALT	<0.05	XXXXXXXXXX	<0.05	XXXXXXXXXX	<0.05

NOTES:

- (1) POINT 1 SAMPLES TAKEN FROM REGULATOR CHAMBER
POINT 2 SAMPLES TAKEN FROM DIVERSION CHAMBER
- (2) ALL UNITS ARE MILLIGRAMS PER LITER EXCEPT PH AND THE FOLLOWING:
TEMPERATURE - DEGREES CENTIGRADE
COLIFORM DENSITY - FECAL COLIFORM ORGANISMS PER 100 MILLILITERS
TURBIDITY - JACKSON TURBIDITY UNITS

(3) SAMPLE	TYPE OF SAMPLE	FLOW TO INTERCEPTOR LINE (APPROX)
1	DRY WEATHER-GRAB	50 MILLION GALLONS PER DAY
2	DRY WEATHER-GRAB	40 MILLION GALLONS PER DAY
3	DRY WEATHER-GRAB	35 MILLION GALLONS PER DAY
4	DRY WEATHER-GRAB	35 MILLION GALLONS PER DAY
5	DRY WEATHER-GRAB	30 MILLION GALLONS PER DAY
6	DRY WEATHER - COMPOSITE	42 MILLION GALLONS PER DAY
7	DRY WEATHER-GRAB	30 MILLION GALLONS PER DAY
8	DRY WEATHER-GRAB	30 MILLION GALLONS PER DAY
9	DRY WEATHER-GRAB	30 MILLION GALLONS PER DAY
10	DRY WEATHER-GRAB	35 MILLION GALLONS PER DAY
11	DRY WEATHER- COMPOSITE	31 MILLION GALLONS PER DAY

TABLE 17 - REGULATOR B-1, JOHNSON AVENUE EAST OF MORGAN AVENUE

WET WEATHER SAMPLING RESULTS FOR APRIL 13, 1972

SUMMARY OF THE ANALYSES OF SAMPLES TAKEN WITHIN
 NEWTOWN CREEK DRAINAGE AREA REGULATOR: B1
 JOHNSON AVENUE EAST OF MORGAN AVENUE
 BROOKLYN NEW YORK

DISCHARGE WATERWAY: NEWTOWN CREEK I.S.C. WATER CLASSIFICATION: B2

DATE OF SAMPLING: 4/13/72 NUMBER OF SAMPLES TAKEN: 12

SAMPLED BY: INTERSTATE SANITATION COMMISSION
 ANALYSES PERFORMED BY: INTERSTATE SANITATION COMMISSION
 I.S.C. INVESTIGATION NUMBER: 8954

PARAMETER	SAMPLE 1 POINT 2 1035	SAMPLE 2 POINT 2 1045	SAMPLE 3 POINT 2 1055	SAMPLE 4 POINT 2 1110	SAMPLE 5 POINT 2 1125	SAMPLE 6 POINT 2 1155
TOTAL SUSPENDED SOLIDS	1595	8759	1831	564	388	323
SETTLABLE SOLIDS	1522	8646	1759	497	274	201
COLOFORM DENSITY	*****	*****	*****	*****	*****	*****
BIOCHEMICAL OXYGEN DEMAND	242	428	275	215	186	123
TEMPERATURE	*****	*****	*****	*****	*****	*****
PH	*****	*****	*****	*****	*****	*****
CHLORIDES	32	37	39	39	41	32
TOTAL CARBON	6	12	8	7	7	4
TOTAL ORGANIC CARBON	4	11	8	7	6	3
OIL AND GREASE	46.7	8970.9	1031.3	163.4	*****	*****
TURBIDITY(UNSETTLED SAMPLE)	70	98	65	61	80	65
TURBIDITY(SETTLED SAMPLE)	45	60	44	45	50	41
ORTHO PHOSPHATE - P	*****	*****	*****	*****	*****	*****
AMMONIA - N	*****	*****	*****	*****	*****	*****
NITRITE - N	*****	*****	*****	*****	*****	*****
NITRATE - N	*****	*****	*****	*****	*****	*****
COPPER	0.30	0.30	0.30	0.30	*****	0.20
ZINC	0.54	0.82	0.82	0.70	*****	0.44
CHROMIUM	0.40	0.35	0.55	0.50	*****	0.35
LEAD	0.40	1.40	0.40	0.20	*****	0.20
NICKEL	0.20	0.20	0.30	0.30	*****	0.20
CADMIUM	0.06	0.08	0.08	0.06	*****	0.06
MANGANESE	0.06	0.12	0.08	0.08	*****	0.06
MERCURY	0.0046	0.0023	0.0016	0.0028	*****	0.0007
SILVER	<0.05	<0.05	<0.05	<0.05	*****	<0.05
COBALT	<0.05	<0.05	<0.05	<0.05	*****	<0.05

TABLE 17 - (CONTINUED)

PARAMETER	SAMPLE 7	SAMPLE 8	SAMPLE 9	SAMPLE 10	SAMPLE 11	SAMPLE 12
	POINT 2 1225	POINT 2 1255	POINT 2 1325	POINT 2 1425	POINT 2 1525	POINT 2 1655
TOTAL SUSPENDED SOLIDS	214	248	237	135	132	157
SETTLABLE SOLIDS	146	181	169	80	80	67
COLIFORM DENSITY	*****	*****	*****	*****	*****	*****
BIOCHEMICAL OXYGEN DEMAND	120	86	145	158	103	143
TEMPERATURE	*****	*****	*****	*****	*****	*****
PH	*****	*****	*****	*****	*****	*****
CHLORIDES	32	32	61	62	59	114
TOTAL CARBON	7	4	8	11	11	11
TOTAL ORGANIC CARBON	6	3	8	11	11	11
OIL AND GREASE	*****	*****	*****	*****	*****	*****
TURBIDITY(UNSETTLED SAMPLE).....	50	50	53	52	46	82
TURBIDITY(SETTLED SAMPLE).....	32	34	44	43	40	67
ORTHO PHOSPHATE - P	*****	*****	*****	*****	*****	*****
AMMONIA - N	*****	*****	*****	*****	*****	*****
NITRITE - N	*****	*****	*****	*****	*****	*****
NITRATE - N	*****	*****	*****	*****	*****	*****
COPPER	*****	0.15	*****	0.55	*****	0.85
ZINC	*****	0.26	*****	0.98	*****	1.16
CHROMIUM	*****	0.25	*****	1.15	*****	1.35
LEAD	*****	<0.20	*****	<0.20	*****	0.20
NICKEL	*****	0.20	*****	0.70	*****	0.80
CADMIUM	*****	<0.02	*****	0.16	*****	0.16
MANGANESE	*****	0.04	*****	0.08	*****	0.08
MERCURY	*****	0.0004	*****	0.0007	*****	0.0004
SILVER	*****	<0.05	*****	<0.05	*****	<0.05
COBALT	*****	<0.05	*****	<0.05	*****	<0.05

NOTES:

- (1) POINT 1 SAMPLES TAKEN FROM REGULATOR CHAMBER
POINT 2 SAMPLES TAKEN FROM DIVERSION CHAMBER
- (2) ALL UNITS ARE MILLIGRAMS PER LITER EXCEPT PH AND THE FOLLOWING:
TEMPERATURE - DEGREES CENTIGRADE
COLIFORM DENSITY - FECAL COLIFORM ORGANISMS PER 100 MILLILITERS
TURBIDITY - JACKSON TURBIDITY UNITS
- (3)

SAMPLE	TYPE OF SAMPLE	FLOW TO RECEIVING WATERWAY (APPROX)
1	WET WEATHER-GRAB	43 MILLION GALLONS PER DAY
2	WET WEATHER-GRAB	53 MILLION GALLONS PER DAY
3	WET WEATHER-GRAB	63 MILLION GALLONS PER DAY
4	WET WEATHER-GRAB	80 MILLION GALLONS PER DAY
5	WET WEATHER-GRAB	95 MILLION GALLONS PER DAY
6	WET WEATHER-GRAB	110 MILLION GALLONS PER DAY
7	WET WEATHER-GRAB	130 MILLION GALLONS PER DAY
8	WET WEATHER-GRAB	121 MILLION GALLONS PER DAY
9	WET WEATHER-GRAB	88 MILLION GALLONS PER DAY
10	WET WEATHER-GRAB	23 MILLION GALLONS PER DAY
11	WET WEATHER-GRAB	(SEE NOTE 4)
12	WET WEATHER-GRAB	(SEE NOTE 4)
- (4) NO BY-PASS: FLOW IN DIVERSION CHAMBER THROUGH REGULATOR TO INTERCEPTOR LINE

TABLE 18 REGULATOR B-1, JOHNSON AVE. EAST OF MORGAN AVE.

STORM FLOW AND POLLUTION LOADING CHARACTERISTICS DURING STORM OF APRIL 13, 1972

Sample Number	Time (E.S.T.)	Interval (Min.)	Avg. Dry Weather Flow (CFS)	Runoff (CFS)	Total Flow (CFS)	By-Pass [†] (CFS)	By-Pass (MGD)	Avg. By-Pass During Interval (MGD)	T.S.S. (Mg/L)	Avg. T.S.S. During Interval (Mg/L)	T.S.S. (Lbs.)	B.O.D. (Mg/L)	Avg. B.O.D. During Interval (Mg/L)	B.O.D. (Lbs.)	Oil and Grease (Mg/L)	Avg. Oil & Grease During Interval (Mg/L)	Oil and Grease (Lbs.)	
-	1005		60	56	116	0	0		425*	1010	2269	210*	226	508	36*	42	94	
1	1035	30	60	94	154	38	25	13	1595	5177	9244	242	226	598	47	4509	8051	
2	1045	10	60	112	172	56	36	31	8759	5305	11917	428	335	791	8971	5001	11234	
3	1055	10	60	120	180	64	41	39	1851	5305	5219	275	352	791	1031	597	2579	
4	1110	15	60	146	206	90	58	50	564	1208	5219	215	245	1058	163	597	2579	
5	1125	15	59	165	224	108	70	64	388	476	2632	186	201	1111	110*	137	758	
6	1155	30	59	111	270	154	100	85	323	356	5229	123	155	2277	55*	83	1219	
7	1225	30	58	247	305	189	122	111	214	269	5160	120	122	2340	38*	47	901	
8	1255	30	58	258	316	200	129	126	248	231	5030	86	103	2243	37*	38	827	
9	1325	30	58	241	293	177	115	122	237	243	5123	145	116	2445	36*	37	780	
10	1425	60	58	138	196	80	52	84	135	186	5400	158	152	4413	34*	35	1016	
11	1525	60	56	60	116	0	0	26	132	134	1204	163	162	1456	32*	33	297	
12	1655	90	56	20	76	...	(SEE NOTE A)	...	157	145	-	143	153	-	29*	31	-	
Total By-Pass Loading												58,427	19,240			27,756		


250


NOTES:


[†] Regulator Capacity is estimated to be 116 CFS. By-Pass (CFS) = Total Flow (CFS) - Regulator Capacity (CFS).

*Value obtained from extrapolated data.

A) No By-Pass - Flow in diversion chamber passing through regulator to interceptor line.







a function of time, respectively. An explanation of the column headings and the method of calculation for the various columns in Table 18 are found in Appendix B. Appendix D also lists the terms used in Tables 18 and 20.

Analytical data for the storm that occurred on June 16, 1972, is presented in Table 19. The storm flow and pollution loading characteristics of the storm are given in Table 20 and the total suspended solids, BOD, and oil and grease concentrations are given as a function of time in Figures 57, 58, and 59, respectively.

Estimates of storm runoff for both storm periods were calculated using the rational method. This method probably is the most prevalent one currently used in the United States to estimate the quantities of storm water runoff (23, 24). The rational formula relates runoff to rainfall in the following manner:

$$Q = CIA$$

where: Q = peak runoff
C = runoff coefficient
I = average rainfall intensity
A = drainage area

The runoff coefficient "C", is the least known quantity in the rational equation. It is not easily determined since it includes the effects of several variables such as infiltration capacity, interception by vegetation, and storage in depressions or rooftops. The coefficient represents a fixed ratio of runoff to rainfall in the equation but in reality it varies as a function of time during a storm, from storm to storm, and with the seasons.

Presently, there is no precise method for evaluating the runoff coefficient, although studies have been reported in this area (25). Common engineering practice is to utilize average values of the coefficient for various surface conditions. Values of the coefficient reported in the literature (23, 26, 27, 28) for urban areas range from 0.70 - 0.95. It should be noted that in highly urbanized regions with high percentages of impervious surfaces, the choice of "C" becomes more reasonable as "C" approaches unity and the application of the rational method becomes more suitable.

During this study, the initial value of the runoff coefficient was chosen to be 0.55 (a conservative value) and was incremented by 0.04 for each hour of rainfall to account for further runoff following saturation of the surface. The total flow during each increment was determined by

TABLE 19 - REGULATOR B-1, JOHNSON AVENUE EAST OF MORGAN AVENUE
WET WEATHER SAMPLING RESULTS FOR JUNE 16, 1972

SUMMARY OF THE ANALYSIS OF SAMPLES TAKEN WITHIN
NEWTOWN CREEK DRAINAGE AREA REGULATOR: B-1
JOHNSON AVENUE EAST OF MORGAN AVENUE
BROOKLYN NEW YORK

DISCHARGE WATERWAY: NEWTOWN CREEK I.S.C. WATER CLASSIFICATION: B2

DATE OF SAMPLING: 6/16/72 NUMBER OF SAMPLES TAKEN: 8

SAMPLED BY: INTERSTATE SANITATION COMMISSION
ANALYSES PERFORMED BY: INTERSTATE SANITATION COMMISSION
I.S.C. INVESTIGATION NUMBER: 9035

PARAMETER	SAMPLE 1	SAMPLE 2	SAMPLE 3	SAMPLE 4
	POINT 2	POINT 2	POINT 2	POINT 2
	1540	1550	1600	1610
TOTAL SUSPENDED SOLIDS	531	16804	2312	20244
SETTLABLE SOLIDS	486	16726	2144	20157
COLIFORM DENSITY	*****	*****	*****	*****
BIOCHEMICAL OXYGEN DEMAND	173	321	465	272
TEMPERATURE	*****	*****	*****	*****
PH	*****	*****	*****	*****
CHLORIDES	32	35	50	29
TOTAL CARBON	*****	*****	*****	*****
TOTAL ORGANIC CARBON	*****	*****	*****	*****
OIL AND GREASE	110	4314	248	1216
TURBIDITY (UNSETTLED SAMPLE) ...	75	92	110	83
TURBIDITY (SETTLED SAMPLE)	40	50	110	59
ORTHO PHOSPHATE - P	*****	*****	*****	*****
AMMONIA - N	*****	*****	*****	*****
NITRITE - N	*****	*****	*****	*****
NITRATE - N	*****	*****	*****	*****
COPPER	0.66	0.72	1.49	1.13
ZINC	1.48	2.09	1.65	2.25
CHROMIUM	1.08	0.88	1.21	1.42
LEAD	0.80	1.00	0.80	1.40
NICKEL	0.90	1.30	1.70	1.90
CADMIUM	0.03	0.08	0.36	0.28
MANGANESE	0.15	0.22	0.24	0.22
MERCURY	0.0020	0.0006	0.0010	0.0074
SILVER	*****	*****	*****	*****
COBALT	*****	*****	*****	*****

TABLE 19 - (CONTINUED)

PARAMETER	SAMPLE 5 POINT 2 1625	SAMPLE 6 POINT 2 1640	SAMPLE 7 POINT 2 1710	SAMPLE 8 POINT 2 1730
TOTAL SUSPENDED SOLIDS	7604	1128	420	130
SETTLABLE SOLIDS	7534	1061	383	99
COLIFORM DENSITY	*****	*****	*****	*****
BIOCHEMICAL OXYGEN DEMAND	199	148	82	87
TEMPERATURE	*****	*****	*****	*****
PH	*****	*****	*****	*****
CHLORIDES	18	16	24	21
TOTAL CARBON	*****	*****	*****	*****
TOTAL ORGANIC CARBON	*****	*****	*****	*****
OIL AND GREASE	*****	1008	*****	47
TURBIDITY (UNSETTLED SAMPLE)....	84	72	50	45
TURBIDITY (SETTLED SAMPLE).....	39	40	26	25
ORTHO PHOSPHATE - P	*****	*****	*****	*****
AMMONIA - N	*****	*****	*****	*****
NITRATE - N	*****	*****	*****	*****
NITRATE - N	*****	*****	*****	*****
COOPER	0.67	0.69	0.25	0.25
ZINC	1.55	1.66	0.83	0.71
CHROMIUM	1.17	1.13	0.37	0.21
LEAD	0.70	1.10	0.40	0.40
NICKEL	0.40	0.40	0.30	0.05
CADMIUM	0.13	0.13	0.03	0.03
MANGANESE	0.14	0.18	0.10	0.07
MERCURY	0.0034	0.0023	0.0015	0.0014
SILVER	*****	*****	*****	*****
COBALT	*****	*****	*****	*****

NOTES:

- (1) POINT 1 SAMPLES TAKEN FROM REGULATOR CHAMBER
POINT 2 SAMPLES TAKEN FROM DIVERSION CHAMBER
- (2) ALL UNITS ARE MILLIGRAMS PER LITER EXCEPT PH AND THE FOLLOWING:
TEMPERATURE - DEGREES CENTIGRADE
COLIFORM DENSITY - FECAL COLIFORM ORGANISMS PER 100 MILLILITERS
TURBIDITY - JACKSON TURBIDITY UNITS
- (3)

SAMPLE	TYPE OF SAMPLE	FLOW TO RECEIVING WATERWAY (APPROX)
1	WET WEATHER-GRAB	289 MILLION GALLONS PER DAY
2	WET WEATHER-GRAB	287 MILLION GALLONS PER DAY
3	WET WEATHER-GRAB	286 MILLION GALLONS PER DAY
4	WET WEATHER-GRAB	284 MILLION GALLONS PER DAY
5	WET WEATHER-GRAB	278 MILLION GALLONS PER DAY
6	WET WEATHER-GRAB	267 MILLION GALLONS PER DAY
7	WET WEATHER-GRAB	32 MILLION GALLONS PER DAY
8	WET WEATHER-GRAB	1 MILLION GALLONS PER DAY

TABLE 20 - REGULATOR B-1, JOHNSON AVE. EAST OF MORGAN AVE.

STORM FLOW AND POLLUTION LOADING CHARACTERISTICS DURING STORM OF JUNE 16, 1972

Sample Number	Time (E.S.T.)	Interval (Min.)	Total Flow (CFS)	By-Pass [†] Flow (CFS)	By-Pass Flow (MGD)	Avg. By-Pass During Interval (MGD)	T.S.S. (Mg/L)	Avg. T.S.S. During Interval (Mg/L)	T.S.S. (Lbs.)	B.O.D. (Mg/L)	Avg. B.O.D. During Interval (Mg/L)	B.O.D. (Lbs.)	Oil and Grease (Mg/L)	Avg. Oil & Grease During Interval (Mg/L)	Oil and Grease (Lbs.)
-	1530	10	100	-	-	21	120*	326	394	80*	127	154	33*	72	87
1	1540	10	180	64	41	149	531	8668	74392	173	247	2120	110	2212	18984
2	1550	10	512	396	256	265	16804	17664	269623	321	393	5999	4314	3157	48186
3	1600	10	540	424	274	278	18524**	19384	310392	465	369	5909	2000**	1590	25466
4	1610	15	552	436	282	285	20244	13924	342865	272	236	5811	1180	1140	28071
5	1625	15	560	444	287	286	7604	4366	107886	199	174	4300	1100	1054	26045
6	1640	30	556	440	285	280	1128	774	37449	148	115	5564	1008	584	28256
7	1710	20	540	424	274	265	420	275	8395	82	85	2595	160**	104	3175
8	1730	50	512	396	256	128	130	130	4792	87	90	3318	47	37	1364
-	1820		116	0	0		130*			115*			27*		
Total By-Pass Loading												1,156,188	35,770	179,630	

260


NOTES:

[†] Regulator Capacity is estimated to be 116 CFS. By-Pass (CFS) = Total Flow (CFS) - Regulator Capacity (CFS).

*Extrapolated Value

**Interpolated Value

A) Average Dry Weather Flow: 55-60 CFS during this period.








FIG. 58
FOR REGULATOR B-1 DRAINAGE BASIN
B. O. D. VERSUS TIME
DURING STORM OF JUNE 16, 1972





calculating the runoff flow using the rational equation and adding to that value the mean dry weather flow. A plot of these points versus time determined the shape of the total flow curve during each of the two storms studied. The placement of the total flow curve on the time axis was based upon the time of the observed initial bypass flow. The initial bypass was estimated to occur at 1.5 times the design mean dry weather flow of 50 million gallons a day through the regulator. Actually, there was a slight difference between the observed time of initial bypass and the theoretical time of bypass based upon runoff calculations. This is probably due to the fact that the rainfall data for the storms were obtained at the National Weather Service station at Central Park, a distance of approximately five miles from this regulator.

The total quantity of bypass for each storm was obtained by numerically integrating the function represented by the difference between total flow and initial bypass flow.

The two storms that were sampled were of distinctly different characteristics. During the storm which occurred on April 13, 1972, 0.97 inches of rain fell over a 9-hour period with a peak intensity between 11 A.M. and 12 noon EST of 0.26 inches per hour. As can be seen on Figure 54, the hydrograph of the rainfall approximates a normal distribution and may be considered to be typical of a spring day-long rain storm. The storm previous to this occurred on April 4, more than a week prior, during which 0.31 inches of rain fell.

The storm which occurred on June 16, 1972, was of a completely different nature. During this storm, a total of 1.31 inches of rain fell and as can be seen from the hydrograph on Figure 57, the total rainfall occurred over a 4-hour period. During the initial two hours, 1.22 inches fell with the peak intensity of 0.65 inches per hour occurring between 2 and 3 P.M. EST. This type of storm is perhaps typical of a summer thunderstorm due to its high intensity and short duration. In fact, this storm has established a new record for rainfall on this date. The rainfall previous to the June 16 date occurred on June 10, during which 0.19 inches of rain fell. Trace amounts of rain also fell on June 12, 13, 14, and 15, which totaled approximately 0.01 to 0.02 inches.

An analysis of the total suspended solids, BOD, and oil and grease values for both storms indicates that the nature of the storm, i.e., its intensity and duration, has a large effect upon the pollutants which are bypassed through the regulator. The April 13 storm, which had a relatively long buildup time, allowed the concentration of both parameters (TSS and BOD) to be maximized prior to the peak flow and

thus some of the "first flush" phenomena was diverted to the treatment plant prior to bypassing. In contrast, the June 16 storm had a high initial rainfall rate, such that the maximum values of pollutant concentrations and flow rates practically coincided. For all practical purposes, all of the "first flush" was discharged into the receiving waters with little or none being diverted to the treatment plant.

In both cases, however, the concentration as well as poundage of pollutants bypassed are very large. For instance, on the April 13 storm, 58,000 pounds of total suspended solids, 19,000 pounds of BOD, and 28,000 pounds of oil and grease were bypassed while on the more intense June 16 storm, over 1 million pounds of suspended solids, 36,000 pounds of BOD, and 180,000 pounds of oil and grease were bypassed. To gain some insight into the magnitude of these values, consider that during the June 16 storm, in 3 hours and 15 minutes of bypassing, approximately 30 times as much suspended solids were bypassed as are discharged from the treatment plant in a full 24-hour normal dry weather flow period. BOD and oil and grease discharges were also very high, especially in light of the fact that the flow through this regulator is only 25% of the total Newtown Creek Treatment Plant flow.

As can be seen from the tables of analytical data, during the wet weather flows, some of the heavy metals appear to have higher concentrations than during dry weather. In particular, wet weather lead and mercury concentrations appear to be significantly higher than corresponding dry weather values. As seen in Tables 15 and 16, dry weather lead concentrations (8 values) are all less than 0.20 Mg/L. Wet weather analyses (see Tables 17 and 19) for lead show concentrations ranging from less than 0.20 to 1.40 Mg/L (16 values). The analyses for mercury during dry and wet weather periods have shown a similar trend. The dry weather analyses for mercury (Table 19) show concentrations below 0.0001 Mg/L (5 values). Wet weather concentrations of mercury (Tables 17 and 19) range from 0.0004 to 0.0074 Mg/L (16 values). It is interesting to note that during the June 16 storm, the total quantities of lead and mercury discharged were approximately 135 and 0.4 pounds, respectively. The increased concentration of these metals during wet weather periods could be attributed to automobile exhaust residues, vehicle drippings, and atmospheric scrubbing of lead and mercury aerosol compounds. However, even those metals which show a lower concentration during storms (due to a dilution effect of the stormwater) still discharge a considerable load into the receiving waters.

Treatment plants in general do not remove the large amounts of heavy metals and thus the effect on the receiving waters

should not differ appreciably whether these heavy metals enter directly via bypass flow or indirectly through the treatment plant effluent. It should be noted that even if means were developed to remove these heavy metals at treatment plants (which does not appear to be the general case), this would only allow their removal during dry weather flow. The heavy metals would continue to bypass the treatment plant controls during wet weather flow periods. Thus, it becomes apparent that these heavy metals must be removed at their source before entering the sewer system. Essentially, pretreatment, whether to remove heavy metals or other pollutants, would reduce the load to treatment plants, minimize concentrations in bypass flow, and tend to improve the quality of receiving waters.

If the pollutant values associated with this regulator can be considered representative of the type of bypassing that occurs throughout the District, then some means must be found to minimize the effects of combined sewers, for even though the treatment plants in the District are being expanded and upgraded, this upgrading may not achieve the desired results since the wet weather bypassing may totally overwhelm the receiving waters. In fact, it may be that in determining the efficiency of a treatment system, the results should be evaluated on a systemwide basis; i.e., not only the efficiency of the treatment plant but the net discharge should be considered, including the bypass from combined sewers. Therefore, additional attention needs to be directed toward a total system evaluation of effects, i.e., combined sewers and treatment plants and a minimization of these effects rather than on treatment plants alone.

SECTION XVII

ACKNOWLEDGMENTS

The Interstate Sanitation Commission is indebted to the officials of each of the ten areas studied in this report for their cooperation in supplying necessary data. Special appreciation is made to the officials listed below:

Bayonne, New Jersey

Department of Public Works

Adam Lapinski, Director
Fred James, Plant Superintendent - Water & Sewer Utilities
John Adie, Assistant Plant Superintendent - Water and Sewer Utilities

Bayonne Planning Board

Daniel Hensel, Senior Planner

Hoboken, New Jersey

Department of Public Works

Raphael Vitale, Director
Charles Schmidt, Plant Superintendent
Victor Dauria, Plant Personnel

Housing Authority of the City of Hoboken

M. Edward DeFazio, Executive Director

Jersey City, New Jersey

James Dolan, Chief Engineer - Water and Engineering Division
Robert Sobeck, Plant Superintendent

Allen Cantor, Director - Division of Planning

Nelson S. Silver, Principal Planner - Division of Planning

West New York, New Jersey

Department of Public Works

John Cendo, Commissioner
Frank Oleri, Jr., Plant Superintendent

New York City Plants, New York

Environmental Protection Administration - Department of
Water Resources, Bureau of Water Pollution Control

Martin Lang, Commissioner

William J. Stampe, Administrative Engineer

Harman J. Smity, Senior Civil Engineer

Maurice F. Breen, Senior Civil Engineer - Sanitary

Norman M. Cherry, Senior Civil Engineer

Martin J. Gelvand, Senior Civil Engineer

Edward O. Wagner, Acting Chief - Division of Plant
Operations

William Fotopulis, Chief - Plant Services Section

William Paulmeno, Assistant Civil Engineer

Ralph Cohn, Assistant Mechanical Engineer

The Newtown Creek Regulator Crew

The Oakwood Beach Regulator Crew

Yonkers, New York

Westchester County Department of Environmental Facilities

William Borghard, Commissioner

Ken Wolf, Chief - Regulator and Pump Station Maintenance

The North Yonkers Regulator Crew

City of Yonkers - Engineering Department

Richard Aglietti, Assistant City Engineer

City of Yonkers - Planning Board

Philip Pistone, Director

The guidance and advice provided by the Project Officer,
Mr. Albert W. Bromberg, and the Chief of the Storm and
Combined Sewer Technology Branch, Mr. Richard Field, both of
the Environmental Protection Agency, is acknowledged with
sincere appreciation.

This study was performed under the direction of Dr. Alan I.
Mytelka, Assistant Chief Engineer of the Interstate Sanitation
Commission, with the assistance of the following personnel:

Lawrence P. Cagliostro - Senior Sanitary Engineer

David J. Deutsch - Senior Sanitary Engineer

Clifford A. Haupt - Senior Sanitary Engineer

Special acknowledgment is given to Henry W. Anusiak and
William M. McCormack (Sanitarians) whose efforts in the field
helped to supply the data for this study and to Joseph S.
Czachor (Associate Sanitary Chemist) and the other Commission
Laboratory personnel for performing the required chemical
analyses.

The advice and constructive review of this report by Mr. Thomas R. Glenn, Jr., Director and Chief Engineer of the Interstate Sanitation Commission, is gratefully acknowledged.


SECTION XVIII

REFERENCES

1. Federal Water Pollution Control Administration, "Proceedings, Pollution of the Interstate Waters of the Hudson River and Its Tributaries -- New York and New Jersey, Third Session", U. S. Department of the Interior, June 1969.
2. American Public Health Association, "Standard Methods for the Examination of Water and Wastewater", Thirteenth Edition, 1971, New York, N.Y.
3. American Public Works Association, "Problems of Combined Sewer Facilities and Overflows, 1967", U. S. Department of the Interior, Federal Water Pollution Control Administration, Water Pollution Research Series, WP-20-11, Dec. 1, 1967.
4. American Public Works Association, "Combined Sewer Regulator Overflow Facilities", U. S. Department of the Interior, Federal Water Pollution Control Administration, Water Pollution Research Series, 11022 DMU 07/70.
5. Caster, A.C., "Monitoring Stormwater Overflows", Journal Water Pollution Control Federation, Volume 37, No. 9, September 1965.
6. Minneapolis-Saint Paul Sanitary District, "Dispatching System for Control of Combined Sewer Losses", Environmental Protection Agency, Water Pollution Control Research Series, 11020 FAQ 03/71.
7. Detroit Metro Water Department, Detroit Sewer Monitoring and Remote Control, "Combined Sewer Overflow Abatement Technology", U. S. Department of the Interior, Federal Water Quality Administration, Water Pollution Control Research Series, 11024, 06/70.
8. Municipality of Metro, Seattle, Wash., "Maximizing Storage in Combined Sewer Systems", 11022 ELK, Report for EPA, 12/71.
9. American Public Works Association, "Combined Sewer Regulation & Management - A Manual of Practice", U. S. Department of the Interior, Federal Water Quality Administration, Water Pollution Control Research Series, 11022 DMU 08/70.

10. Field, R., and Struzeski, E., "Management and Control of Combined Sewer Overflows", Journal Water Pollution Control Federation, Volume 44, No. 7, July 1972.
11. Dow Chemical Company, "Chemical Treatment of Combined Sewer Overflows", Environmental Protection Agency-Water Quality Office, Water Pollution Control Research Series, 11023 FDB 09/70.
12. Shuckrow, A.J., "Physical-Chemical Treatment of Combined Sewer Overflows", Paper presented at 44th Annual Meeting, New York Water Pollution Control Assn., New York, January 26-28, 1972.
13. Underwater Storage, Inc., "Control of Pollution by Underwater Storage", Environmental Protection Agency-Water Quality Office, Water Pollution Control Research Series, 11020 DWF 12/69.
14. Dodson, Kinney & Lindblom, "Evaluation of Storm Standby Tanks - Columbus, Ohio", Environmental Protection Agency-Water Quality Office, Water Pollution Control Research Series, 11020 FAL 03/71.
15. Hydrotechnic Corp., "High-Rate Filtration Combined Sewer Overflows", (Contract No. 14-12-858), Environmental Protection Agency-Water Quality Office, Water Pollution Control Research Series, 11023 EYI 12/72.
16. Nebolsine, R., et al, "Ultra High-Rate Filtration System for Treating Overflows from Combined Sewers", Paper presented at 44th Annual Conf., Water Pollution Control Federation, San Francisco, Calif., Oct. 3-8, 1971.
17. Crane Co., "Microstraining and Disinfection of Combined Sewer Overflows", Environmental Protection Agency-Water Quality Office, Water Pollution Control Research Series, 11023 EVO 06/70.
18. Ecology Div., Rex Chainbelt, Inc., "Screening/Flotation Treatment of Combined Sewer Overflows", 11020 FDC 01/72, Report for EPA.
19. Envirogenics Company, "Urban Storm Runoff and Combined Sewer Overflow Pollution", Environmental Protection Agency, Research & Monitoring, Water Pollution Control Research Series, 11024 FKM 12/71.

20. Metcalf & Eddy, Inc., "Storm Water Problems & Control in Sanitary Sewers", Environmental Protection Agency-Water Quality Office, Water Pollution Control Research Series, 11024 EQA 03/71.
21. American Public Works Association, "Prevention and Correction of Excessive Infiltration and Inflow into Sewer Systems", Environmental Protection Agency-Water Quality Office, Water Pollution Control Research Series, 11022 EFF 01/71.
22. U. S. Corps of Engineers, "Joint Pollution Studies on the New York Harbor Model", Miscellaneous Paper No. 2-558, February 1963, Vicksburg, Mississippi.
23. "Design and Construction of Sanitary Storm Sewers", Manual of Engineering Practice, No. 37, American Society of Civil Engineers, New York, 1960.
24. Federal Water Pollution Control Administration, "An Evaluation of the Significance of Combined Sewer Overflows in the Hudson River Conference Area", U. S. Department of the Interior, June 1969.
25. Schaake, J.C., "Report No. XI of the Storm Drainage Research Project", Johns Hopkins University, Dept. of Sanitary Engineering, Baltimore, Md. (1963)
26. Fair & Geyer, "Water Supply and Waste Water Disposal", John Wiley and Sons, Inc., New York, January 1967.
27. Chow, V.T., "Handbook of Applied Hydrology", McGraw Hill Book Company, New York, 1964.
28. Clark, J.A., Viesman, W., and Hammer, M.J., "Water Supply and Pollution Control, Second Edition, International Textbook Company, Scranton, Pa., 1971.



APPENDIX A

FIG. 60
KEY TO LINE DESIGNATIONS
FOR A TYPICAL REGULATOR

APPENDIX B

GLOSSARY AND ABBREVIATIONS

BYPASS (noun) - An arrangement of pipe, conduit, gates, pumps, and valves whereby the flow may be passed around a hydraulic structure or treatment facility.

(verb) - The act of causing flow to pass around a hydraulic structure or treatment facility.

COMBINED SEWER - A sewer which carries sanitary sewage with its component commercial and industrial wastes at all times and which, during storm or thaw periods, serves as the collector and transporter of storm water from streets or other points of origin, thus serving a "combined" purpose. Combined sewers make provision for the overflow of excessive amounts of flow, over and above the volumes to be carried by the interceptor sewers and handled by treatment or pumping facilities, from the combined sewer system at predetermined points where some form of regulator devices are located.

COMBINED SEWER OVERFLOW - Wastewater flow in a combined sewer system resulting from the runoff of precipitation or from the flowing or draining of previous precipitation.

DIVERSION CHAMBER - An enclosure within the regulator which acts to conduct flow from an influent sewage line to the regulator chamber under dry weather conditions. During wet weather (bypass conditions), the flow is directed to the tide gate chamber.

DRY WEATHER FLOW - The combination of sanitary sewage and industrial and commercial wastes normally found in the sanitary sewers during the dry weather season of the year, sometimes referred to as base flow.

DYNAMIC REGULATOR - A semi-automatic or automatic regulator device which may or may not have movable parts that are sensitive to hydraulic conditions at their points of installation and are capable of adjusting themselves to variations in such conditions or of being adjusted by remote control to meet hydraulic conditions at points of installation or at other points in the total combined sewer system.

FORCE MAIN - A pressure pipe joining the pump outlet at a wastewater pumping station with a point of gravity flow.

INTERCEPTOR SEWER - A sewer that receives dry weather flow from a number of transverse sewers or outlets, and frequently additional predetermined quantities of storm water admixed

with sanitary flows, and conducts such wastewaters to a point for treatment or for disposal between the collector sewer and the interceptor sewer.

LOADING - The dry weight, in pounds, of some material that is being added to a process or disposed of to a receiving waterway.

Mg/L - Milligrams per liter or the concentration of some chemical in a liquid. If a letter appears after "Mg" it represents the chemical symbol, e.g., "N" for nitrogen, "P" for phosphorous.

MGD - Million gallons per day -- a common term for quantity of wastewater flow.

OUTFALL SEWER - The outlet, structure, or sewer through which sewage is finally discharged.

OVERFLOWS - The overflowing of trunk or interceptor sewers resulting from the combination of extraneous flows and normal flows that exceed their capacities.

RATIONAL METHOD - A means of computing storm drainage flow rates by use of the formula $Q=CIA$ where Q is the peak runoff, C is a coefficient describing the physical drainage area, I is the rainfall intensity, and A is the drainage area.

REGULATOR - A structure which controls the amount of sewage entering an interceptor by storing in a trunk line or diverting some portion of the flow to an outfall.

REGULATOR CHAMBER - An enclosure which acts to control the quantity of flow of sewage admitted to an intercepting sewer or a unit of a sewage treatment plant.

STATIC REGULATOR - A regulator device which has no moving parts or has movable parts which are insensitive to hydraulic conditions at the point of installation and which are not capable of adjusting themselves to meet varying flow or level conditions in the regulator-overflow structure.

TIDE GATE CHAMBER - An enclosure within the regulator which acts to conduct the sewage flow (usually bypass) through a tide gate to the outfall.

TRUNK - A large sewer which receives wastewater from tributary branch sewers serving generally one drainage area.

ABBREVIATIONS

BR	Branch
CA	Corrugated Aluminum
CB	Circular Brick
CFS	Cubic Feet per Second
CI	Cast Iron
CIRC	Circular
COM	Commercial
CONC	Concrete
FTRC	Flat Top Reinforced Concrete
IND	Industrial
INT	Interceptor
MDWF	Mean Dry Weather Flow
N/A	Not Available
OB	Oval Brick
OTH	Other
PRCP	Pre-cast reinforced concrete pipe
RC	Reinforced concrete
RES	Residential
VP	Vitrified (Clay) pipe
Ø	Diameter

APPENDIX C
LEGEND FOR DRAINAGE BASIN
AND
REGULATOR LOCATION MAPS

-----	LEAD LINE TO REGULATOR'S DRAINAGE AREA
————	LIMITS OF DRAINAGE AREA
————	OUTFALL
————	INTERCEPTOR
REG.	REGULATOR CHAMBER
DIV.	DIVERSION CHAMBER
T.G.	TIDE GATE CHAMBER
○→	REGULATOR NUMBER
●	EXISTING REGULATOR
○	PROPOSED OR UNDER CONSTRUCTION REGULATOR
▲	EXISTING PUMP STATION
△	PROPOSED OR UNDER CONSTRUCTION PUMP STATION
■	EXISTING SEWAGE TREATMENT PLANT
□	PROPOSED OR UNDER CONSTRUCTION SEWAGE TREATMENT PLANT

APPENDIX D

TERMS USED IN TABLES 18 and 20

Sample Number - Consecutively numbered grab samples taken from overflow during storm.

Time (EST) - Eastern Standard Time used in all cases.

Interval (Min.) - Time interval between grab samples.

Avg. Dry Weather Flow (CFS) - Based on limited field observations made during dry weather sampling.

Total Flow (CFS) - Sum of Avg. Dry Weather Flow and Runoff.

Bypass (CFS) - Difference between Total Flow and Regulator's Capacity.

Bypass (MGD) - Conversion Factor: $0.649 \times (\text{CFS}) = (\text{MGD})$.

Avg. Bypass During Interval (MGD) - $\overline{\text{Flow}}$ (MGD).

TSS (Mg/L) - Values from laboratory analyses of wet weather samples.

Avg. TSS During Interval (Mg/L) - $\overline{\text{Conc.}}$ (Mg/L).

TSS (Lbs) - $\overline{\text{Conc.}}$ (Mg/L) \times 8.34 Lbs/Gal \times $\overline{\text{Flow}}$ (MGD) \times Interval (Min./24 \times 60).

BOD (Mg/L) - Values from laboratory analyses of wet weather samples.

Avg. BOD During Interval (Mg/L) - $\overline{\text{Conc.}}$ (Mg/L).

BOD (Lbs) - $\overline{\text{Conc.}}$ (Mg/L) \times 8.34 Lbs/Gal \times $\overline{\text{Flow}}$ (MGD) \times Interval (Min./24 \times 60).

Oil and Grease (Mg/L) - Values from laboratory analyses of wet weather samples.

Avg. Oil and Grease During Interval (Mg/L) - $\overline{\text{Conc.}}$ (Mg/L).

Oil and Grease (Lbs) - $\overline{\text{Conc.}}$ (Mg/L) \times 8.34 Lbs/Gal \times $\overline{\text{Flow}}$ (MGD) \times Interval (Min./24 \times 60).

$\overline{\text{XXX}}$ - Average value of parameter.